



MALCOLM X ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MALCOLM X ELEMENTARY	WS- 009887	8/19/2016	1	Food Prep Sink	In kitchen second clockwise from entry door	FT-82016-009887-A	< 1	FT-82016-009887-B	< 1
2	MALCOLM X ELEMENTARY	WS- 009888	8/19/2016	1	Cooler	In multi-purpose room	FT-82016-009888-A	< 1	FT-82016-009888-B	< 1
3	MALCOLM X ELEMENTARY	WS- 009889	8/19/2016	1	Cooler	In health suite	FT-82016-009889-A	< 1	FT-82016-009889-B	< 1
4	MALCOLM X ELEMENTARY	WS- 009891	8/19/2016	1	Cooler	In hallway adjacent to room 109	FT-82016-009891-A	< 1	FT-82016-009891-B	< 1
5	MALCOLM X ELEMENTARY	WS- 009893	8/19/2016	1	Cooler	In hallway adjacent to room 115	FT-82016-009893-A	< 1	FT-82016-009893-B	< 1
6	MALCOLM X ELEMENTARY	WS- 009894	8/19/2016	1	Cooler	In hallway across from room 132	FT-82016-009894-A	< 1	FT-82016-009894-B	< 1
7	MALCOLM X ELEMENTARY	WS- 009895	8/19/2016	1	Fountain	In classroom 130	FT-82016-009895-A	< 1	FT-82016-009895-B	< 1
8	MALCOLM X ELEMENTARY	WS- 009897	8/19/2016	1	Cooler	In classroom 131	FT-82016-009897-A	< 1	FT-82016-009897-B	< 1
9	MALCOLM X ELEMENTARY	WS- 009900	8/19/2016	2	Cooler	In hallway adjacent to room 208	FT-82016-009900-A	< 1	FT-82016-009900-B	< 1
10	MALCOLM X ELEMENTARY	WS- 009901	8/19/2016	2	Cooler	In hallway across from room 202	FT-82016-009901-A	< 1	FT-82016-009901-B	< 1
11	MALCOLM X ELEMENTARY	WS- 009902	8/19/2016	2	Cooler	In hallway adjacent to room 218	FT-82016-009902-A	< 1	FT-82016-009902-B	< 1
12	MALCOLM X ELEMENTARY	WS- 009904	8/19/2016	2	Fountain	In classroom 225	FT-82016-009904-A	< 1	FT-82016-009904-B	< 1
13	MALCOLM X ELEMENTARY	WS- 009906	8/19/2016	2	Fountain	In classroom 226	FT-82016-009906-A	< 1	FT-82016-009906-B	< 1
14	MALCOLM X ELEMENTARY	WS- 009907	8/19/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-009907-A	< 1	FT-82016-009907-B	< 1
15	MALCOLM X ELEMENTARY	WS- 009908	8/19/2016	3	Cooler	In hallway across from room 303	FT-82016-009908-A	< 1	FT-82016-009908-B	< 1