



Mann Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003935	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 150 High Left	WF-09062022-003935	12/30/2022	FT-FY23-11182022-003935-A	1.4	FT-FY23-11182022-003935-B	<1
WS- 003936	4/20/2022	4/20/2023	1	Combo Fountain	In classroom 150 Low Right	WF-04202022-003936	12/30/2022	FT-FY23-11182022-003936-A	<1	FT-FY23-11182022-003936-B	<1
WS- 003937	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 146 High Left	WF-09062022-003937	12/30/2022	FT-FY23-11182022-003937-A	<1	FT-FY23-11182022-003937-B	<1
WS- 003938	4/20/2022	4/20/2023	1	Combo Fountain	In classroom 146 Low Right	WF-04202022-003938	12/30/2022	FT-FY23-11182022-003938-A	1.6	FT-FY23-11182022-003938-B	<1
WS- 003939	4/20/2022	4/20/2023	1	Combo Fountain	In classroom 142 Low Right	WF-04202022-003939	12/30/2022	FT-FY23-11182022-003939-A	<1	FT-FY23-11182022-003939-B	<1
WS- 003940	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 142 High Right	WF-09062022-003940	12/30/2022	FT-FY23-11182022-003940-A	<1	FT-FY23-11182022-003940-B	<1
WS- 003941	4/20/2022	4/20/2023	1	Combo Fountain	In classroom 154 Low Right	WF-04202022-003941	12/30/2022	FT-FY23-11182022-003941-A	<1	FT-FY23-11182022-003941-B	<1
WS- 003942	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 154 High Left	WF-09062022-003942	12/30/2022	FT-FY23-11182022-003942-A	<1	FT-FY23-11182022-003942-B	<1
WS- 003943	4/20/2022	4/20/2023	1	Combo Fountain	In classroom 138 Low Right	WF-04202022-003943	12/30/2022	FT-FY23-11182022-003943-A	1.4	FT-FY23-11182022-003943-B	<1
WS- 003944	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 138 High Mid	WF-09062022-003944	12/30/2022	FT-FY23-11182022-003944-A	<1	FT-FY23-11182022-003944-B	<1
WS- 003945	4/20/2022	4/20/2023	1	Cooler	In hallway adjacent to room 156A	WF-04202022-003945	12/30/2022	FT-FY23-11182022-003945-A	<1	FT-FY23-11182022-003945-B	<1
WS- 003946	7/19/2022	7/19/2023	2	Cooler	In hallway adjacent to room 229 Low Left	WF-07192022-003946	12/30/2022	FT-FY23-11182022-003946-A	<1	FT-FY23-11182022-003946-B	<1
WS- 003953	4/20/2022	4/20/2023	1	Cooler	In hallway adjacent to room 134	WF-04202022-003953	12/30/2022	FT-FY23-11182022-003953-A	<1	FT-FY23-11182022-003953-B	<1
WS- 003956	4/20/2022	4/20/2023	1	Break Room	In staff lounge 133 High Left	WF-04202022-003956	12/30/2022	FT-FY23-11182022-003956-A	<1	FT-FY23-11182022-003956-B	<1
WS- 003960	4/20/2022	4/20/2023	3	Cooler	In hallway adjacent to room 317 Low Left	WF-04202022-003960	12/30/2022	FT-FY23-11182022-003960-A	<1	FT-FY23-11182022-003960-B	<1
WS- 003961	4/20/2022	4/20/2023	2	Cooler	In hallway adjacent to staff work room 226	WF-04202022-003961	12/30/2022	FT-FY23-11182022-003961-A	<1	FT-FY23-11182022-003961-B	<1
WS- 003962	4/20/2022	4/20/2023	3	Cooler	In hallway adjacent to room 302 Low Right	WF-04202022-003962	12/30/2022	FT-FY23-11182022-003962-A	1.1	FT-FY23-11182022-003962-B	<1
WS- 003963	4/20/2022	4/20/2023	1	Cooler	In hallway adjacent to room 150	WF-04202022-003963	12/30/2022	FT-FY23-11182022-003963-A	<1	FT-FY23-11182022-003963-B	<1
WS- 003964	9/6/2022	9/6/2023	3	Classroom Faucet	In classroom 302 multipurpose lab High Left	WF-09062022-003964	12/30/2022	FT-FY23-11182022-003964-A	<1	FT-FY23-11182022-003964-B	<1
WS- 003965	9/6/2022	9/6/2023	3	Sprayer	In classroom 302 multipurpose lab (spray nozzle) Low Right	WF-09062022-003965	12/30/2022	FT-FY23-11182022-003965-A	1.6	FT-FY23-11182022-003965-B	<1
WS- 003968	4/20/2022	4/20/2023	2	Cooler	In hallway adjacent to room 216	WF-04202022-003968	12/30/2022	FT-FY23-11182022-003968-A	<1	FT-FY23-11182022-003968-B	4.6
WS- 010545	4/20/2022	4/20/2023	1	Health Suite	In health suite 157B Left	WF-04202022-010545	12/30/2022	FT-FY23-11182022-010545-A	4.8	FT-FY23-11182022-010545-B	<1
WS- 010546	4/20/2022	4/20/2023	1	Combo Fountain	In health suite 157B Right	WF-04202022-010546	12/30/2022	FT-FY23-11182022-010546-A	<1	FT-FY23-11182022-010546-B	<1
WS- 011487	4/20/2022	4/20/2023	1	Bottle Filler	In hallway adjacent to room 156A	WF-04202022-011487	12/30/2022	FT-FY23-11182022-011487-A	<1	FT-FY23-11182022-011487-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003948	1/18/2022	1/18/2023	1	Food Prep Sink	In kitchen third clockwise from entry door Low Right	WF-01182022-003948	12/30/2022	FT-FY23-11182022-003948-A	1.4	FT-FY23-11182022-003948-B	<1
WS- 003949	1/18/2022	1/18/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door Right	WF-01182022-003949	12/30/2022	FT-FY23-11182022-003949-A	<1	FT-FY23-11182022-003949-B	<1