



Mann Elementary School Lead in Water Test Results

FY21 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|------------------|--|------|-------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-003935 | 9/21/2020 | 9/21/2021 | 1 | Combo Faucet | In classroom 150 | High | Left | WF-09212020-003935 | 3/6/2021 | FT-FY21-022021-003935-A | <1 | FT-FY21-022021-003935-B | <1 |
| WS-003936 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In classroom 150 | Low | Right | WF-06102020-003936 | 3/6/2021 | FT-FY21-022021-003936-A | <1 | FT-FY21-022021-003936-B | <1 |
| WS-003937 | 9/21/2020 | 9/21/2021 | 1 | Combo Faucet | In classroom 146 | High | Left | WF-09212020-003937 | 3/6/2021 | FT-FY21-022021-003937-A | <1 | FT-FY21-022021-003937-B | <1 |
| WS-003938 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In classroom 146 | Low | Right | WF-06102020-003938 | 3/6/2021 | FT-FY21-022021-003938-A | <1 | FT-FY21-022021-003938-B | <1 |
| WS-003939 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In classroom 142 | Low | Right | WF-06102020-003939 | 3/6/2021 | FT-FY21-022021-003939-A | <1 | FT-FY21-022021-003939-B | <1 |
| WS-003940 | 9/21/2020 | 9/21/2021 | 1 | Combo Faucet | In classroom 142 | High | Right | WF-09212020-003940 | 3/6/2021 | FT-FY21-022021-003940-A | <1 | FT-FY21-022021-003940-B | <1 |
| WS-003941 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In classroom 154 | Low | Right | WF-06102020-003941 | 3/6/2021 | FT-FY21-022021-003941-A | <1 | FT-FY21-022021-003941-B | <1 |
| WS-003942 | 9/21/2020 | 9/21/2021 | 1 | Combo Faucet | In classroom 154 | High | Left | WF-09212020-003942 | 3/6/2021 | FT-FY21-022021-003942-A | <1 | FT-FY21-022021-003942-B | <1 |
| WS-003943 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In classroom 138 | Low | Right | WF-06102020-003943 | 3/6/2021 | FT-FY21-022021-003943-A | <1 | FT-FY21-022021-003943-B | <1 |
| WS-003944 | 9/21/2020 | 9/21/2021 | 1 | Combo Faucet | In classroom 138 | High | Mid | WF-09212020-003944 | 3/6/2021 | FT-FY21-022021-003944-A | <1 | FT-FY21-022021-003944-B | <1 |
| WS-003945 | 6/10/2020 | 6/10/2021 | 1 | Cooler | In hallway adjacent to room 156A | | | WF-06102020-003945 | 3/6/2021 | FT-FY21-022021-003945-A | <1 | FT-FY21-022021-003945-B | <1 |
| WS-003946 | 6/10/2020 | 6/10/2021 | 2 | Cooler | In hallway adjacent to room 229 | Low | Left | WF-06102020-003946 | 3/6/2021 | FT-FY21-022021-003946-A | <1 | FT-FY21-022021-003946-B | <1 |
| WS-003947 | 6/10/2020 | 6/10/2021 | 2 | Cooler | In hallway adjacent to room 235 | | | WF-06102020-003947 | 3/6/2021 | FT-FY21-022021-003947-A | <1 | FT-FY21-022021-003947-B | <1 |
| WS-003952 | 6/10/2020 | 6/10/2021 | 1 | Cooler | In hallway adjacent to room 110 | | | WF-06102020-003952 | 3/6/2021 | FT-FY21-022021-003952-A | <1 | FT-FY21-022021-003952-B | <1 |
| WS-003953 | 6/10/2020 | 6/10/2021 | 1 | Cooler | In hallway adjacent to room 134 | | | WF-06102020-003953 | 3/6/2021 | FT-FY21-022021-003953-A | <1 | FT-FY21-022021-003953-B | <1 |
| WS-003956 | 6/10/2020 | 6/10/2021 | 1 | Break Room | In staff lounge 133 | High | Left | WF-06102020-003956 | 3/6/2021 | FT-FY21-022021-003956-A | <1 | FT-FY21-022021-003956-B | <1 |
| WS-003960 | 6/10/2020 | 6/10/2021 | 3 | Cooler | In hallway adjacent to room 317 | Low | Left | WF-06102020-003960 | 3/6/2021 | FT-FY21-022021-003960-A | <1 | FT-FY21-022021-003960-B | <1 |
| WS-003961 | 6/10/2020 | 6/10/2021 | 2 | Cooler | In hallway adjacent to staff work room 226 | | | WF-06102020-003961 | 3/6/2021 | FT-FY21-022021-003961-A | <1 | FT-FY21-022021-003961-B | <1 |
| WS-003962 | 6/10/2020 | 6/10/2021 | 3 | Cooler | In hallway adjacent to room 302 | Low | Right | WF-06102020-003962 | 3/6/2021 | FT-FY21-022021-003962-A | <1 | FT-FY21-022021-003962-B | <1 |
| WS-003963 | 6/10/2020 | 6/10/2021 | 1 | Cooler | In hallway adjacent to room 150 | | | WF-06102020-003963 | 3/6/2021 | FT-FY21-022021-003963-A | <1 | FT-FY21-022021-003963-B | <1 |
| WS-003964 | 9/21/2020 | 9/21/2021 | 3 | Classroom Faucet | In classroom 302 multipurpose lab | High | Left | WF-09212020-003964 | 3/6/2021 | FT-FY21-022021-003964-A | <1 | FT-FY21-022021-003964-B | <1 |
| WS-003965 | 9/21/2020 | 9/21/2021 | 3 | Sprayer | In classroom 302 multipurpose lab (spray nozzle) | Low | Right | WF-09212020-003965 | 3/6/2021 | FT-FY21-022021-003965-A | <1 | FT-FY21-022021-003965-B | <1 |
| WS-003968 | 6/10/2020 | 6/10/2021 | 2 | Cooler | In hallway adjacent to room 216 | | | WF-06102020-003968 | 3/6/2021 | FT-FY21-022021-003968-A | <1 | FT-FY21-022021-003968-B | <1 |
| WS-010545 | 6/10/2020 | 6/10/2021 | 1 | Health Suite | In health suite 157B | | Left | WF-06102020-010545 | 3/6/2021 | FT-FY21-022021-010545-A | <1 | FT-FY21-022021-010545-B | <1 |
| WS-010546 | 6/10/2020 | 6/10/2021 | 1 | Combo Fountain | In health suite 157B | | Right | WF-06102020-010546 | 3/6/2021 | FT-FY21-022021-010546-A | <1 | FT-FY21-022021-010546-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|---|-----|-------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-003948 | 1/25/2021 | 1/25/2022 | 1 | Food Prep Sink | In kitchen third clockwise from entry door | Low | Right | WF-01252021-003948 | 3/6/2021 | FT-FY21-022021-003948-A | <1 | FT-FY21-022021-003948-B | <1 |
| WS-003949 | 1/25/2021 | 1/25/2022 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | | Right | WF-01252021-003949 | 3/6/2021 | FT-FY21-022021-003949-A | <1 | FT-FY21-022021-003949-B | <1 |