



Mann Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003935	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 150 High Left	WF-08272024-003935	11/11/2024	FT-FY25-10082024-003935-A	<2	FT-FY25-10082024-003935-B	<2
WS- 003936	4/3/2024	4/3/2025	1	Combo Fountain	In classroom 150 Low Right	WF-04032024-003936	11/11/2024	FT-FY25-10082024-003936-A	<2	FT-FY25-10082024-003936-B	<2
WS- 003937	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 146 High Left	WF-08272024-003937	11/11/2024	FT-FY25-10082024-003937-A	<2	FT-FY25-10082024-003937-B	<2
WS- 003938	4/3/2024	4/3/2025	1	Combo Fountain	In classroom 146 Low Right	WF-04032024-003938	11/11/2024	FT-FY25-10082024-003938-A	<2	FT-FY25-10082024-003938-B	<2
WS- 003939	4/3/2024	4/3/2025	1	Combo Fountain	In classroom 142 Low Right	WF-04032024-003939	11/11/2024	FT-FY25-10082024-003939-A	<2	FT-FY25-10082024-003939-B	<2
WS- 003940	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 142 High Right	WF-08272024-003940	11/11/2024	FT-FY25-10082024-003940-A	<2	FT-FY25-10082024-003940-B	<2
WS- 003941	4/3/2024	4/3/2025	1	Combo Fountain	In classroom 154 Low Right	WF-04032024-003941	11/11/2024	FT-FY25-10082024-003941-A	<2	FT-FY25-10082024-003941-B	<2
WS- 003942	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 154 High Left	WF-08272024-003942	11/11/2024	FT-FY25-10082024-003942-A	<2	FT-FY25-10082024-003942-B	<2
WS- 003943	4/3/2024	4/3/2025	1	Combo Fountain	In classroom 138 Low Right	WF-04032024-003943	11/11/2024	FT-FY25-10082024-003943-A	<2	FT-FY25-10082024-003943-B	<2
WS- 003944	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 138 High Mid	WF-08272024-003944	11/11/2024	FT-FY25-10082024-003944-A	<2	FT-FY25-10082024-003944-B	<2
WS- 003945	4/3/2024	4/3/2025	1	Cooler	In hallway adjacent to room 156A	WF-04032024-003945	11/11/2024	FT-FY25-10082024-003945-A	<2	FT-FY25-10082024-003945-B	<2
WS- 003946	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to room 229 Low Left	WF-04032024-003946	11/11/2024	FT-FY25-10082024-003946-A	<2	FT-FY25-10082024-003946-B	<2
WS- 003947	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to room 235	WF-04032024-003947	11/11/2024	FT-FY25-10082024-003947-A	<2	FT-FY25-10082024-003947-B	<2
WS- 003952	4/3/2024	4/3/2025	1	Cooler	In hallway adjacent to room 110	WF-04032024-003952	11/11/2024	FT-FY25-10082024-003952-A	<2	FT-FY25-10082024-003952-B	<2
WS- 003953	4/3/2024	4/3/2025	1	Cooler	In hallway adjacent to room 134	WF-04032024-003953	11/11/2024	FT-FY25-10082024-003953-A	<2	FT-FY25-10082024-003953-B	<2
WS- 003956	4/3/2024	4/3/2025	1	Break Room	In staff lounge 133 High Left	WF-04032024-003956	11/11/2024	FT-FY25-10082024-003956-A	<2	FT-FY25-10082024-003956-B	<2
WS- 003960	4/3/2024	4/3/2025	3	Cooler	In hallway adjacent to room 317 Low Left	WF-04032024-003960	11/11/2024	FT-FY25-10082024-003960-A	<2	FT-FY25-10082024-003960-B	<2
WS- 003961	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to staff work room 226	WF-04032024-003961	11/11/2024	FT-FY25-10082024-003961-A	<2	FT-FY25-10082024-003961-B	<2
WS- 003962	4/3/2024	4/3/2025	3	Cooler	In hallway adjacent to room 302 Low Right	WF-04032024-003962	11/11/2024	FT-FY25-10082024-003962-A	<2	FT-FY25-10082024-003962-B	<2
WS- 003963	4/3/2024	4/3/2025	1	Cooler	In hallway adjacent to room 150	WF-04032024-003963	11/11/2024	FT-FY25-10082024-003963-A	<2	FT-FY25-10082024-003963-B	<2
WS- 003964	8/27/2024	8/27/2025	3	Classroom Faucet	In classroom 302 multipurpose lab High Left	WF-08272024-003964	11/11/2024	FT-FY25-10082024-003964-A	<2	FT-FY25-10082024-003964-B	<2
WS- 003965	8/27/2024	8/27/2025	3	Sprayer	In classroom 302 multipurpose lab (spray nozzle) Low Right	WF-08272024-003965	11/11/2024	FT-FY25-10082024-003965-A	<2	FT-FY25-10082024-003965-B	<2
WS- 003968	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to room 216	WF-04032024-003968	11/11/2024	FT-FY25-10082024-003968-A	<2	FT-FY25-10082024-003968-B	<2
WS- 010545	4/3/2024	4/3/2025	1	Health Suite	In health suite 157B Left	WF-04032024-010545	11/11/2024	FT-FY25-10082024-010545-A	<2	FT-FY25-10082024-010545-B	<2
WS- 010546	4/3/2024	4/3/2025	1	Combo Fountain	In health suite 157B Right	WF-04032024-010546	11/11/2024	FT-FY25-10082024-010546-A	<2	FT-FY25-10082024-010546-B	<2
WS- 011487	4/3/2024	4/3/2025	1	Bottle Filler	In hallway adjacent to room 156A	WF-04032024-011487	11/11/2024	FT-FY25-10082024-011487-A	<2	FT-FY25-10082024-011487-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003948	11/27/2023	11/27/2024	1	Food Prep Sink	In kitchen third clockwise from entry door Low Right	WF-11272023-003948	11/11/2024	FT-FY25-10082024-003948-A	<2	FT-FY25-10082024-003948-B	<2
WS- 003949	11/27/2023	11/27/2024	1	Food Prep Sink	In kitchen fourth clockwise from entry door Right	WF-11272023-003949	11/11/2024	FT-FY25-10082024-003949-A	<2	FT-FY25-10082024-003949-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.