



Mann ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|-------|------------------|--|------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 003935 | 10/1/2018 | 10/1/2019 | 1 | Combo Faucet | In classroom 150 | High Left | WF-10012018-003935 | 11/27/2018 | FT-FY19-112018-003935-A | <1 | FT-FY19-112018-003935-B | <1 |
| WS- 003936 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In classroom 150 | Low Right | WF-04302018-003936 | 11/27/2018 | FT-FY19-112018-003936-A | <1 | FT-FY19-112018-003936-B | <1 |
| WS- 003937 | 10/1/2018 | 10/1/2019 | 1 | Combo Faucet | In classroom 146 | High Left | WF-10012018-003937 | 11/27/2018 | FT-FY19-112018-003937-A | <1 | FT-FY19-112018-003937-B | <1 |
| WS- 003938 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In classroom 146 | Low Right | WF-04302018-003938 | 11/27/2018 | FT-FY19-112018-003938-A | <1 | FT-FY19-112018-003938-B | <1 |
| WS- 003939 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In classroom 142 | Low Right | WF-04302018-003939 | 11/27/2018 | FT-FY19-112018-003939-A | <1 | FT-FY19-112018-003939-B | <1 |
| WS- 003940 | 10/1/2018 | 10/1/2019 | 1 | Combo Faucet | In classroom 142 | High Right | WF-10012018-003940 | 11/27/2018 | FT-FY19-112018-003940-A | <1 | FT-FY19-112018-003940-B | <1 |
| WS- 003941 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In classroom 154 | Low Right | WF-04302018-003941 | 11/27/2018 | FT-FY19-112018-003941-A | <1 | FT-FY19-112018-003941-B | <1 |
| WS- 003942 | 10/1/2018 | 10/1/2019 | 1 | Combo Faucet | In classroom 154 | High Left | WF-10012018-003942 | 11/27/2018 | FT-FY19-112018-003942-A | <1 | FT-FY19-112018-003942-B | <1 |
| WS- 003943 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In classroom 138 | Low Right | WF-04302018-003943 | 11/27/2018 | FT-FY19-112018-003943-A | <1 | FT-FY19-112018-003943-B | <1 |
| WS- 003944 | 10/1/2018 | 10/1/2019 | 1 | Combo Faucet | In classroom 138 | High Mid | WF-10012018-003944 | 11/27/2018 | FT-FY19-112018-003944-A | <1 | FT-FY19-112018-003944-B | <1 |
| WS- 003945 | 4/30/2018 | 4/30/2019 | 1 | Cooler | In hallway adjacent to room 156A | | WF-04302018-003945 | 11/27/2018 | FT-FY19-112018-003945-A | <1 | FT-FY19-112018-003945-B | <1 |
| WS- 003946 | 4/30/2018 | 4/30/2019 | 2 | Cooler | In hallway adjacent to room 229 | Low Left | WF-04302018-003946 | 11/27/2018 | FT-FY19-112018-003946-A | <1 | FT-FY19-112018-003946-B | <1 |
| WS- 003947 | 4/30/2018 | 4/30/2019 | 2 | Cooler | In hallway adjacent to room 235 | | WF-04302018-003947 | 11/27/2018 | FT-FY19-112018-003947-A | <1 | FT-FY19-112018-003947-B | <1 |
| WS- 003952 | 4/30/2018 | 4/30/2019 | 1 | Cooler | In hallway adjacent to room 110 | | WF-04302018-003952 | 11/27/2018 | FT-FY19-112018-003952-A | <1 | FT-FY19-112018-003952-B | <1 |
| WS- 003953 | 4/30/2018 | 4/30/2019 | 1 | Cooler | In hallway adjacent to room 134 | | WF-04302018-003953 | 11/27/2018 | FT-FY19-112018-003953-A | <1 | FT-FY19-112018-003953-B | <1 |
| WS- 003956 | 4/30/2018 | 4/30/2019 | 1 | Break Room | In staff lounge 133 | High Left | WF-04302018-003956 | 11/27/2018 | FT-FY19-112018-003956-A | <1 | FT-FY19-112018-003956-B | <1 |
| WS- 003960 | 4/30/2018 | 4/30/2019 | 3 | Cooler | In hallway adjacent to room 317 | Low Left | WF-04302018-003960 | 11/27/2018 | FT-FY19-112018-003960-A | <1 | FT-FY19-112018-003960-B | <1 |
| WS- 003961 | 4/30/2018 | 4/30/2019 | 2 | Cooler | In hallway adjacent to staff work room 226 | | WF-04302018-003961 | 11/27/2018 | FT-FY19-112018-003961-A | <1 | FT-FY19-112018-003961-B | <1 |
| WS- 003962 | 4/30/2018 | 4/30/2019 | 3 | Cooler | In hallway adjacent to room 302 | Low Right | WF-04302018-003962 | 11/27/2018 | FT-FY19-112018-003962-A | <1 | FT-FY19-112018-003962-B | <1 |
| WS- 003963 | 4/30/2018 | 4/30/2019 | 1 | Cooler | In hallway adjacent to room 150 | | WF-04302018-003963 | 11/27/2018 | FT-FY19-112018-003963-A | <1 | FT-FY19-112018-003963-B | <1 |
| WS- 003964 | 12/11/2018 | 12/11/2019 | 3 | Classroom Faucet | In classroom 302 multipurpose lab | High Left | WF-12112018-003964 | 12/19/2018 | FT-FY19-122018-003964-A | <1 | FT-FY19-122018-003964-B | <1 |
| WS- 003965 | 12/11/2018 | 12/11/2019 | 3 | Sprayer | In classroom 302 multipurpose lab (spray nozzle) | Low Right | WF-12112018-003965 | 12/19/2018 | FT-FY19-122018-003965-A | <1 | FT-FY19-122018-003965-B | <1 |
| WS- 003968 | 4/30/2018 | 4/30/2019 | 2 | Cooler | In hallway adjacent to room 216 | | WF-04302018-003968 | 11/27/2018 | FT-FY19-112018-003968-A | <1 | FT-FY19-112018-003968-B | <1 |
| WS- 010545 | 4/30/2018 | 4/30/2019 | 1 | Health Suite | In health suite 157B | Left | WF-04302018-010545 | 11/27/2018 | FT-FY19-112018-010545-A | <1 | FT-FY19-112018-010545-B | <1 |
| WS- 010546 | 4/30/2018 | 4/30/2019 | 1 | Combo Fountain | In health suite 157B | Right | WF-04302018-010546 | 11/27/2018 | FT-FY19-112018-010546-A | <1 | FT-FY19-112018-010546-B | <1 |

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

| Record ID | Floor | Device Type | Device Location | | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|------------|-------|----------------|---|-----------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 003948 | 1 | Food Prep Sink | In kitchen third clockwise from entry door | Low Right | 11/27/2018 | FT-FY19-112018-003948-A | <1 | FT-FY19-112018-003948-B | <1 |
| WS- 003949 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | Right | 11/27/2018 | FT-FY19-112018-003949-A | <1 | FT-FY19-112018-003949-B | <1 |