



Mann ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003938	6/5/2017	6/5/2018	1	Combo Fountain	In classroom 146 Right Low	WF-62017-003938	11/6/2017	FT-FY18-62017-003938-A	<1	FT-FY18-62017-003938-B	<1	
WS- 003939	6/5/2017	6/5/2018	1	Combo Fountain	In classroom 142 Right Low	WF-62017-003939	11/6/2017	FT-FY18-62017-003939-A	<1	FT-FY18-62017-003939-B	<1	
WS- 003941	6/5/2017	6/5/2018	1	Combo Fountain	In classroom 154 Right Low	WF-62017-003941	11/6/2017	FT-FY18-62017-003941-A	<1	FT-FY18-62017-003941-B	<1	
WS- 003945	6/5/2017	6/5/2018	1	Cooler	In hallway adjacent to room 156A Mid Low	WF-62017-003945	11/6/2017	FT-FY18-62017-003945-A	<1	FT-FY18-62017-003945-B	<1	
WS- 003947	6/5/2017	6/5/2018	2	Fountain	In hallway adjacent to room 235 Mid Low	WF-62017-003947	11/6/2017	FT-FY18-62017-003947-A	<1	FT-FY18-62017-003947-B	<1	
WS- 003960	6/5/2017	6/5/2018	3	Cooler	In hallway adjacent to room 317 Left Low	WF-62017-003960	11/6/2017	FT-FY18-62017-003960-A	<1	FT-FY18-62017-003960-B	<1	
WS- 003963	6/5/2017	6/5/2018	1	Cooler	In hallway adjacent to room 150	WF-62017-003963	11/6/2017	FT-FY18-62017-003963-A	<1	FT-FY18-62017-003963-B	<1	
WS- 010545	6/5/2017	6/5/2018	1	Health Suite	In health suite 157B Left	WF-62017-010545	11/6/2017	FT-FY18-62017-010545-A	<1	FT-FY18-62017-010545-B	<1	

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 003948	1	Food Prep Sink	In kitchen third clockwise from entry door Right Low	11/6/2017	FT-FY18-102017-003948-A	<1	FT-FY18-102017-003948-B	<1		
WS- 003949	1	Food Prep Sink	In kitchen fourth clockwise from entry door Right	11/6/2017	FT-FY18-102017-003949-A	<1	FT-FY18-102017-003949-B	<1		