



Marie Reed ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000897	6/11/2019	6/11/2020	4	Cooler	In hallway adjacent to room 439	WF-06112019-000897	12/11/2019	FT-FY20-112019-000897-A	<1	FT-FY20-112019-000897-B	<1
WS- 000899	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 467	WF-06112019-000899	12/11/2019	FT-FY20-112019-000899-A	<1	FT-FY20-112019-000899-B	<1
WS- 000900	6/11/2019	6/11/2020	4	Cooler	In hallway adjacent to girls restroom	WF-06112019-000900	12/11/2019	FT-FY20-112019-000900-A	<1	FT-FY20-112019-000900-B	<1
WS- 000901	6/11/2019	6/11/2020	4	Break Room	In staff lounge 472	WF-06112019-000901	12/11/2019	FT-FY20-112019-000901-A	<1	FT-FY20-112019-000901-B	<1
WS- 000902	6/11/2019	6/11/2020	4	Cooler	In hallway adjacent to boys restroom	WF-06112019-000902	12/11/2019	FT-FY20-112019-000902-A	<1	FT-FY20-112019-000902-B	<1
WS- 000903	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 401	WF-06112019-000903	12/11/2019	FT-FY20-112019-000903-A	<1	FT-FY20-112019-000903-B	<1
WS- 000906	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 403	WF-06112019-000906	12/11/2019	FT-FY20-112019-000906-A	<1	FT-FY20-112019-000906-B	<1
WS- 000910	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 409	WF-06112019-000910	12/11/2019	FT-FY20-112019-000910-A	<1	FT-FY20-112019-000910-B	<1
WS- 000911	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 411	WF-06112019-000911	12/11/2019	FT-FY20-112019-000911-A	<1	FT-FY20-112019-000911-B	<1
WS- 000913	6/11/2019	6/11/2020	4	Cooler	In hallway adjacent to girls restroom	WF-06112019-000913	12/11/2019	FT-FY20-112019-000913-A	<1	FT-FY20-112019-000913-B	<1
WS- 000915	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 415	WF-06112019-000915	12/11/2019	FT-FY20-112019-000915-A	<1	FT-FY20-112019-000915-B	<1
WS- 000916	6/11/2019	6/11/2020	4	Combo Fountain	In library room 400	WF-06112019-000916	12/11/2019	FT-FY20-112019-000916-A	<1	FT-FY20-112019-000916-B	<1
WS- 000918	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 417	WF-06112019-000918	12/11/2019	FT-FY20-112019-000918-A	<1	FT-FY20-112019-000918-B	<1
WS- 000920	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 419	WF-06112019-000920	12/11/2019	FT-FY20-112019-000920-A	<1	FT-FY20-112019-000920-B	<1
WS- 000922	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 306	WF-10012019-000922	12/11/2019	FT-FY20-112019-000922-A	<1	FT-FY20-112019-000922-B	<1
WS- 000923	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 306	WF-06112019-000923	12/11/2019	FT-FY20-112019-000923-A	<1	FT-FY20-112019-000923-B	<1
WS- 000924	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 301	WF-10012019-000924	12/11/2019	FT-FY20-112019-000924-A	<1	FT-FY20-112019-000924-B	<1
WS- 000925	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 301	WF-06112019-000925	12/11/2019	FT-FY20-112019-000925-A	<1	FT-FY20-112019-000925-B	<1
WS- 000926	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 308	WF-10012019-000926	12/11/2019	FT-FY20-112019-000926-A	<1	FT-FY20-112019-000926-B	<1
WS- 000927	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 308	WF-06112019-000927	12/11/2019	FT-FY20-112019-000927-A	<1	FT-FY20-112019-000927-B	<1
WS- 000928	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 310	WF-10012019-000928	12/11/2019	FT-FY20-112019-000928-A	<1	FT-FY20-112019-000928-B	<1
WS- 000929	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 310	WF-06112019-000929	12/11/2019	FT-FY20-112019-000929-A	<1	FT-FY20-112019-000929-B	<1
WS- 000930	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 305	WF-10012019-000930	12/11/2019	FT-FY20-112019-000930-A	<1	FT-FY20-112019-000930-B	<1
WS- 000931	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 305	WF-06112019-000931	12/11/2019	FT-FY20-112019-000931-A	<1	FT-FY20-112019-000931-B	<1
WS- 000932	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 311	WF-10012019-000932	12/11/2019	FT-FY20-112019-000932-A	<1	FT-FY20-112019-000932-B	<1
WS- 000933	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 311	WF-06112019-000933	12/11/2019	FT-FY20-112019-000933-A	<1	FT-FY20-112019-000933-B	<1
WS- 000934	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 302	WF-10012019-000934	12/11/2019	FT-FY20-112019-000934-A	<1	FT-FY20-112019-000934-B	<1
WS- 000935	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 302	WF-06112019-000935	12/11/2019	FT-FY20-112019-000935-A	<1	FT-FY20-112019-000935-B	<1
WS- 000936	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 319	WF-10012019-000936	12/11/2019	FT-FY20-112019-000936-A	<1	FT-FY20-112019-000936-B	<1
WS- 000937	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 319	WF-06112019-000937	12/11/2019	FT-FY20-112019-000937-A	<1	FT-FY20-112019-000937-B	<1
WS- 000938	10/1/2019	10/1/2020	3	Combo Faucet	In classroom 321	WF-10012019-000938	12/11/2019	FT-FY20-112019-000938-A	<1	FT-FY20-112019-000938-B	<1

WS- 000939	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 321	WF-06112019-000939	12/11/2019	FT-FY20-112019-000939-A	<1	FT-FY20-112019-000939-B	<1
WS- 000940	6/11/2019	6/11/2020	3	Health Suite	In health suite 368D	WF-06112019-000940	12/11/2019	FT-FY20-112019-000940-A	<1	FT-FY20-112019-000940-B	<1
WS- 000941	6/11/2019	6/11/2020	3	Break Room	In break room 372	WF-06112019-000941	12/11/2019	FT-FY20-112019-000941-A	<1	FT-FY20-112019-000941-B	<1
WS- 000942	6/11/2019	6/11/2020	3	Bottle Filler	In cafeteria (bottle filler)	WF-06112019-000942	12/11/2019	FT-FY20-112019-000942-A	<1	FT-FY20-112019-000942-B	<1
WS- 000943	6/11/2019	6/11/2020	3	Cooler	In cafeteria Low Right	WF-06112019-000943	12/11/2019	FT-FY20-112019-000943-A	<1	FT-FY20-112019-000943-B	<1
WS- 000944	6/11/2019	6/11/2020	3	Cooler	In cafeteria High Left	WF-06112019-000944	12/11/2019	FT-FY20-112019-000944-A	<1	FT-FY20-112019-000944-B	<1
WS- 000948	6/11/2019	6/11/2020	4	Break Room	In staff lounge room 430	WF-06112019-000948	12/11/2019	FT-FY20-112019-000948-A	<1	FT-FY20-112019-000948-B	<1
WS- 000959	6/11/2019	6/11/2020	3	Break Room	In workroom 317	WF-06112019-000959	12/11/2019	FT-FY20-112019-000959-A	<1	FT-FY20-112019-000959-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000967	7/24/2019	7/24/2020	3	Food Prep Sink	In kitchen first clockwise from entry	WF-07242019-000967	12/11/2019	FT-FY20-112019-000967-A	<1	FT-FY20-112019-000967-B	<1