



Marie Reed Recreation Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000897	4/25/2022	4/25/2023	4	Cooler	In hallway adjacent to room 439	WF-04252022-000897	1/19/2023	FT-FY23-12292022-000897-A	<1	FT-FY23-12292022-000897-B	<1
WS- 000900	4/25/2022	4/25/2023	4	Cooler	In hallway adjacent to girls restroom	WF-04252022-000900	1/19/2023	FT-FY23-12292022-000900-A	<1	FT-FY23-12292022-000900-B	<1
WS- 000901	4/25/2022	4/25/2023	4	Break Room	In staff lounge 472	WF-04252022-000901	1/19/2023	FT-FY23-12292022-000901-A	<1	FT-FY23-12292022-000901-B	<1
WS- 000902	4/25/2022	4/25/2023	4	Cooler	In hallway adjacent to boys restroom	WF-04252022-000902	1/19/2023	FT-FY23-12292022-000902-A	<1	FT-FY23-12292022-000902-B	<1
WS- 000903	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 401	WF-04252022-000903	1/19/2023	FT-FY23-12292022-000903-A	<1	FT-FY23-12292022-000903-B	<1
WS- 000906	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 403	WF-04252022-000906	1/19/2023	FT-FY23-12292022-000906-A	<1	FT-FY23-12292022-000906-B	<1
WS- 000908	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 406	WF-04252022-000908	1/19/2023	FT-FY23-12292022-000908-A	<1	FT-FY23-12292022-000908-B	<1
WS- 000910	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 409	WF-04252022-000910	1/19/2023	FT-FY23-12292022-000910-A	<1	FT-FY23-12292022-000910-B	<1
WS- 000911	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 411	WF-04252022-000911	1/19/2023	FT-FY23-12292022-000911-A	<1	FT-FY23-12292022-000911-B	<1
WS- 000913	4/25/2022	4/25/2023	4	Cooler	In hallway adjacent to girls restroom	WF-04252022-000913	1/19/2023	FT-FY23-12292022-000913-A	<1	FT-FY23-12292022-000913-B	<1
WS- 000915	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 415	WF-04252022-000915	1/19/2023	FT-FY23-12292022-000915-A	<1	FT-FY23-12292022-000915-B	<1
WS- 000916	4/25/2022	4/25/2023	4	Combo Fountain	In library room 400	WF-04252022-000916	1/19/2023	FT-FY23-12292022-000916-A	<1	FT-FY23-12292022-000916-B	<1
WS- 000918	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 417	WF-04252022-000918	1/19/2023	FT-FY23-12292022-000918-A	<1	FT-FY23-12292022-000918-B	<1
WS- 000920	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 419	WF-04252022-000920	1/19/2023	FT-FY23-12292022-000920-A	<1	FT-FY23-12292022-000920-B	<1
WS- 000922	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 306	WF-09062022-000922	1/19/2023	FT-FY23-12292022-000922-A	<1	FT-FY23-12292022-000922-B	<1
WS- 000923	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 306	WF-04252022-000923	1/19/2023	FT-FY23-12292022-000923-A	<1	FT-FY23-12292022-000923-B	<1
WS- 000924	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 301	WF-09062022-000924	1/19/2023	FT-FY23-12292022-000924-A	<1	FT-FY23-12292022-000924-B	<1
WS- 000925	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 301	WF-04252022-000925	1/19/2023	FT-FY23-12292022-000925-A	<1	FT-FY23-12292022-000925-B	<1
WS- 000928	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 310	WF-09062022-000928	1/19/2023	FT-FY23-12292022-000928-A	<1	FT-FY23-12292022-000928-B	<1
WS- 000929	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 310	WF-04252022-000929	1/19/2023	FT-FY23-12292022-000929-A	<1	FT-FY23-12292022-000929-B	<1
WS- 000930	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 305	WF-09062022-000930	1/19/2023	FT-FY23-12292022-000930-A	<1	FT-FY23-12292022-000930-B	<1
WS- 000931	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 305	WF-04252022-000931	1/19/2023	FT-FY23-12292022-000931-A	<1	FT-FY23-12292022-000931-B	<1
WS- 000932	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 311	WF-09062022-000932	1/19/2023	FT-FY23-12292022-000932-A	<1	FT-FY23-12292022-000932-B	<1
WS- 000933	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 311	WF-04252022-000933	1/19/2023	FT-FY23-12292022-000933-A	<1	FT-FY23-12292022-000933-B	<1
WS- 000934	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 302	WF-09062022-000934	1/19/2023	FT-FY23-12292022-000934-A	<1	FT-FY23-12292022-000934-B	<1
WS- 000935	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 302	WF-04252022-000935	1/19/2023	FT-FY23-12292022-000935-A	<1	FT-FY23-12292022-000935-B	<1
WS- 000936	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 319	WF-09062022-000936	1/19/2023	FT-FY23-12292022-000936-A	<1	FT-FY23-12292022-000936-B	<1
WS- 000937	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 319	WF-04252022-000937	1/19/2023	FT-FY23-12292022-000937-A	<1	FT-FY23-12292022-000937-B	<1
WS- 000938	9/6/2022	9/6/2023	3	Combo Faucet	In classroom 321	WF-09062022-000938	1/19/2023	FT-FY23-12292022-000938-A	<1	FT-FY23-12292022-000938-B	<1
WS- 000939	4/25/2022	4/25/2023	3	Combo Fountain	In classroom 321	WF-04252022-000939	1/19/2023	FT-FY23-12292022-000939-A	<1	FT-FY23-12292022-000939-B	<1
WS- 000940	4/25/2022	4/25/2023	3	Health Suite	In health suite 368D	WF-04252022-000940	1/19/2023	FT-FY23-12292022-000940-A	<1	FT-FY23-12292022-000940-B	<1
WS- 000941	4/25/2022	4/25/2023	3	Break Room	In break room 372	WF-04252022-000941	1/19/2023	FT-FY23-12292022-000941-A	<1	FT-FY23-12292022-000941-B	<1
WS- 000942	4/25/2022	4/25/2023	3	Bottle Filler	In cafeteria (bottle filler)	WF-04252022-000942	1/19/2023	FT-FY23-12292022-000942-A	<1	FT-FY23-12292022-000942-B	<1
WS- 000943	4/25/2022	4/25/2023	3	Cooler	In cafeteria	WF-04252022-000943	1/19/2023	FT-FY23-12292022-000943-A	<1	FT-FY23-12292022-000943-B	<1

WS- 000944	4/25/2022	4/25/2023	3	Cooler	In cafeteria	High Left	WF-04252022-000944	1/19/2023	FT-FY23-12292022-000944-A	<1	FT-FY23-12292022-000944-B	<1
WS- 000948	4/25/2022	4/25/2023	4	Break Room	In staff lounge room 430		WF-04252022-000948	1/19/2023	FT-FY23-12292022-000948-A	<1	FT-FY23-12292022-000948-B	<1
WS- 000959	4/25/2022	4/25/2023	3	Break Room	In workroom 317		WF-04252022-000959	1/19/2023	FT-FY23-12292022-000959-A	<1	FT-FY23-12292022-000959-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000967	12/20/2022	12/20/2023	3	Food Prep Sink	In kitchen first clockwise from entry	WF-12202022-000967	1/19/2023	FT-FY23-12292022-000967-A	<1	FT-FY23-12292022-000967-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000899	4/25/2022	4/25/2023	4	Combo Fountain	In classroom 467	WF-04252022-000899	1/19/2023	FT-FY23-12292022-000899-A	5.1	FT-FY23-12292022-000899-B	1.1