



Marie Reed Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000897	5/3/2021	5/3/2022	4	Cooler	In hallway adjacent to room 439	WF-05032021-000897	11/29/2021	FT-FY22-11122021-000897-A	<1	FT-FY22-11122021-000897-B	<1
WS- 000899	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 467	WF-05032021-000899	11/29/2021	FT-FY22-11122021-000899-A	<1	FT-FY22-11122021-000899-B	<1
WS- 000900	5/3/2021	5/3/2022	4	Cooler	In hallway adjacent to girls restroom	WF-05032021-000900	11/29/2021	FT-FY22-11122021-000900-A	<1	FT-FY22-11122021-000900-B	<1
WS- 000901	5/3/2021	5/3/2022	4	Break Room	In staff lounge 472	WF-05032021-000901	11/29/2021	FT-FY22-11122021-000901-A	<1	FT-FY22-11122021-000901-B	<1
WS- 000902	5/3/2021	5/3/2022	4	Cooler	In hallway adjacent to boys restroom	WF-05032021-000902	11/29/2021	FT-FY22-11122021-000902-A	<1	FT-FY22-11122021-000902-B	<1
WS- 000903	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 401	WF-05032021-000903	11/29/2021	FT-FY22-11122021-000903-A	<1	FT-FY22-11122021-000903-B	<1
WS- 000906	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 403	WF-05032021-000906	11/29/2021	FT-FY22-11122021-000906-A	<1	FT-FY22-11122021-000906-B	<1
WS- 000908	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 406	WF-05032021-000908	11/29/2021	FT-FY22-11122021-000908-A	1.2	FT-FY22-11122021-000908-B	<1
WS- 000910	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 409	WF-05032021-000910	11/29/2021	FT-FY22-11122021-000910-A	<1	FT-FY22-11122021-000910-B	<1
WS- 000911	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 411	WF-05032021-000911	11/29/2021	FT-FY22-11122021-000911-A	<1	FT-FY22-11122021-000911-B	<1
WS- 000913	5/3/2021	5/3/2022	4	Cooler	In hallway adjacent to girls restroom	WF-05032021-000913	11/29/2021	FT-FY22-11122021-000913-A	<1	FT-FY22-11122021-000913-B	<1
WS- 000915	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 415	WF-05032021-000915	11/29/2021	FT-FY22-11122021-000915-A	1.3	FT-FY22-11122021-000915-B	<1
WS- 000916	5/3/2021	5/3/2022	4	Combo Fountain	In library room 400	WF-05032021-000916	11/29/2021	FT-FY22-11122021-000916-A	<1	FT-FY22-11122021-000916-B	<1
WS- 000918	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 417	WF-05032021-000918	11/29/2021	FT-FY22-11122021-000918-A	<1	FT-FY22-11122021-000918-B	<1
WS- 000920	5/3/2021	5/3/2022	4	Combo Fountain	In classroom 419	WF-05032021-000920	11/29/2021	FT-FY22-11122021-000920-A	<1	FT-FY22-11122021-000920-B	<1
WS- 000922	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 306	WF-09132021-000922	11/29/2021	FT-FY22-11122021-000922-A	<1	FT-FY22-11122021-000922-B	<1
WS- 000923	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 306	WF-05032021-000923	11/29/2021	FT-FY22-11122021-000923-A	<1	FT-FY22-11122021-000923-B	<1
WS- 000924	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 301	WF-09132021-000924	11/29/2021	FT-FY22-11122021-000924-A	<1	FT-FY22-11122021-000924-B	<1
WS- 000925	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 301	WF-05032021-000925	11/29/2021	FT-FY22-11122021-000925-A	<1	FT-FY22-11122021-000925-B	<1
WS- 000926	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 308	WF-09132021-000926	11/29/2021	FT-FY22-11122021-000926-A	<1	FT-FY22-11122021-000926-B	<1
WS- 000927	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 308	WF-05032021-000927	11/29/2021	FT-FY22-11122021-000927-A	<1	FT-FY22-11122021-000927-B	<1
WS- 000928	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 310	WF-09132021-000928	11/29/2021	FT-FY22-11122021-000928-A	<1	FT-FY22-11122021-000928-B	<1
WS- 000929	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 310	WF-05032021-000929	11/29/2021	FT-FY22-11122021-000929-A	<1	FT-FY22-11122021-000929-B	<1
WS- 000930	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 305	WF-09132021-000930	11/29/2021	FT-FY22-11122021-000930-A	<1	FT-FY22-11122021-000930-B	<1
WS- 000931	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 305	WF-05032021-000931	11/29/2021	FT-FY22-11122021-000931-A	<1	FT-FY22-11122021-000931-B	<1
WS- 000934	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 302	WF-09132021-000934	11/29/2021	FT-FY22-11122021-000934-A	<1	FT-FY22-11122021-000934-B	<1
WS- 000935	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 302	WF-05032021-000935	11/29/2021	FT-FY22-11122021-000935-A	<1	FT-FY22-11122021-000935-B	<1
WS- 000936	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 319	WF-09132021-000936	11/29/2021	FT-FY22-11122021-000936-A	<1	FT-FY22-11122021-000936-B	<1
WS- 000937	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 319	WF-05032021-000937	11/29/2021	FT-FY22-11122021-000937-A	<1	FT-FY22-11122021-000937-B	<1
WS- 000938	9/13/2021	9/13/2022	3	Combo Faucet	In classroom 321	WF-09132021-000938	11/29/2021	FT-FY22-11122021-000938-A	<1	FT-FY22-11122021-000938-B	<1
WS- 000939	5/3/2021	5/3/2022	3	Combo Fountain	In classroom 321	WF-05032021-000939	11/29/2021	FT-FY22-11122021-000939-A	<1	FT-FY22-11122021-000939-B	<1
WS- 000940	5/3/2021	5/3/2022	3	Health Suite	In health suite 368D	WF-05032021-000940	11/29/2021	FT-FY22-11122021-000940-A	<1	FT-FY22-11122021-000940-B	<1
WS- 000941	5/3/2021	5/3/2022	3	Break Room	In break room 372	WF-05032021-000941	11/29/2021	FT-FY22-11122021-000941-A	<1	FT-FY22-11122021-000941-B	<1
WS- 000942	5/3/2021	5/3/2022	3	Bottle Filler	In cafeteria (bottle filler)	WF-05032021-000942	11/29/2021	FT-FY22-11122021-000942-A	<1	FT-FY22-11122021-000942-B	<1
WS- 000948	5/3/2021	5/3/2022	4	Break Room	In staff lounge room 430	WF-05032021-000948	11/29/2021	FT-FY22-11122021-000948-A	<1	FT-FY22-11122021-000948-B	<1

WS- 000959	5/3/2021	5/3/2022	3	Break Room	In workroom 317	WF-05032021-000959	11/29/2021	FT-FY22-11122021-000959-A	<1	FT-FY22-11122021-000959-B	<1
------------	----------	----------	---	------------	-----------------	--------------------	------------	---------------------------	----	---------------------------	----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000967	1/4/2021	1/4/2022	3	Food Prep Sink	In kitchen first clockwise from entry	WF-01042021-000967	11/29/2021	FT-FY22-11122021-000967-A	<1	FT-FY22-11122021-000967-B	<1