



Marie Reed Recreation Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000897	4/17/2024	4/17/2025	4	Cooler	In hallway adjacent to room 439	WF-04172024-000897	10/15/2024	FT-FY25-10032024-000897-A	<2	FT-FY25-10032024-000897-B	<2
WS- 000899	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 467	WF-04172024-000899	10/15/2024	FT-FY25-10032024-000899-A	<2	FT-FY25-10032024-000899-B	<2
WS- 000900	4/17/2024	4/17/2025	4	Cooler	In hallway adjacent to girls restroom	WF-04172024-000900	10/15/2024	FT-FY25-10032024-000900-A	<2	FT-FY25-10032024-000900-B	<2
WS- 000901	4/17/2024	4/17/2025	4	Break Room	In staff lounge 472	WF-04172024-000901	10/15/2024	FT-FY25-10032024-000901-A	<2	FT-FY25-10032024-000901-B	<2
WS- 000902	4/17/2024	4/17/2025	4	Cooler	In hallway adjacent to boys restroom	WF-04172024-000902	10/15/2024	FT-FY25-10032024-000902-A	<2	FT-FY25-10032024-000902-B	<2
WS- 000903	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 401	WF-04172024-000903	10/15/2024	FT-FY25-10032024-000903-A	<2	FT-FY25-10032024-000903-B	<2
WS- 000906	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 403	WF-04172024-000906	10/15/2024	FT-FY25-10032024-000906-A	<2	FT-FY25-10032024-000906-B	<2
WS- 000908	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 406	WF-04172024-000908	10/15/2024	FT-FY25-10032024-000908-A	<2	FT-FY25-10032024-000908-B	<2
WS- 000910	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 409	WF-04172024-000910	10/15/2024	FT-FY25-10032024-000910-A	<2	FT-FY25-10032024-000910-B	<2
WS- 000913	4/17/2024	4/17/2025	4	Cooler	In hallway adjacent to girls restroom	WF-04172024-000913	10/15/2024	FT-FY25-10032024-000913-A	<2	FT-FY25-10032024-000913-B	<2
WS- 000915	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 415	WF-04172024-000915	10/15/2024	FT-FY25-10032024-000915-A	<2	FT-FY25-10032024-000915-B	<2
WS- 000916	4/17/2024	4/17/2025	4	Combo Fountain	In library room 400	WF-04172024-000916	10/15/2024	FT-FY25-10032024-000916-A	<2	FT-FY25-10032024-000916-B	<2
WS- 000920	4/17/2024	4/17/2025	4	Combo Fountain	In classroom 419	WF-04172024-000920	10/15/2024	FT-FY25-10032024-000920-A	<2	FT-FY25-10032024-000920-B	<2
WS- 000922	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 306	WF-08262024-000922	10/15/2024	FT-FY25-10032024-000922-A	<2	FT-FY25-10032024-000922-B	<2
WS- 000923	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 306	WF-04172024-000923	10/15/2024	FT-FY25-10032024-000923-A	<2	FT-FY25-10032024-000923-B	<2
WS- 000924	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 301	WF-08262024-000924	10/15/2024	FT-FY25-10032024-000924-A	<2	FT-FY25-10032024-000924-B	<2
WS- 000925	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 301	WF-04172024-000925	10/15/2024	FT-FY25-10032024-000925-A	<2	FT-FY25-10032024-000925-B	<2
WS- 000926	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 308	WF-08262024-000926	10/15/2024	FT-FY25-10032024-000926-A	<2	FT-FY25-10032024-000926-B	<2
WS- 000927	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 308	WF-04172024-000927	10/15/2024	FT-FY25-10032024-000927-A	<2	FT-FY25-10032024-000927-B	<2
WS- 000928	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 310	WF-08262024-000928	10/15/2024	FT-FY25-10032024-000928-A	<2	FT-FY25-10032024-000928-B	<2
WS- 000929	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 310	WF-04172024-000929	10/15/2024	FT-FY25-10032024-000929-A	<2	FT-FY25-10032024-000929-B	<2
WS- 000930	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 305	WF-08262024-000930	10/15/2024	FT-FY25-10032024-000930-A	<2	FT-FY25-10032024-000930-B	<2
WS- 000931	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 305	WF-04172024-000931	10/15/2024	FT-FY25-10032024-000931-A	<2	FT-FY25-10032024-000931-B	<2
WS- 000932	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 311	WF-08262024-000932	10/15/2024	FT-FY25-10032024-000932-A	<2	FT-FY25-10032024-000932-B	<2
WS- 000933	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 311	WF-04172024-000933	10/15/2024	FT-FY25-10032024-000933-A	<2	FT-FY25-10032024-000933-B	<2
WS- 000934	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 302	WF-08262024-000934	10/15/2024	FT-FY25-10032024-000934-A	<2	FT-FY25-10032024-000934-B	<2
WS- 000935	4/17/2024	4/17/2025	3	Combo Fountain	In classroom 302	WF-04172024-000935	10/15/2024	FT-FY25-10032024-000935-A	<2	FT-FY25-10032024-000935-B	<2
WS- 000936	8/26/2024	8/26/2025	3	Combo Faucet	In classroom 319	WF-08262024-000936	10/15/2024	FT-FY25-10032024-000936-A	<2	FT-FY25-10032024-000936-B	<2
WS- 000937	8/21/2024	8/21/2025	3	Combo Fountain	In classroom 319	WF-08212024-000937	10/15/2024	FT-FY25-10032024-000937-A	<2	FT-FY25-10032024-000937-B	<2
WS- 000940	4/17/2024	4/17/2025	3	Health Suite	In health suite 368D	WF-04172024-000940	10/15/2024	FT-FY25-10032024-000940-A	<2	FT-FY25-10032024-000940-B	<2
WS- 000941	4/17/2024	4/17/2025	3	Break Room	In break room 372	WF-04172024-000941	10/15/2024	FT-FY25-10032024-000941-A	<2	FT-FY25-10032024-000941-B	<2
WS- 000942	9/11/2024	9/11/2025	3	Bottle Filler	In cafeteria (bottle filler)	WF-09112024-000942	10/15/2024	FT-FY25-10032024-000942-A	<2	FT-FY25-10032024-000942-B	<2
WS- 000943	9/11/2024	9/11/2025	3	Cooler	In cafeteria Low Right	WF-09112024-000943	10/15/2024	FT-FY25-10032024-000943-A	<2	FT-FY25-10032024-000943-B	<2

WS- 000944	9/11/2024	9/11/2025	3	Cooler	In cafeteria High Left	WF-09112024-000944	10/15/2024	FT-FY25-10032024-000944-A	<2	FT-FY25-10032024-000944-B	<2
WS- 000948	4/17/2024	4/17/2025	4	Break Room	In staff lounge room 430	WF-04172024-000948	10/15/2024	FT-FY25-10032024-000948-A	<2	FT-FY25-10032024-000948-B	<2
WS- 000959	4/17/2024	4/17/2025	3	Break Room	In workroom 317	WF-04172024-000959	10/15/2024	FT-FY25-10032024-000959-A	<2	FT-FY25-10032024-000959-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000967	11/14/2023	11/14/2024	3	Food Prep Sink	In kitchen first clockwise from entry	WF-11142023-000967	10/15/2024	FT-FY25-10032024-000967-A	<2	FT-FY25-10032024-000967-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.