



# MARIE REED LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000849	Utility	Basement	in boiler room (water source)	WT-042916-866-A	< 1	WT-042916-866-B	8				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000850	Kitchen	Basement	in kitchen Left	WT-042916-867-A	< 1	WT-042916-867-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000851	Kitchen	Basement	in kitchen Right	WT-042916-868-A	< 1	WT-042916-868-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000853	Health Suite	1	In health suite	WT-042916-870-A	< 1	WT-042916-870-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000854	Cooler	1	In hallway, adjacent to general office	WT-042916-871-A	< 1	WT-042916-871-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000855	Cooler	1	In hallway adjacent to boys restroom, near entrance	WT-042916-872-A	< 1	WT-042916-872-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000858	Classroom	1	In classroom pk-3, second sink clockwise from west entry door	WT-042916-875-A	< 1	WT-042916-875-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000860	Cooler	1	In classroom PK-3 adjacent boys restroom	WT-042916-877-A	< 1	WT-042916-877-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000861	Classroom	1	In classroom pk-3, fourth sink clockwise from west entry door	WT-042916-878-A	2	WT-042916-878-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000862	Classroom	1	In classroom pk4 east wall adjacent girls restroom	WT-042916-879-A	3	WT-042916-879-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000863	Cooler	1	In classroom pk4 east wall adjacent to girls restroom	WT-042916-880-A	< 1	WT-042916-880-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000864	Classroom	1	In classroom pk-3, fifth sink clockwise from west entry door	WT-042916-881-A	< 1	WT-042916-881-B	2				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000865	Classroom	1	In classroom pk-3, sixth sink clockwise from west entry door	WT-042916-882-A	< 1	WT-042916-882-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000866	Classroom	1	In classroom pk-3, first sink clockwise from west entry door	WT-042916-883-A	3	WT-042916-883-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000867	Classroom	1	In classroom pk-3, third sink clockwise from west entry door	WT-042916-884-A	< 1	WT-042916-884-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000868	Cooler	1	In auditorium	WT-042916-885-A	3	WT-042916-885-B	3				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000870	Break Room	1	In teachers lounge	WT-042916-887-A	4	WT-042916-887-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000871	Cooler	2	In early learning center 3, between stairwell and unisex restroom	WT-042916-888-A	2	WT-042916-888-B	2				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000872	Cooler	2	In early learning center 1, between stairwell and custodian closet 1	WT-042916-889-A	< 1	WT-042916-889-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000873	Classroom	2	In copy room area near storage room 22	WT-042916-890-A	2	WT-042916-890-B	1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000874	Cooler	2	In early learning center 1, between stairwell and teachers restroom	WT-042916-891-A	< 1	WT-042916-891-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000875	Classroom	2	In art and science room 6	WT-042916-892-A	< 1	WT-042916-892-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000876	Cooler	2	In early learning center 3, between stairwell and teachers restroom	WT-042916-893-A	< 1	WT-042916-893-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000878	Classroom	2	In art and science room 1	WT-042916-895-A	10	WT-042916-895-B	1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000879	Cooler	2	In early learning center 3, between stairwell and custodian closet	WT-042916-896-A	< 1	WT-042916-896-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000880	Cooler	2	In early learning center 3, between stairwell and custodian closet 4	WT-042916-897-A	< 1	WT-042916-897-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000881	Classroom	2	In art and science room 4	WT-042916-898-A	< 1	WT-042916-898-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000882	Classroom	2	In art and science room 3	WT-042916-899-A	2	WT-042916-899-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000883	Cooler	2	In early learning center 3, between stairwell and teachers restroom	WT-042916-900-A	< 1	WT-042916-900-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000888	Cooler	Ground Floor	In UPO room	WT-042916-905-A	2	WT-042916-905-B	3				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000889	Break Room	Ground Floor	In UPO room	WT-042916-906-A	< 1	WT-042916-906-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000890	Classroom	Ground Floor	In UPO room Left High	WT-042916-907-A	2	WT-042916-907-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000891	Classroom	Ground Floor	In UPO room Mid Low	WT-042916-908-A	< 1	WT-042916-908-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000892	Classroom	Ground Floor	In UPO room Right Low	WT-042916-909-A	< 1	WT-042916-909-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000893	Classroom	2	In art and science room, on west wall, near WT-911	WT-042916-910-A	1	WT-042916-910-B	< 1				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000894	Cooler	2	In hallway adjacent custodial storage 2	WT-042916-911-A	< 1	WT-042916-911-B	2				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000895	Classroom	2	In classroom east wall	WT-042916-912-A	< 1	WT-042916-912-B	2				
MARIE REED ELEMENTARY SCHOOL	5/3/2016	WS-000896	Classroom	2	In art and science room 5	WT-042916-913-A	1	WT-042916-913-B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.