



# Marie Reed Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000945	3/27/2024	3/27/2025	1	Cooler	In pool room 160 Left	WF-03272024-000945	4/18/2024	FT-FY24-04022024-000945-A	<1	FT-FY24-04022024-000945-B	<1
WS- 000946	3/27/2024	3/27/2025	1	Bottle Filler	In pool room 160	WF-03272024-000946	4/18/2024	FT-FY24-04022024-000946-A	<1	FT-FY24-04022024-000946-B	<1
WS- 000947	3/27/2024	3/27/2025	1	Cooler	In pool room 160 Low Right	WF-03272024-000947	4/18/2024	FT-FY24-04022024-000947-A	<1	FT-FY24-04022024-000947-B	<1
WS- 000964	3/27/2024	3/27/2025	2	Cooler	In hallway across from phys ed office 272 High Left	WF-03272024-000964	4/18/2024	FT-FY24-04022024-000964-A	<1	FT-FY24-04022024-000964-B	<1
WS- 000965	3/27/2024	3/27/2025	2	Cooler	In hallway across from phys ed office 272 Low Right	WF-03272024-000965	4/18/2024	FT-FY24-04022024-000965-A	<1	FT-FY24-04022024-000965-B	<1
WS- 000966	3/27/2024	3/27/2025	2	Bottle Filler	In hallway across from phys ed office 272	WF-03272024-000966	4/18/2024	FT-FY24-04022024-000966-A	<1	FT-FY24-04022024-000966-B	<1