



Marie Reed ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000900	8/15/2017	8/15/2018	4	Cooler	In hallway adjacent to girls restroom	WF-82017-000900	11/10/2017	FT-FY18--82017-000900-A	<1	FT-FY18--82017-000900-B	<1
WS- 000901	8/16/2017	8/16/2018	4	Break Room	In staff lounge 472	WF-82017-000901	11/10/2017	FT-FY18--82017-000901-A	<1	FT-FY18--82017-000901-B	<1
WS- 000906	8/16/2017	8/16/2018	4	Combo Fountain	In classroom 403	WF-82017-000906	11/10/2017	FT-FY18--82017-000906-A	<1	FT-FY18--82017-000906-B	<1
WS- 000915	8/17/2017	8/17/2018	4	Combo Fountain	In classroom 415	WF-82017-000915	11/10/2017	FT-FY18--82017-000915-A	<1	FT-FY18--82017-000915-B	<1
WS- 000916	8/16/2017	8/16/2018	4	Combo Fountain	In library room 400	WF-82017-000916	11/10/2017	FT-FY18--82017-000916-A	<1	FT-FY18--82017-000916-B	<1
WS- 000918	8/16/2017	8/16/2018	4	Combo Fountain	In classroom 417	WF-82017-000918	11/10/2017	FT-FY18--82017-000918-A	<1	FT-FY18--82017-000918-B	<1
WS- 000920	8/16/2017	8/16/2018	4	Combo Fountain	In classroom 419	WF-82017-000920	11/10/2017	FT-FY18--82017-000920-A	<1	FT-FY18--82017-000920-B	<1
WS- 000924	10/31/2017	10/31/2018	3	Combo Faucet	In classroom 301	WF-102017-000924	11/10/2017	FT-FY18-102017-000924-A	2.5	FT-FY18-102017-000924-B	<1
WS- 000925	8/16/2017	8/16/2018	3	Combo Fountain	In classroom 301	WF-82017-000925	11/10/2017	FT-FY18--82017-000925-A	<1	FT-FY18--82017-000925-B	<1
WS- 000928	10/31/2017	10/31/2018	3	Combo Faucet	In classroom 310	WF-102017-000928	11/10/2017	FT-FY18-102017-000928-A	1.7	FT-FY18-102017-000928-B	<1
WS- 000932	10/31/2017	10/31/2018	3	Combo Faucet	In classroom 311	WF-102017-000932	11/10/2017	FT-FY18-102017-000932-A	2.5	FT-FY18-102017-000932-B	<1
WS- 000935	8/16/2017	8/16/2018	3	Combo Fountain	In classroom 302	WF-82017-000935	11/10/2017	FT-FY18--82017-000935-A	<1	FT-FY18--82017-000935-B	<1
WS- 000936	10/31/2017	10/31/2018	3	Combo Faucet	In classroom 319	WF-102017-000936	11/10/2017	FT-FY18-102017-000936-A	2.3	FT-FY18-102017-000936-B	<1
WS- 000938	10/31/2017	10/31/2018	3	Combo Faucet	In classroom 321	WF-102017-000938	11/10/2017	FT-FY18-102017-000938-A	<1	FT-FY18-102017-000938-B	<1