



# Marie Reed ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000897	6/21/2018	6/21/2019	4	Cooler	In hallway adjacent to room 439	WF-06212018-000897	11/29/2018	FT-FY19-112018-000897-A	<1	FT-FY19-112018-000897-B	<1
WS-000899	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 467	WF-06212018-000899	11/29/2018	FT-FY19-112018-000899-A	<1	FT-FY19-112018-000899-B	<1
WS-000900	6/21/2018	6/21/2019	4	Cooler	In hallway adjacent to girls restroom	WF-06212018-000900	11/29/2018	FT-FY19-112018-000900-A	<1	FT-FY19-112018-000900-B	<1
WS-000901	6/21/2018	6/21/2019	4	Break Room	In staff lounge 472	WF-06212018-000901	11/29/2018	FT-FY19-112018-000901-A	<1	FT-FY19-112018-000901-B	<1
WS-000902	6/21/2018	6/21/2019	4	Cooler	In hallway adjacent to boys restroom	WF-06212018-000902	11/29/2018	FT-FY19-112018-000902-A	<1	FT-FY19-112018-000902-B	<1
WS-000903	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 401	WF-06212018-000903	11/29/2018	FT-FY19-112018-000903-A	<1	FT-FY19-112018-000903-B	<1
WS-000906	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 403	WF-06212018-000906	11/29/2018	FT-FY19-112018-000906-A	<1	FT-FY19-112018-000906-B	<1
WS-000908	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 406	WF-06212018-000908	11/29/2018	FT-FY19-112018-000908-A	<1	FT-FY19-112018-000908-B	<1
WS-000910	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 409	WF-06212018-000910	11/29/2018	FT-FY19-112018-000910-A	<1	FT-FY19-112018-000910-B	<1
WS-000911	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 411	WF-06212018-000911	11/29/2018	FT-FY19-112018-000911-A	<1	FT-FY19-112018-000911-B	<1
WS-000913	6/21/2018	6/21/2019	4	Cooler	In hallway adjacent to girls restroom	WF-06212018-000913	11/29/2018	FT-FY19-112018-000913-A	<1	FT-FY19-112018-000913-B	<1
WS-000915	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 415	WF-06212018-000915	11/29/2018	FT-FY19-112018-000915-A	<1	FT-FY19-112018-000915-B	<1
WS-000916	6/21/2018	6/21/2019	4	Combo Fountain	In library room 400	WF-06212018-000916	11/29/2018	FT-FY19-112018-000916-A	<1	FT-FY19-112018-000916-B	<1
WS-000918	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 417	WF-06212018-000918	11/29/2018	FT-FY19-112018-000918-A	<1	FT-FY19-112018-000918-B	<1
WS-000920	6/21/2018	6/21/2019	4	Combo Fountain	In classroom 419	WF-06212018-000920	11/29/2018	FT-FY19-112018-000920-A	<1	FT-FY19-112018-000920-B	<1
WS-000922	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 306	WF-10082018-000922	11/29/2018	FT-FY19-112018-000922-A	<1	FT-FY19-112018-000922-B	<1
WS-000923	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 306	WF-06212018-000923	11/29/2018	FT-FY19-112018-000923-A	<1	FT-FY19-112018-000923-B	<1
WS-000924	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 301	WF-10082018-000924	11/29/2018	FT-FY19-112018-000924-A	<1	FT-FY19-112018-000924-B	<1
WS-000925	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 301	WF-06212018-000925	11/29/2018	FT-FY19-112018-000925-A	<1	FT-FY19-112018-000925-B	<1
WS-000926	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 308	WF-10082018-000926	11/29/2018	FT-FY19-112018-000926-A	<1	FT-FY19-112018-000926-B	<1
WS-000927	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 308	WF-06212018-000927	11/29/2018	FT-FY19-112018-000927-A	<1	FT-FY19-112018-000927-B	<1
WS-000928	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 310	WF-10082018-000928	11/29/2018	FT-FY19-112018-000928-A	1.5	FT-FY19-112018-000928-B	<1
WS-000929	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 310	WF-06212018-000929	11/29/2018	FT-FY19-112018-000929-A	<1	FT-FY19-112018-000929-B	<1
WS-000930	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 305	WF-10082018-000930	11/29/2018	FT-FY19-112018-000930-A	<1	FT-FY19-112018-000930-B	<1
WS-000931	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 305	WF-06212018-000931	11/29/2018	FT-FY19-112018-000931-A	<1	FT-FY19-112018-000931-B	<1
WS-000932	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 311	WF-10082018-000932	11/29/2018	FT-FY19-112018-000932-A	<1	FT-FY19-112018-000932-B	<1
WS-000933	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 311	WF-06212018-000933	11/29/2018	FT-FY19-112018-000933-A	<1	FT-FY19-112018-000933-B	<1
WS-000934	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 302	WF-10082018-000934	11/29/2018	FT-FY19-112018-000934-A	2	FT-FY19-112018-000934-B	<1
WS-000935	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 302	WF-06212018-000935	11/29/2018	FT-FY19-112018-000935-A	<1	FT-FY19-112018-000935-B	<1
WS-000936	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 319	WF-10082018-000936	11/29/2018	FT-FY19-112018-000936-A	<1	FT-FY19-112018-000936-B	<1
WS-000937	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 319	WF-06212018-000937	11/29/2018	FT-FY19-112018-000937-A	<1	FT-FY19-112018-000937-B	<1
WS-000938	10/8/2018	10/8/2019	3	Combo Faucet	In classroom 321	WF-10082018-000938	11/29/2018	FT-FY19-112018-000938-A	<1	FT-FY19-112018-000938-B	<1
WS-000939	6/21/2018	6/21/2019	3	Combo Fountain	In classroom 321	WF-06212018-000939	11/29/2018	FT-FY19-112018-000939-A	<1	FT-FY19-112018-000939-B	<1

WS- 000940	6/21/2018	6/21/2019	3	Health Suite	In health suite 368D	WF-06212018-000940	11/29/2018	FT-FY19-112018-000940-A	1.1	FT-FY19-112018-000940-B	<1	
WS- 000941	6/21/2018	6/21/2019	3	Break Room	In break room 372	WF-06212018-000941	11/29/2018	FT-FY19-112018-000941-A	<1	FT-FY19-112018-000941-B	<1	
WS- 000942	6/21/2018	6/21/2019	3	Bottle Filler	In cafeteria (bottle filler)	WF-06212018-000942	11/29/2018	FT-FY19-112018-000942-A	<1	FT-FY19-112018-000942-B	<1	
WS- 000943	6/21/2018	6/21/2019	3	Cooler	In cafeteria	Low Right	WF-06212018-000943	11/29/2018	FT-FY19-112018-000943-A	<1	FT-FY19-112018-000943-B	<1
WS- 000944	6/21/2018	6/21/2019	3	Cooler	In cafeteria	High Left	WF-06212018-000944	11/29/2018	FT-FY19-112018-000944-A	<1	FT-FY19-112018-000944-B	<1
WS- 000948	6/21/2018	6/21/2019	4	Break Room	In staff lounge room 430	WF-06212018-000948	11/29/2018	FT-FY19-112018-000948-A	<1	FT-FY19-112018-000948-B	<1	
WS- 000959	6/21/2018	6/21/2019	3	Break Room	In workroom 317	WF-06212018-000959	11/29/2018	FT-FY19-112018-000959-A	<1	FT-FY19-112018-000959-B	<1	

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000967	3	Food Prep Sink	In kitchen first clockwise from entry			11/29/2018	FT-FY19-112018-000967-A	<1	FT-FY19-112018-000967-B	<1