



Marvin Gaye Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000470	12/14/2023	12/14/2024	1	Food Prep Sink	In teaching kitchen	WF-12142023-000470	5/3/2024	FT-FY24-04172024-000470-A	1.1	FT-FY24-04172024-000470-B	<1
WS- 000471	4/10/2024	4/10/2025	2	Bottle Filler	In hallway adjacent to music room 202	WF-04102024-000471	5/3/2024	FT-FY24-04172024-000471-A	<1	FT-FY24-04172024-000471-B	<1
WS- 000472	4/10/2024	4/10/2025	2	Cooler	In hallway adjacent to music room 202	WF-04102024-000472	5/3/2024	FT-FY24-04172024-000472-A	<1	FT-FY24-04172024-000472-B	<1