



# Maury Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014600	3/8/2023	3/8/2024	1	Health Suite	In room 102C treatment	WF-03082023-014600	12/21/2023	FT-FY24-11012023-014600-A	<1	FT-FY24-11012023-014600-B	<1
WS-014601	3/8/2023	3/8/2024	1	Break Room	In room 105D staff lounge	WF-03082023-014601	12/21/2023	FT-FY24-11012023-014601-A	<1	FT-FY24-11012023-014601-B	<1
WS-014602	3/8/2023	3/8/2024	1	Health Suite	In room 105A wellness room	WF-03082023-014602	12/21/2023	FT-FY24-11012023-014602-A	1.6	FT-FY24-11012023-014602-B	<1
WS-014604	3/8/2023	3/8/2024	1	Combo Fountain	In room 137 art	WF-03082023-014604	12/21/2023	FT-FY24-11012023-014604-A	4.8	FT-FY24-11012023-014604-B	<1
WS-014606	3/8/2023	3/8/2024	1	Bottle Filler	In room 134 cafeteria adjacent to kitchen entrance	WF-03082023-014606	12/21/2023	FT-FY24-11012023-014606-A	<1	FT-FY24-11012023-014606-B	<1
WS-014607	3/8/2023	3/8/2024	1	Cooler	In room 134 cafeteria adjacent to kitchen entrance High Left	WF-03082023-014607	12/21/2023	FT-FY24-11012023-014607-A	<1	FT-FY24-11012023-014607-B	<1
WS-014608	3/8/2023	3/8/2024	1	Cooler	In room 134 cafeteria adjacent to kitchen entrance Low Right	WF-03082023-014608	12/21/2023	FT-FY24-11012023-014608-A	<1	FT-FY24-11012023-014608-B	<1
WS-014616	3/8/2023	3/8/2024	1	Bottle Filler	In room 135 gymnasium adjacent to 139 restroom	WF-03082023-014616	12/21/2023	FT-FY24-11012023-014616-A	<1	FT-FY24-11012023-014616-B	<1
WS-014617	3/8/2023	3/8/2024	1	Cooler	In room 135 gymnasium adjacent to 139 restroom High Left	WF-03082023-014617	12/21/2023	FT-FY24-11012023-014617-A	<1	FT-FY24-11012023-014617-B	<1
WS-014618	3/8/2023	3/8/2024	1	Cooler	In room 135 gymnasium adjacent to 139 restroom Low Right	WF-03082023-014618	12/21/2023	FT-FY24-11012023-014618-A	<1	FT-FY24-11012023-014618-B	1.4
WS-014619	3/8/2023	3/8/2024	1	Bottle Filler	In room 133 atrium between restroom	WF-03082023-014619	12/21/2023	FT-FY24-11012023-014619-A	<1	FT-FY24-11012023-014619-B	<1
WS-014621	3/8/2023	3/8/2024	1	Cooler	In room 133 atrium between restroom Low Right	WF-03082023-014621	12/21/2023	FT-FY24-11012023-014621-A	<1	FT-FY24-11012023-014621-B	<1
WS-014623	3/8/2023	3/8/2024	1	Break Room	In room 120 pantry	WF-03082023-014623	12/21/2023	FT-FY24-11012023-014623-A	<1	FT-FY24-11012023-014623-B	<1
WS-014625	3/8/2023	3/8/2024	1	Combo Fountain	In room 122 think tank	WF-03082023-014625	12/21/2023	FT-FY24-11012023-014625-A	1.7	FT-FY24-11012023-014625-B	<1
WS-014628	9/25/2023	9/25/2024	1	Combo Faucet	In room 121 pre-k	WF-09252023-014628	12/21/2023	FT-FY24-11012023-014628-A	1.4	FT-FY24-11012023-014628-B	<1
WS-014629	3/8/2023	3/8/2024	1	Combo Fountain	In room 121 pre-k	WF-03082023-014629	12/21/2023	FT-FY24-11012023-014629-A	<1	FT-FY24-11012023-014629-B	<1
WS-014631	3/8/2023	3/8/2024	1	Combo Fountain	In room 124 music	WF-03082023-014631	12/21/2023	FT-FY24-11012023-014631-A	<1	FT-FY24-11012023-014631-B	<1
WS-014632	9/25/2023	9/25/2024	1	Combo Faucet	In room 123 pre-k	WF-09252023-014632	12/21/2023	FT-FY24-11012023-014632-A	<1	FT-FY24-11012023-014632-B	<1
WS-014633	3/8/2023	3/8/2024	1	Combo Fountain	In room 123 pre-k	WF-03082023-014633	12/21/2023	FT-FY24-11012023-014633-A	<1	FT-FY24-11012023-014633-B	<1
WS-014640	9/25/2023	9/25/2024	1	Combo Faucet	In room 127 pre-k	WF-09252023-014640	12/21/2023	FT-FY24-11012023-014640-A	1.9	FT-FY24-11012023-014640-B	<1
WS-014641	3/8/2023	3/8/2024	1	Combo Fountain	In room 127 pre-k	WF-03082023-014641	12/21/2023	FT-FY24-11012023-014641-A	1.9	FT-FY24-11012023-014641-B	<1
WS-014642	9/25/2023	9/25/2024	1	Combo Faucet	In room 128 pre-k	WF-09252023-014642	12/21/2023	FT-FY24-11012023-014642-A	<1	FT-FY24-11012023-014642-B	<1
WS-014643	3/8/2023	3/8/2024	1	Combo Fountain	In room 128 pre-k	WF-03082023-014643	12/21/2023	FT-FY24-11012023-014643-A	<1	FT-FY24-11012023-014643-B	<1
WS-014645	3/8/2023	3/8/2024	2	Break Room	In room 209 pantry	WF-03082023-014645	12/21/2023	FT-FY24-11012023-014645-A	<1	FT-FY24-11012023-014645-B	<1
WS-014646	3/8/2023	3/8/2024	2	Bottle Filler	In hallway adjacent to 210A janitor	WF-03082023-014646	12/21/2023	FT-FY24-11012023-014646-A	<1	FT-FY24-11012023-014646-B	<1
WS-014647	3/8/2023	3/8/2024	2	Cooler	In hallway adjacent to 210A janitor High Left	WF-03082023-014647	12/21/2023	FT-FY24-11012023-014647-A	<1	FT-FY24-11012023-014647-B	<1
WS-014648	3/8/2023	3/8/2024	2	Cooler	In hallway adjacent to 210A janitor Low Right	WF-03082023-014648	12/21/2023	FT-FY24-11012023-014648-A	<1	FT-FY24-11012023-014648-B	<1
WS-014650	9/25/2023	9/25/2024	2	Combo Faucet	In room 211 kindergarten	WF-09252023-014650	12/21/2023	FT-FY24-11012023-014650-A	2.3	FT-FY24-11012023-014650-B	<1
WS-014651	3/8/2023	3/8/2024	2	Combo Fountain	In room 211 kindergarten	WF-03082023-014651	12/21/2023	FT-FY24-11012023-014651-A	<1	FT-FY24-11012023-014651-B	<1
WS-014653	9/25/2023	9/25/2024	2	Combo Faucet	In room 216 kindergarten	WF-09252023-014653	12/21/2023	FT-FY24-11012023-014653-A	3.6	FT-FY24-11012023-014653-B	<1
WS-014654	3/8/2023	3/8/2024	2	Combo Fountain	In room 216 kindergarten	WF-03082023-014654	12/21/2023	FT-FY24-11012023-014654-A	<1	FT-FY24-11012023-014654-B	<1
WS-014657	9/25/2023	9/25/2024	2	Combo Faucet	In room 213 kindergarten	WF-09252023-014657	12/21/2023	FT-FY24-11012023-014657-A	2.5	FT-FY24-11012023-014657-B	<1
WS-014658	3/8/2023	3/8/2024	2	Combo Fountain	In room 213 kindergarten	WF-03082023-014658	12/21/2023	FT-FY24-11012023-014658-A	<1	FT-FY24-11012023-014658-B	<1
WS-014660	9/25/2023	9/25/2024	2	Combo Faucet	In room 215 kindergarten	WF-09252023-014660	12/21/2023	FT-FY24-11012023-014660-A	2.2	FT-FY24-11012023-014660-B	<1
WS-014661	3/8/2023	3/8/2024	2	Combo Fountain	In room 215 kindergarten	WF-03082023-014661	12/21/2023	FT-FY24-11012023-014661-A	<1	FT-FY24-11012023-014661-B	<1
WS-014664	3/8/2023	3/8/2024	2	Combo Fountain	In room 217 first grade	WF-03082023-014664	12/21/2023	FT-FY24-11012023-014664-A	<1	FT-FY24-11012023-014664-B	<1

WS-014667	3/8/2023	3/8/2024	2	Combo Fountain	In room 218 first grade		WF-03082023-014667	12/21/2023	FT-FY24-11012023-014667-A	<1	FT-FY24-11012023-014667-B	<1
WS-014670	3/8/2023	3/8/2024	2	Combo Fountain	In room 219 first grade		WF-03082023-014670	12/21/2023	FT-FY24-11012023-014670-A	<1	FT-FY24-11012023-014670-B	<1
WS-014673	3/8/2023	3/8/2024	2	Combo Fountain	In room 222 first grade		WF-03082023-014673	12/21/2023	FT-FY24-11012023-014673-A	<1	FT-FY24-11012023-014673-B	<1
WS-014675	3/8/2023	3/8/2024	3	Combo Fountain	In room 308 maker space		WF-03082023-014675	12/21/2023	FT-FY24-11012023-014675-A	1.8	FT-FY24-11012023-014675-B	<1
WS-014677	3/8/2023	3/8/2024	3	Break Room	In room 313 pantry		WF-03082023-014677	12/21/2023	FT-FY24-11012023-014677-A	<1	FT-FY24-11012023-014677-B	<1
WS-014678	3/8/2023	3/8/2024	3	Bottle Filler	In hallway adjacent to 312A janitor		WF-03082023-014678	12/21/2023	FT-FY24-11012023-014678-A	<1	FT-FY24-11012023-014678-B	<1
WS-014679	3/8/2023	3/8/2024	3	Cooler	In hallway adjacent to 312A janitor	High Left	WF-03082023-014679	12/21/2023	FT-FY24-11012023-014679-A	<1	FT-FY24-11012023-014679-B	<1
WS-014680	3/8/2023	3/8/2024	3	Cooler	In hallway adjacent to 312A janitor	Low Right	WF-03082023-014680	12/21/2023	FT-FY24-11012023-014680-A	<1	FT-FY24-11012023-014680-B	<1
WS-014682	3/8/2023	3/8/2024	3	Combo Fountain	In room 319 fourth grade		WF-03082023-014682	12/21/2023	FT-FY24-11012023-014682-A	<1	FT-FY24-11012023-014682-B	<1
WS-014684	3/8/2023	3/8/2024	3	Combo Fountain	In room 318 fourth grade		WF-03082023-014684	12/21/2023	FT-FY24-11012023-014684-A	<1	FT-FY24-11012023-014684-B	<1
WS-014686	3/8/2023	3/8/2024	3	Combo Fountain	In room 320 fourth grade		WF-03082023-014686	12/21/2023	FT-FY24-11012023-014686-A	<1	FT-FY24-11012023-014686-B	<1
WS-014688	3/8/2023	3/8/2024	3	Combo Fountain	In room 323 fifth grade		WF-03082023-014688	12/21/2023	FT-FY24-11012023-014688-A	<1	FT-FY24-11012023-014688-B	<1
WS-014690	3/8/2023	3/8/2024	3	Combo Fountain	In room 324 fifth grade		WF-03082023-014690	12/21/2023	FT-FY24-11012023-014690-A	<1	FT-FY24-11012023-014690-B	<1
WS-014692	3/8/2023	3/8/2024	3	Combo Fountain	In room 326 fifth grade		WF-03082023-014692	12/21/2023	FT-FY24-11012023-014692-A	<1	FT-FY24-11012023-014692-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014615	1/18/2023	1/18/2024	1	Food Prep Sink	In kitchen sixth clockwise from entry	WF-01182023-014615	12/21/2023	FT-FY24-11012023-014615-A	<1	FT-FY24-11012023-014615-B	<1
WS-014652	1/18/2023	1/18/2024	2	Food Prep Sink	In room 214 discovery cave	WF-01182023-014652	12/21/2023	FT-FY24-11012023-014652-A	2.8	FT-FY24-11012023-014652-B	<1