



Maury Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014600	3/24/2021	3/24/2022	1	Health Suite	In room 102C treatment	WF-03242021-014600	3/1/2022	FT-FY22-12292021-014600-A	<1	FT-FY22-12292021-014600-B	<1	
WS-014601	3/24/2021	3/24/2022	1	Break Room	In room 105D staff lounge	WF-03242021-014601	3/1/2022	FT-FY22-12292021-014601-A	<1	FT-FY22-12292021-014601-B	<1	
WS-014602	3/24/2021	3/24/2022	1	Health Suite	In room 105A wellness room	WF-03242021-014602	3/1/2022	FT-FY22-12292021-014602-A	1.3	FT-FY22-12292021-014602-B	<1	
WS-014604	3/24/2021	3/24/2022	1	Combo Fountain	In room 137 art	WF-03242021-014604	3/1/2022	FT-FY22-12292021-014604-A	<1	FT-FY22-12292021-014604-B	<1	
WS-014616	3/24/2021	3/24/2022	1	Bottle Filler	In room 135 gymnasium adjacent to 139 restroom	WF-03242021-014616	3/1/2022	FT-FY22-12292021-014616-A	<1	FT-FY22-12292021-014616-B	<1	
WS-014617	3/24/2021	3/24/2022	1	Cooler	In room 135 gymnasium adjacent to 139 restroom	High Left	WF-03242021-014617	3/1/2022	FT-FY22-12292021-014617-A	<1	FT-FY22-12292021-014617-B	<1
WS-014618	3/24/2021	3/24/2022	1	Cooler	In room 135 gymnasium adjacent to 139 restroom	Low Right	WF-03242021-014618	3/1/2022	FT-FY22-12292021-014618-A	<1	FT-FY22-12292021-014618-B	<1
WS-014619	6/17/2021	6/17/2022	1	Bottle Filler	In room 133 atrium between restroom	WF-06172021-014619	3/1/2022	FT-FY22-12292021-014619-A	<1	FT-FY22-12292021-014619-B	<1	
WS-014620	6/17/2021	6/17/2022	1	Cooler	In room 133 atrium between restroom	High Left	WF-06172021-014620	3/1/2022	FT-FY22-12292021-014620-A	<1	FT-FY22-12292021-014620-B	<1
WS-014621	6/17/2021	6/17/2022	1	Cooler	In room 133 atrium between restroom	Low Right	WF-06172021-014621	3/1/2022	FT-FY22-12292021-014621-A	<1	FT-FY22-12292021-014621-B	<1
WS-014623	3/24/2021	3/24/2022	1	Break Room	In room 120 pantry	WF-03242021-014623	3/1/2022	FT-FY22-12292021-014623-A	<1	FT-FY22-12292021-014623-B	<1	
WS-014625	3/24/2021	3/24/2022	1	Combo Fountain	In room 122 think tank	WF-03242021-014625	3/1/2022	FT-FY22-12292021-014625-A	<1	FT-FY22-12292021-014625-B	<1	
WS-014628	10/13/2021	10/13/2022	1	Combo Faucet	In room 121 pre-k	WF-10132021-014628	3/1/2022	FT-FY22-12292021-014628-A	<1	FT-FY22-12292021-014628-B	<1	
WS-014629	3/24/2021	3/24/2022	1	Combo Fountain	In room 121 pre-k	WF-03242021-014629	3/1/2022	FT-FY22-12292021-014629-A	<1	FT-FY22-12292021-014629-B	<1	
WS-014631	3/24/2021	3/24/2022	1	Combo Fountain	In room 124 music	WF-03242021-014631	3/1/2022	FT-FY22-12292021-014631-A	<1	FT-FY22-12292021-014631-B	<1	
WS-014632	10/13/2021	10/13/2022	1	Combo Faucet	In room 123 pre-k	WF-10132021-014632	3/1/2022	FT-FY22-12292021-014632-A	<1	FT-FY22-12292021-014632-B	<1	
WS-014633	3/24/2021	3/24/2022	1	Combo Fountain	In room 123 pre-k	WF-03242021-014633	3/1/2022	FT-FY22-12292021-014633-A	<1	FT-FY22-12292021-014633-B	<1	
WS-014637	10/13/2021	10/13/2022	1	Combo Faucet	In room 125 pre-k	WF-10132021-014637	3/1/2022	FT-FY22-12292021-014637-A	<1	FT-FY22-12292021-014637-B	<1	
WS-014638	3/24/2021	3/24/2022	1	Combo Fountain	In room 125 pre-k	WF-03242021-014638	3/1/2022	FT-FY22-12292021-014638-A	<1	FT-FY22-12292021-014638-B	<1	
WS-014640	10/13/2021	10/13/2022	1	Combo Faucet	In room 127 pre-k	WF-10132021-014640	3/1/2022	FT-FY22-12292021-014640-A	<1	FT-FY22-12292021-014640-B	<1	
WS-014641	3/24/2021	3/24/2022	1	Combo Fountain	In room 127 pre-k	WF-03242021-014641	3/1/2022	FT-FY22-12292021-014641-A	<1	FT-FY22-12292021-014641-B	<1	
WS-014642	10/13/2021	10/13/2022	1	Combo Faucet	In room 128 pre-k	WF-10132021-014642	3/1/2022	FT-FY22-12292021-014642-A	<1	FT-FY22-12292021-014642-B	<1	
WS-014643	3/24/2021	3/24/2022	1	Combo Fountain	In room 128 pre-k	WF-03242021-014643	3/1/2022	FT-FY22-12292021-014643-A	<1	FT-FY22-12292021-014643-B	<1	
WS-014645	3/24/2021	3/24/2022	2	Break Room	In room 209 pantry	WF-03242021-014645	3/1/2022	FT-FY22-12292021-014645-A	<1	FT-FY22-12292021-014645-B	<1	
WS-014646	3/24/2021	3/24/2022	2	Bottle Filler	In hallway adjacent to 210A janitor	WF-03242021-014646	3/1/2022	FT-FY22-12292021-014646-A	<1	FT-FY22-12292021-014646-B	<1	
WS-014647	3/24/2021	3/24/2022	2	Cooler	In hallway adjacent to 210A janitor	High Left	WF-03242021-014647	3/1/2022	FT-FY22-12292021-014647-A	<1	FT-FY22-12292021-014647-B	<1
WS-014648	3/24/2021	3/24/2022	2	Cooler	In hallway adjacent to 210A janitor	Low Right	WF-03242021-014648	3/1/2022	FT-FY22-12292021-014648-A	<1	FT-FY22-12292021-014648-B	<1
WS-014650	10/13/2021	10/13/2022	2	Combo Faucet	In room 211 kindergarten	WF-10132021-014650	3/1/2022	FT-FY22-12292021-014650-A	<1	FT-FY22-12292021-014650-B	<1	
WS-014651	3/24/2021	3/24/2022	2	Combo Fountain	In room 211 kindergarten	WF-03242021-014651	3/1/2022	FT-FY22-12292021-014651-A	<1	FT-FY22-12292021-014651-B	<1	
WS-014653	10/13/2021	10/13/2022	2	Combo Faucet	In room 216 kindergarten	WF-10132021-014653	3/1/2022	FT-FY22-12292021-014653-A	2.1	FT-FY22-12292021-014653-B	<1	
WS-014654	3/24/2021	3/24/2022	2	Combo Fountain	In room 216 kindergarten	WF-03242021-014654	3/1/2022	FT-FY22-12292021-014654-A	<1	FT-FY22-12292021-014654-B	<1	
WS-014657	10/13/2021	10/13/2022	2	Combo Faucet	In room 213 kindergarten	WF-10132021-014657	3/1/2022	FT-FY22-12292021-014657-A	<1	FT-FY22-12292021-014657-B	<1	
WS-014658	3/24/2021	3/24/2022	2	Combo Fountain	In room 213 kindergarten	WF-03242021-014658	3/1/2022	FT-FY22-12292021-014658-A	<1	FT-FY22-12292021-014658-B	<1	
WS-014660	10/13/2021	10/13/2022	2	Combo Faucet	In room 215 kindergarten	WF-10132021-014660	3/1/2022	FT-FY22-12292021-014660-A	<1	FT-FY22-12292021-014660-B	<1	
WS-014661	3/24/2021	3/24/2022	2	Combo Fountain	In room 215 kindergarten	WF-03242021-014661	3/1/2022	FT-FY22-12292021-014661-A	<1	FT-FY22-12292021-014661-B	<1	
WS-014664	3/24/2021	3/24/2022	2	Combo Fountain	In room 217 first grade	WF-03242021-014664	3/1/2022	FT-FY22-12292021-014664-A	<1	FT-FY22-12292021-014664-B	<1	

WS-014667	3/24/2021	3/24/2022	2	Combo Fountain	In room 218 first grade		WF-03242021-014667	3/1/2022	FT-FY22-12292021-014667-A	<1	FT-FY22-12292021-014667-B	<1
WS-014670	3/24/2021	3/24/2022	2	Combo Fountain	In room 219 first grade		WF-03242021-014670	3/1/2022	FT-FY22-12292021-014670-A	1.7	FT-FY22-12292021-014670-B	<1
WS-014673	3/24/2021	3/24/2022	2	Combo Fountain	In room 222 first grade		WF-03242021-014673	3/1/2022	FT-FY22-12292021-014673-A	<1	FT-FY22-12292021-014673-B	<1
WS-014675	3/24/2021	3/24/2022	3	Combo Fountain	In room 308 maker space		WF-03242021-014675	3/1/2022	FT-FY22-12292021-014675-A	<1	FT-FY22-12292021-014675-B	<1
WS-014677	3/24/2021	3/24/2022	3	Break Room	In room 313 pantry		WF-03242021-014677	3/1/2022	FT-FY22-12292021-014677-A	<1	FT-FY22-12292021-014677-B	<1
WS-014678	3/24/2021	3/24/2022	3	Bottle Filler	In hallway adjacent to 312A janitor		WF-03242021-014678	3/1/2022	FT-FY22-12292021-014678-A	<1	FT-FY22-12292021-014678-B	<1
WS-014679	3/24/2021	3/24/2022	3	Cooler	In hallway adjacent to 312A janitor	High Left	WF-03242021-014679	3/1/2022	FT-FY22-12292021-014679-A	<1	FT-FY22-12292021-014679-B	<1
WS-014680	3/24/2021	3/24/2022	3	Cooler	In hallway adjacent to 312A janitor	Low Right	WF-03242021-014680	3/1/2022	FT-FY22-12292021-014680-A	<1	FT-FY22-12292021-014680-B	<1
WS-014682	3/24/2021	3/24/2022	3	Combo Fountain	In room 319 fourth grade		WF-03242021-014682	3/1/2022	FT-FY22-12292021-014682-A	<1	FT-FY22-12292021-014682-B	<1
WS-014684	3/24/2021	3/24/2022	3	Combo Fountain	In room 318 fourth grade		WF-03242021-014684	3/1/2022	FT-FY22-12292021-014684-A	<1	FT-FY22-12292021-014684-B	<1
WS-014686	3/24/2021	3/24/2022	3	Combo Fountain	In room 320 fourth grade		WF-03242021-014686	3/1/2022	FT-FY22-12292021-014686-A	<1	FT-FY22-12292021-014686-B	<1
WS-014688	3/24/2021	3/24/2022	3	Combo Fountain	In room 323 fifth grade		WF-03242021-014688	3/1/2022	FT-FY22-12292021-014688-A	<1	FT-FY22-12292021-014688-B	<1
WS-014690	3/24/2021	3/24/2022	3	Combo Fountain	In room 324 fifth grade		WF-03242021-014690	3/1/2022	FT-FY22-12292021-014690-A	<1	FT-FY22-12292021-014690-B	<1
WS-014692	3/24/2021	3/24/2022	3	Combo Fountain	In room 326 fifth grade		WF-03242021-014692	3/1/2022	FT-FY22-12292021-014692-A	<1	FT-FY22-12292021-014692-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014615	2/15/2021	2/15/2022	1	Food Prep Sink	In kitchen sixth clockwise from entry	WF-02152021-014615	3/1/2022	FT-FY22-12292021-014615-A	<1	FT-FY22-12292021-014615-B	<1	
WS-014652	2/15/2021	2/15/2022	2	Food Prep Sink	In room 214 discovery cave	WF-02152021-014652	3/1/2022	FT-FY22-12292021-014652-A	<1	FT-FY22-12292021-014652-B	<1	