



Maury ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014600	2/24/2025	2/24/2026	1	Health Suite	In room 102C treatment	WF-02242025-014600	1/19/2026	FT-FY26-12112025-014600-A	<2	FT-FY26-12112025-014600-B	<2
WS-014601	2/24/2025	2/24/2026	1	Break Room	In room 105D staff lounge	WF-02242025-014601	1/19/2026	FT-FY26-12112025-014601-A	<2	FT-FY26-12112025-014601-B	<2
WS-014602	2/24/2025	2/24/2026	1	Health Suite	In room 105A wellness room	WF-02242025-014602	1/19/2026	FT-FY26-12112025-014602-A	<2	FT-FY26-12112025-014602-B	<2
WS-014604	2/24/2025	2/24/2026	1	Combo Fountain	In room 137 art	WF-02242025-014604	1/19/2026	FT-FY26-12112025-014604-A	<2	FT-FY26-12112025-014604-B	<2
WS-014616	2/24/2025	2/24/2026	1	Bottle Filler	In room 135 gymnasium adjacent to 139 restroom	WF-02242025-014616	1/19/2026	FT-FY26-12112025-014616-A	<2	FT-FY26-12112025-014616-B	<2
WS-014618	2/24/2025	2/24/2026	1	Cooler	In room 135 gymnasium adjacent to 139 restroom Low Right	WF-02242025-014618	1/19/2026	FT-FY26-12112025-014618-A	<2	FT-FY26-12112025-014618-B	<2
WS-014619	2/24/2025	2/24/2026	1	Bottle Filler	In room 133 atrium between restroom	WF-02242025-014619	1/19/2026	FT-FY26-12112025-014619-A	<2	FT-FY26-12112025-014619-B	<2
WS-014620	2/24/2025	2/24/2026	1	Cooler	In room 133 atrium between restroom High Left	WF-02242025-014620	1/19/2026	FT-FY26-12112025-014620-A	<2	FT-FY26-12112025-014620-B	<2
WS-014621	2/24/2025	2/24/2026	1	Cooler	In room 133 atrium between restroom Low Right	WF-02242025-014621	1/19/2026	FT-FY26-12112025-014621-A	<2	FT-FY26-12112025-014621-B	<2
WS-014623	2/24/2025	2/24/2026	1	Break Room	In room 120 pantry	WF-02242025-014623	1/19/2026	FT-FY26-12112025-014623-A	<2	FT-FY26-12112025-014623-B	<2
WS-014625	2/24/2025	2/24/2026	1	Combo Fountain	In room 122 think tank	WF-02242025-014625	1/19/2026	FT-FY26-12112025-014625-A	<2	FT-FY26-12112025-014625-B	<2
WS-014628	9/15/2025	9/15/2026	1	Combo Faucet	In room 121 pre-k	WF-09152025-014628	1/19/2026	FT-FY26-12112025-014628-A	<2	FT-FY26-12112025-014628-B	<2
WS-014629	2/24/2025	2/24/2026	1	Combo Fountain	In room 121 pre-k	WF-02242025-014629	1/19/2026	FT-FY26-12112025-014629-A	<2	FT-FY26-12112025-014629-B	<2
WS-014631	2/24/2025	2/24/2026	1	Combo Fountain	In room 124 music	WF-02242025-014631	1/19/2026	FT-FY26-12112025-014631-A	<2	FT-FY26-12112025-014631-B	<2
WS-014632	9/15/2025	9/15/2026	1	Combo Faucet	In room 123 pre-k	WF-09152025-014632	1/19/2026	FT-FY26-12112025-014632-A	<2	FT-FY26-12112025-014632-B	<2
WS-014633	2/24/2025	2/24/2026	1	Combo Fountain	In room 123 pre-k	WF-02242025-014633	1/19/2026	FT-FY26-12112025-014633-A	<2	FT-FY26-12112025-014633-B	<2
WS-014637	9/15/2025	9/15/2026	1	Combo Faucet	In room 125 pre-k	WF-09152025-014637	1/19/2026	FT-FY26-12112025-014637-A	<2	FT-FY26-12112025-014637-B	<2
WS-014638	2/24/2025	2/24/2026	1	Combo Fountain	In room 125 pre-k	WF-02242025-014638	1/19/2026	FT-FY26-12112025-014638-A	<2	FT-FY26-12112025-014638-B	<2
WS-014640	9/15/2025	9/15/2026	1	Combo Faucet	In room 127 pre-k	WF-09152025-014640	1/19/2026	FT-FY26-12112025-014640-A	<2	FT-FY26-12112025-014640-B	<2
WS-014641	2/24/2025	2/24/2026	1	Combo Fountain	In room 127 pre-k	WF-02242025-014641	1/19/2026	FT-FY26-12112025-014641-A	<2	FT-FY26-12112025-014641-B	<2
WS-014642	9/15/2025	9/15/2026	1	Combo Faucet	In room 128 pre-k	WF-09152025-014642	1/19/2026	FT-FY26-12112025-014642-A	<2	FT-FY26-12112025-014642-B	<2
WS-014643	2/24/2025	2/24/2026	1	Combo Fountain	In room 128 pre-k	WF-02242025-014643	1/19/2026	FT-FY26-12112025-014643-A	<2	FT-FY26-12112025-014643-B	<2
WS-014645	2/24/2025	2/24/2026	2	Break Room	In room 209 pantry	WF-02242025-014645	1/19/2026	FT-FY26-12112025-014645-A	<2	FT-FY26-12112025-014645-B	<2
WS-014646	2/24/2025	2/24/2026	2	Bottle Filler	In hallway adjacent to 210A janitor	WF-02242025-014646	1/19/2026	FT-FY26-12112025-014646-A	<2	FT-FY26-12112025-014646-B	<2
WS-014647	2/24/2025	2/24/2026	2	Cooler	In hallway adjacent to 210A janitor High Left	WF-02242025-014647	1/19/2026	FT-FY26-12112025-014647-A	<2	FT-FY26-12112025-014647-B	<2
WS-014648	2/24/2025	2/24/2026	2	Cooler	In hallway adjacent to 210A janitor Low Right	WF-02242025-014648	1/19/2026	FT-FY26-12112025-014648-A	<2	FT-FY26-12112025-014648-B	<2
WS-014650	9/15/2025	9/15/2026	2	Combo Faucet	In room 211 kindergarten	WF-09152025-014650	1/19/2026	FT-FY26-12112025-014650-A	2.5	FT-FY26-12112025-014650-B	<2
WS-014651	2/24/2025	2/24/2026	2	Combo Fountain	In room 211 kindergarten	WF-02242025-014651	1/19/2026	FT-FY26-12112025-014651-A	<2	FT-FY26-12112025-014651-B	<2
WS-014652	12/1/2025	12/1/2026	2	Food Prep Sink	In room 214 discovery cave	WF-12012025-014652	1/19/2026	FT-FY26-12112025-014652-A	<2	FT-FY26-12112025-014652-B	<2
WS-014653	9/15/2025	9/15/2026	2	Combo Faucet	In room 216 kindergarten	WF-09152025-014653	1/19/2026	FT-FY26-12112025-014653-A	<2	FT-FY26-12112025-014653-B	<2
WS-014654	2/24/2025	2/24/2026	2	Combo Fountain	In room 216 kindergarten	WF-02242025-014654	1/19/2026	FT-FY26-12112025-014654-A	<2	FT-FY26-12112025-014654-B	<2
WS-014657	9/15/2025	9/15/2026	2	Combo Faucet	In room 213 kindergarten	WF-09152025-014657	1/19/2026	FT-FY26-12112025-014657-A	<2	FT-FY26-12112025-014657-B	<2
WS-014658	2/24/2025	2/24/2026	2	Combo Fountain	In room 213 kindergarten	WF-02242025-014658	1/19/2026	FT-FY26-12112025-014658-A	<2	FT-FY26-12112025-014658-B	<2
WS-014660	9/15/2025	9/15/2026	2	Combo Faucet	In room 215 kindergarten	WF-09152025-014660	1/19/2026	FT-FY26-12112025-014660-A	<2	FT-FY26-12112025-014660-B	<2

WS-014661	2/24/2025	2/24/2026	2	Combo Fountain	In room 215 kindergarten		WF-02242025-014661	1/19/2026	FT-FY26-12112025-014661-A	<2	FT-FY26-12112025-014661-B	<2
WS-014664	2/24/2025	2/24/2026	2	Combo Fountain	In room 217 first grade		WF-02242025-014664	1/19/2026	FT-FY26-12112025-014664-A	<2	FT-FY26-12112025-014664-B	<2
WS-014667	2/24/2025	2/24/2026	2	Combo Fountain	In room 218 first grade		WF-02242025-014667	1/19/2026	FT-FY26-12112025-014667-A	<2	FT-FY26-12112025-014667-B	<2
WS-014670	2/24/2025	2/24/2026	2	Combo Fountain	In room 219 first grade		WF-02242025-014670	1/19/2026	FT-FY26-12112025-014670-A	<2	FT-FY26-12112025-014670-B	<2
WS-014673	2/24/2025	2/24/2026	2	Combo Fountain	In room 222 first grade		WF-02242025-014673	1/19/2026	FT-FY26-12112025-014673-A	<2	FT-FY26-12112025-014673-B	<2
WS-014675	2/24/2025	2/24/2026	3	Combo Fountain	In room 308 maker space		WF-02242025-014675	1/19/2026	FT-FY26-12112025-014675-A	3.6	FT-FY26-12112025-014675-B	<2
WS-014677	2/24/2025	2/24/2026	3	Break Room	In room 313 pantry		WF-02242025-014677	1/19/2026	FT-FY26-12112025-014677-A	<2	FT-FY26-12112025-014677-B	<2
WS-014678	2/24/2025	2/24/2026	3	Bottle Filler	In hallway adjacent to 312A janitor		WF-02242025-014678	1/19/2026	FT-FY26-12112025-014678-A	<2	FT-FY26-12112025-014678-B	<2
WS-014679	2/24/2025	2/24/2026	3	Cooler	In hallway adjacent to 312A janitor	High Left	WF-02242025-014679	1/19/2026	FT-FY26-12112025-014679-A	<2	FT-FY26-12112025-014679-B	<2
WS-014680	2/24/2025	2/24/2026	3	Cooler	In hallway adjacent to 312A janitor	Low Right	WF-02242025-014680	1/19/2026	FT-FY26-12112025-014680-A	<2	FT-FY26-12112025-014680-B	<2
WS-014682	2/24/2025	2/24/2026	3	Combo Fountain	In room 319 fourth grade		WF-02242025-014682	1/19/2026	FT-FY26-12112025-014682-A	<2	FT-FY26-12112025-014682-B	<2
WS-014684	2/24/2025	2/24/2026	3	Combo Fountain	In room 318 fourth grade		WF-02242025-014684	1/19/2026	FT-FY26-12112025-014684-A	<2	FT-FY26-12112025-014684-B	<2
WS-014686	2/24/2025	2/24/2026	3	Combo Fountain	In room 320 fourth grade		WF-02242025-014686	1/19/2026	FT-FY26-12112025-014686-A	<2	FT-FY26-12112025-014686-B	<2
WS-014688	2/24/2025	2/24/2026	3	Combo Fountain	In room 323 fifth grade		WF-02242025-014688	1/19/2026	FT-FY26-12112025-014688-A	<2	FT-FY26-12112025-014688-B	<2
WS-014690	2/24/2025	2/24/2026	3	Combo Fountain	In room 324 fifth grade		WF-02242025-014690	1/19/2026	FT-FY26-12112025-014690-A	<2	FT-FY26-12112025-014690-B	<2
WS-014692	2/24/2025	2/24/2026	3	Combo Fountain	In room 326 fifth grade		WF-02242025-014692	1/19/2026	FT-FY26-12112025-014692-A	<2	FT-FY26-12112025-014692-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014615	12/1/2025	12/1/2026	1	Food Prep Sink	In kitchen sixth clockwise from entry	WF-12012025-014615	1/19/2026	FT-FY26-12112025-014615-A	<2	FT-FY26-12112025-014615-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.