



Maury Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014600	3/24/2021	3/24/2022	1	Health Suite	In room 102C treatment	WF-03242021-014600	3/28/2021	FT-FY21-032021-014600-A	<1	FT-FY21-032021-014600-B	<1
WS-014601	3/24/2021	3/24/2022	1	Break Room	In room 105D staff lounge	WF-03242021-014601	3/28/2021	FT-FY21-032021-014601-A	<1	FT-FY21-032021-014601-B	<1
WS-014602	3/24/2021	3/24/2022	1	Health Suite	In room 105A wellness room	WF-03242021-014602	3/28/2021	FT-FY21-032021-014602-A	<1	FT-FY21-032021-014602-B	<1
WS-014604	3/24/2021	3/24/2022	1	Combo Fountain	In room 137 art	WF-03242021-014604	3/28/2021	FT-FY21-032021-014604-A	1.1	FT-FY21-032021-014604-B	<1
WS-014616	3/24/2021	3/24/2022	1	Bottle Filler	In room 135 gymnasium adjacent to 139 restroom	WF-03242021-014616	3/28/2021	FT-FY21-032021-014616-A	<1	FT-FY21-032021-014616-B	<1
WS-014619	3/24/2021	3/24/2022	1	Bottle Filler	In room 133 atrium between restroom	WF-03242021-014619	3/28/2021	FT-FY21-032021-014619-A	<1	FT-FY21-032021-014619-B	<1
WS-014623	3/24/2021	3/24/2022	1	Break Room	In room 120 pantry	WF-03242021-014623	3/28/2021	FT-FY21-032021-014623-A	<1	FT-FY21-032021-014623-B	<1
WS-014625	3/24/2021	3/24/2022	1	Combo Fountain	In room 122 think tank	WF-03242021-014625	3/28/2021	FT-FY21-032021-014625-A	<1	FT-FY21-032021-014625-B	<1
WS-014628	10/20/2020	10/20/2021	1	Combo Faucet	In room 121 pre-k	WF-10202020-014628	3/28/2021	FT-FY21-032021-014628-A	<1	FT-FY21-032021-014628-B	<1
WS-014629	3/24/2021	3/24/2022	1	Combo Fountain	In room 121 pre-k	WF-03242021-014629	3/28/2021	FT-FY21-032021-014629-A	<1	FT-FY21-032021-014629-B	<1
WS-014631	3/24/2021	3/24/2022	1	Combo Fountain	In room 124 music	WF-03242021-014631	3/28/2021	FT-FY21-032021-014631-A	<1	FT-FY21-032021-014631-B	<1
WS-014632	10/20/2020	10/20/2021	1	Combo Faucet	In room 123 pre-k	WF-10202020-014632	3/28/2021	FT-FY21-032021-014632-A	<1	FT-FY21-032021-014632-B	<1
WS-014633	3/24/2021	3/24/2022	1	Combo Fountain	In room 123 pre-k	WF-03242021-014633	3/28/2021	FT-FY21-032021-014633-A	<1	FT-FY21-032021-014633-B	<1
WS-014637	10/20/2020	10/20/2021	1	Combo Faucet	In room 125 pre-k	WF-10202020-014637	3/28/2021	FT-FY21-032021-014637-A	<1	FT-FY21-032021-014637-B	<1
WS-014638	3/24/2021	3/24/2022	1	Combo Fountain	In room 125 pre-k	WF-03242021-014638	3/28/2021	FT-FY21-032021-014638-A	<1	FT-FY21-032021-014638-B	<1
WS-014640	10/20/2020	10/20/2021	1	Combo Faucet	In room 127 pre-k	WF-10202020-014640	3/28/2021	FT-FY21-032021-014640-A	<1	FT-FY21-032021-014640-B	<1
WS-014641	3/24/2021	3/24/2022	1	Combo Fountain	In room 127 pre-k	WF-03242021-014641	3/28/2021	FT-FY21-032021-014641-A	<1	FT-FY21-032021-014641-B	<1
WS-014642	10/20/2020	10/20/2021	1	Combo Faucet	In room 128 pre-k	WF-10202020-014642	3/28/2021	FT-FY21-032021-014642-A	<1	FT-FY21-032021-014642-B	<1
WS-014643	3/24/2021	3/24/2022	1	Combo Fountain	In room 128 pre-k	WF-03242021-014643	3/28/2021	FT-FY21-032021-014643-A	<1	FT-FY21-032021-014643-B	<1
WS-014645	3/24/2021	3/24/2022	2	Break Room	In room 209 pantry	WF-03242021-014645	3/28/2021	FT-FY21-032021-014645-A	<1	FT-FY21-032021-014645-B	<1
WS-014646	3/24/2021	3/24/2022	2	Bottle Filler	In hallway adjacent to 210A janitor	WF-03242021-014646	3/28/2021	FT-FY21-032021-014646-A	<1	FT-FY21-032021-014646-B	<1
WS-014650	10/20/2020	10/20/2021	2	Combo Faucet	In room 211 kindergarten	WF-10202020-014650	3/28/2021	FT-FY21-032021-014650-A	<1	FT-FY21-032021-014650-B	<1
WS-014651	3/24/2021	3/24/2022	2	Combo Fountain	In room 211 kindergarten	WF-03242021-014651	3/28/2021	FT-FY21-032021-014651-A	<1	FT-FY21-032021-014651-B	<1
WS-014652	2/15/2021	2/15/2022	2	Food Prep Sink	In room 214 discovery cave	WF-02152021-014652	3/28/2021	FT-FY21-032021-014652-A	<1	FT-FY21-032021-014652-B	<1
WS-014653	10/20/2020	10/20/2021	2	Combo Faucet	In room 216 kindergarten	WF-10202020-014653	3/28/2021	FT-FY21-032021-014653-A	<1	FT-FY21-032021-014653-B	<1
WS-014654	3/24/2021	3/24/2022	2	Combo Fountain	In room 216 kindergarten	WF-03242021-014654	3/28/2021	FT-FY21-032021-014654-A	<1	FT-FY21-032021-014654-B	<1
WS-014657	10/20/2020	10/20/2021	2	Combo Faucet	In room 213 kindergarten	WF-10202020-014657	3/28/2021	FT-FY21-032021-014657-A	<1	FT-FY21-032021-014657-B	<1
WS-014658	3/24/2021	3/24/2022	2	Combo Fountain	In room 213 kindergarten	WF-03242021-014658	3/28/2021	FT-FY21-032021-014658-A	<1	FT-FY21-032021-014658-B	<1
WS-014660	10/20/2020	10/20/2021	2	Combo Faucet	In room 215 kindergarten	WF-10202020-014660	3/28/2021	FT-FY21-032021-014660-A	<1	FT-FY21-032021-014660-B	<1
WS-014661	3/24/2021	3/24/2022	2	Combo Fountain	In room 215 kindergarten	WF-03242021-014661	3/28/2021	FT-FY21-032021-014661-A	<1	FT-FY21-032021-014661-B	<1
WS-014664	3/24/2021	3/24/2022	2	Combo Fountain	In room 217 first grade	WF-03242021-014664	3/28/2021	FT-FY21-032021-014664-A	<1	FT-FY21-032021-014664-B	<1
WS-014667	3/24/2021	3/24/2022	2	Combo Fountain	In room 218 first grade	WF-03242021-014667	3/28/2021	FT-FY21-032021-014667-A	<1	FT-FY21-032021-014667-B	<1
WS-014670	3/24/2021	3/24/2022	2	Combo Fountain	In room 219 first grade	WF-03242021-014670	3/28/2021	FT-FY21-032021-014670-A	<1	FT-FY21-032021-014670-B	<1
WS-014673	3/24/2021	3/24/2022	2	Combo Fountain	In room 222 first grade	WF-03242021-014673	3/28/2021	FT-FY21-032021-014673-A	<1	FT-FY21-032021-014673-B	<1
WS-014675	3/24/2021	3/24/2022	3	Combo Fountain	In room 308 maker space	WF-03242021-014675	3/28/2021	FT-FY21-032021-014675-A	<1	FT-FY21-032021-014675-B	<1

WS-014677	3/24/2021	3/24/2022	3	Break Room	In room 313 pantry	WF-03242021-014677	3/28/2021	FT-FY21-032021-014677-A	<1	FT-FY21-032021-014677-B	<1
WS-014678	3/24/2021	3/24/2022	3	Bottle Filler	In hallway adjacent to 312A janitor	WF-03242021-014678	3/28/2021	FT-FY21-032021-014678-A	<1	FT-FY21-032021-014678-B	<1
WS-014682	3/24/2021	3/24/2022	3	Combo Fountain	In room 319 fourth grade	WF-03242021-014682	3/28/2021	FT-FY21-032021-014682-A	<1	FT-FY21-032021-014682-B	<1
WS-014684	3/24/2021	3/24/2022	3	Combo Fountain	In room 318 fourth grade	WF-03242021-014684	3/28/2021	FT-FY21-032021-014684-A	<1	FT-FY21-032021-014684-B	<1
WS-014686	3/24/2021	3/24/2022	3	Combo Fountain	In room 320 fourth grade	WF-03242021-014686	3/28/2021	FT-FY21-032021-014686-A	<1	FT-FY21-032021-014686-B	<1
WS-014688	3/24/2021	3/24/2022	3	Combo Fountain	In room 323 fifth grade	WF-03242021-014688	3/28/2021	FT-FY21-032021-014688-A	<1	FT-FY21-032021-014688-B	<1
WS-014690	3/24/2021	3/24/2022	3	Combo Fountain	In room 324 fifth grade	WF-03242021-014690	3/28/2021	FT-FY21-032021-014690-A	<1	FT-FY21-032021-014690-B	<1
WS-014692	3/24/2021	3/24/2022	3	Combo Fountain	In room 326 fifth grade	WF-03242021-014692	3/28/2021	FT-FY21-032021-014692-A	<1	FT-FY21-032021-014692-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014615	2/15/2021	2/15/2022	1	Food Prep Sink	In kitchen sixth clockwise from entry	WF-02152021-014615	3/28/2021	FT-FY21-032021-014615-A	<1	FT-FY21-032021-014615-B	<1