



MAURY ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MAURY ELEMENTARY SCHOOL	WS- 008471	8/17/2016	Basement	Fountain	In classroom W030	Right	FT-82016-008471-A	< 1	FT-82016-008471-B	< 1
2	MAURY ELEMENTARY SCHOOL	WS- 008472	8/17/2016	Basement	Cooler	In hallway adjacent to room W022	Low Right	FT-82016-008472-A	< 1	FT-82016-008472-B	< 1
3	MAURY ELEMENTARY SCHOOL	WS- 008473	8/17/2016	Basement	Cooler	In hallway adjacent to room W022	High Left	FT-82016-008473-A	< 1	FT-82016-008473-B	< 1
4	MAURY ELEMENTARY SCHOOL	WS- 008475	8/17/2016	Basement	Fountain	In classroom W010	Right	FT-82016-008475-A	< 1	FT-82016-008475-B	< 1
5	MAURY ELEMENTARY SCHOOL	WS- 008476	8/17/2016	1	Health Suite	In health suite E143		FT-82016-008476-A	< 1	FT-82016-008476-B	< 1
6	MAURY ELEMENTARY SCHOOL	WS- 008477	8/17/2016	1	Classroom Faucet	In classroom E 135	Left	FT-82016-008477-A	< 1	FT-82016-008477-B	< 1
7	MAURY ELEMENTARY SCHOOL	WS- 008478	8/17/2016	1	Fountain	In classroom E 135	Right	FT-82016-008478-A	< 1	FT-82016-008478-B	< 1
8	MAURY ELEMENTARY SCHOOL	WS- 008479	8/17/2016	1	Fountain	In classroom E140	Right	FT-82016-008479-A	< 1	FT-82016-008479-B	< 1
9	MAURY ELEMENTARY SCHOOL	WS- 008480	8/17/2016	1	Classroom Faucet	In classroom E140	Left	FT-82016-008480-A	< 1	FT-82016-008480-B	< 1
10	MAURY ELEMENTARY SCHOOL	WS- 008482	8/17/2016	1	Fountain	In classroom E125	Right	FT-82016-008482-A	< 1	FT-82016-008482-B	< 1
11	MAURY ELEMENTARY SCHOOL	WS- 008485	8/17/2016	1	Cooler	In hallway adjacent to room E121		FT-82016-008485-A	< 1	FT-82016-008485-B	< 1
12	MAURY ELEMENTARY SCHOOL	WS- 008486	8/17/2016	1	Cooler	In classroom E110		FT-82016-008486-A	< 1	FT-82016-008486-B	< 1
13	MAURY ELEMENTARY SCHOOL	WS- 008487	8/17/2016	1	Food Prep Sink	In kitchen	Low	FT-82016-008487-A	< 1	FT-82016-008487-B	< 1
14	MAURY ELEMENTARY SCHOOL	WS- 008489	8/17/2016	1	Cooler	In hallway adjacent to stairwell 3		FT-82016-008489-A	< 1	FT-82016-008489-B	< 1
15	MAURY ELEMENTARY SCHOOL	WS- 008490	8/17/2016	2	Cooler	In hallway adjacent to stairwell 4		FT-82016-008490-A	< 1	FT-82016-008490-B	< 1
16	MAURY ELEMENTARY SCHOOL	WS- 008491	8/17/2016	2	Cooler	In hallway adjacent to room E220		FT-82016-008491-A	< 1	FT-82016-008491-B	< 1
17	MAURY ELEMENTARY SCHOOL	WS- 008494	8/17/2016	2	Fountain	In classroom E230	Right	FT-82016-008494-A	< 1	FT-82016-008494-B	< 1
18	MAURY ELEMENTARY SCHOOL	WS- 008499	8/17/2016	2	Fountain	In classroom E240	Right	FT-82016-008499-A	< 1	FT-82016-008499-B	< 1