



Maury ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008472	6/10/2017	6/10/2018	Basement	Cooler	In hallway adjacent to room W022	Right	Low	WF-62017-008472	11/21/2017	FT-FY18--62017-008472-A	<1	FT-FY18--62017-008472-B	<1
WS- 008473	6/10/2017	6/10/2018	Basement	Cooler	In hallway adjacent to room W022	Left	High	WF-62017-008473	11/21/2017	FT-FY18--62017-008473-A	<1	FT-FY18--62017-008473-B	<1
WS- 008475	6/10/2017	6/10/2018	Basement	Combo Fountain	In classroom W010	Right		WF-62017-008475	11/21/2017	FT-FY18--62017-008475-A	<1	FT-FY18--62017-008475-B	<1
WS- 008477	11/7/2017	11/7/2018	1	Combo Faucet	In classroom E 135	Left		WF-112017-008477	11/21/2017	FT-FY18-112017-008477-A	2	FT-FY18-112017-008477-B	<1
WS- 008481	6/10/2017	6/10/2018	1	Break Room	In work room E134	Left		WF-62017-008481	11/21/2017	FT-FY18--62017-008481-A	<1	FT-FY18--62017-008481-B	<1
WS- 008483	11/7/2017	11/7/2018	1	Combo Faucet	In classroom E125	Left		WF-112017-008483	11/21/2017	FT-FY18-112017-008483-A	<1	FT-FY18-112017-008483-B	<1
WS- 008490	6/10/2017	6/10/2018	2	Cooler	In hallway adjacent to stairwell 4			WF-62017-008490	11/21/2017	FT-FY18--62017-008490-A	<1	FT-FY18--62017-008490-B	<1
WS- 008496	6/10/2017	6/10/2018	2	Break Room	In break room E235	Left		WF-62017-008496	11/21/2017	FT-FY18--62017-008496-A	<1	FT-FY18--62017-008496-B	<1
WS- 008499	6/10/2017	6/10/2018	2	Combo Fountain	In classroom E240	Right		WF-62017-008499	11/21/2017	FT-FY18--62017-008499-A	<1	FT-FY18--62017-008499-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008487	1	Food Prep Sink	In kitchen			Low	11/21/2017	FT-FY18-102017-008487-A	<1	FT-FY18-102017-008487-B	<1