



MCKINLEY LEAD WATER TEST RESULTS

May 24th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010455	Classroom	1	In classroom 108 south wall	WT-042916-10472- A	1.6	WT-042916-10472- B	< 1				
2	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010456	Classroom	1	In classroom 108 west wall first from left	WT-042916-10473- A	< 1	WT-042916-10473- B	< 1				
3	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010457	Classroom	1	In classroom 108 west wall second from left	WT-042916-10474- A	< 1	WT-042916-10474- B	< 1				
4	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010458	Classroom	1	In classroom 108 west wall third from left	WT-042916-10475- A	< 1	WT-042916-10475- B	< 1				
5	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010459	Classroom	1	In classroom 108 west wall last from left	WT-042916-10476- A	< 1	WT-042916-10476- B	< 1				
6	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010460	Classroom	1	In classroom 108 north wall	WT-042916-10477- A	1	WT-042916-10477- B	< 1				
7	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010461	Classroom	1	In room 110A2	WT-042916-10478- A	< 1	WT-042916-10478- B	< 1				
8	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010462	Classroom	1	In classroom 110 south wall Left	WT-042916-10479- A	1.2	WT-042916-10479- B	< 1				
9	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010463	Classroom	1	In classroom 110 south wall Right	WT-042916-10480- A	1.3	WT-042916-10480- B	< 1				
10	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010464	Classroom	1	In classroom 110 west wall Left	WT-042916-10481- A	4.8	WT-042916-10481- B	< 1				
11	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010465	Classroom	1	In classroom 110 west wall Mid	WT-042916-10482- A	4.1	WT-042916-10482- B	< 1				
12	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010466	Classroom	1	In classroom 110 west wall Right	WT-042916-10483- A	2.8	WT-042916-10483- B	< 1				
13	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010467	Classroom	1	In classroom 110 north wall	WT-042916-10484- A	2.4	WT-042916-10484- B	< 1				
14	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010468	Cooler	1	In hallway across from 115F	WT-042916-10485- A	< 1	WT-042916-10485- B	< 1				
15	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010469	Cooler	1	In hallway across from 115F Right High	WT-042916-10486- A	< 1	WT-042916-10486- B	< 1				
16	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010470	Cooler	1	In gym adjacent to 114C Left High	WT-042916-10487- A	< 1	WT-042916-10487- B	< 1				
17	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010471	Cooler	1	In gym adjacent to 114C Right Low	WT-042916-10488- A	< 1	WT-042916-10488- B	< 1				
18	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010472	Cooler	1	In gym adjacent to 114F Left Low	WT-042916-10489- A	< 1	WT-042916-10489- B	< 1				
19	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010473	Cooler	1	In gym adjacent to 114F Left High	WT-042916-10490- A	< 1	WT-042916-10490- B	< 1				
20	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010474	Health Suite	1	In health suite treatment room 117D Left	WT-042916-10491- A	3.2	WT-042916-10491- B	< 1				
21	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010475	Fountain	1	In health suite treatment room 117D	WT-042916-10492- A	2.5	WT-042916-10492- B	< 1				
22	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010476	Cooler	2	In hallway adjacent to room 202 Left Low	WT-042916-10493- A	< 1	WT-042916-10493- B	< 1				
23	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010477	Cooler	2	In hallway adjacent to room 202 Right High	WT-042916-10494- A	< 1	WT-042916-10494- B	< 1				
24	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010478	Classroom	2	In classroom 206 south wall	WT-042916-10495- A	3.2	WT-042916-10495- B	1				
25	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010479	Classroom	2	In classroom 206 west wall Mid	WT-042916-10496- A	4	WT-042916-10496- B	3.5				
26	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010480	Classroom	2	In classroom 206 west wall Mid	WT-042916-10497- A	5.3	WT-042916-10497- B	1.4				
27	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010481	Classroom	2	In classroom 206 west wall Right	WT-042916-10498- A	5	WT-042916-10498- B	1.1				
28	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010482	Classroom	2	In classroom 206 north wall Left	WT-042916-10499- A	5.6	WT-042916-10499- B	< 1				
29	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010483	Classroom	2	In classroom 206 north wall Right	WT-042916-10500- A	7.1	WT-042916-10500- B	< 1				
30	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010484	Classroom	2	In room 206 A	WT-042916-10501- A	< 1	WT-042916-10501- B	< 1				
31	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010485	Classroom	2	In classroom 213B	WT-042916-10502- A	< 1	WT-042916-10502- B	< 1				
32	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010486	Classroom	2	In staff lounge	WT-042916-10503- A	< 1	WT-042916-10503- B	< 1				
33	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010488	Cooler	3	In hallway adjacent to room 302 Left Low	WT-042916-10505- A	< 1	WT-042916-10505- B	< 1				
34	MCKINLEY MIDDLE SCHOOL	5/14/2016	WS-010489	Cooler	3	In hallway adjacent to room 302 Right High	WT-042916-10506- A	< 1	WT-042916-10506- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.