



McKinley Middle School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010468	4/3/2024	4/3/2025	1	Cooler	In hallway across from room 115F Low Left	WF-04032024-010468	12/10/2024	FT-FY25-11082024-010468-A	<2	FT-FY25-11082024-010468-B	<2
WS- 010469	4/3/2024	4/3/2025	1	Cooler	In hallway across from room 115F High Right	WF-04032024-010469	12/10/2024	FT-FY25-11082024-010469-A	<2	FT-FY25-11082024-010469-B	<2
WS- 010470	4/3/2024	4/3/2025	1	Cooler	In gym adjacent to room 114 High Left	WF-04032024-010470	12/10/2024	FT-FY25-11082024-010470-A	<2	FT-FY25-11082024-010470-B	<2
WS- 010472	4/3/2024	4/3/2025	1	Cooler	In gym adjacent to room 114F Low Left	WF-04032024-010472	12/10/2024	FT-FY25-11082024-010472-A	<2	FT-FY25-11082024-010472-B	<2
WS- 010473	4/3/2024	4/3/2025	1	Cooler	In gym adjacent to room 114F High Right	WF-04032024-010473	12/10/2024	FT-FY25-11082024-010473-A	<2	FT-FY25-11082024-010473-B	<2
WS- 010474	4/3/2024	4/3/2025	1	Health Suite	In health suite in treatment room 117D	WF-04032024-010474	12/10/2024	FT-FY25-11082024-010474-A	2.7	FT-FY25-11082024-010474-B	<2
WS- 010475	4/3/2024	4/3/2025	1	Combo Fountain	In treatment room 117D in health suite	WF-04032024-010475	12/10/2024	FT-FY25-11082024-010475-A	<2	FT-FY25-11082024-010475-B	<2
WS- 010476	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to room 202 Low Left	WF-04032024-010476	12/10/2024	FT-FY25-11082024-010476-A	2.4	FT-FY25-11082024-010476-B	<2
WS- 010477	4/3/2024	4/3/2025	2	Cooler	In hallway adjacent to room 202 High Right	WF-04032024-010477	12/10/2024	FT-FY25-11082024-010477-A	2.3	FT-FY25-11082024-010477-B	<2
WS- 010486	4/3/2024	4/3/2025	2	Break Room	In staff lounge	WF-04032024-010486	12/10/2024	FT-FY25-11082024-010486-A	3.7	FT-FY25-11082024-010486-B	3.2
WS- 010488	4/3/2024	4/3/2025	3	Cooler	In hallway adjacent to room 302 Low Left	WF-04032024-010488	12/10/2024	FT-FY25-11082024-010488-A	4.0	FT-FY25-11082024-010488-B	<2
WS- 010489	4/3/2024	4/3/2025	3	Cooler	In hallway adjacent to room 302 High Right	WF-04032024-010489	12/10/2024	FT-FY25-11082024-010489-A	<2	FT-FY25-11082024-010489-B	<2
WS- 010548	4/3/2024	4/3/2025	1	Bottle Filler	In hallway across from room 115F	WF-04032024-010548	12/10/2024	FT-FY25-11082024-010548-A	<2	FT-FY25-11082024-010548-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.