



McKinley MS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010468	6/3/2019	6/3/2020	1	Cooler	In hallway across from room 115F Low Left	WF-06032019-010468	1/13/2020	FT-FY20-122019-010468-A	<1	FT-FY20-122019-010468-B	<1
WS- 010469	6/3/2019	6/3/2020	1	Cooler	In hallway across from room 115F High Right	WF-06032019-010469	1/13/2020	FT-FY20-122019-010469-A	<1	FT-FY20-122019-010469-B	<1
WS- 010470	6/3/2019	6/3/2020	1	Cooler	In gym adjacent to room 114C High Left	WF-06032019-010470	1/13/2020	FT-FY20-122019-010470-A	<1	FT-FY20-122019-010470-B	<1
WS- 010471	6/3/2019	6/3/2020	1	Cooler	In gym adjacent to room 114C Low Right	WF-06032019-010471	1/13/2020	FT-FY20-122019-010471-A	<1	FT-FY20-122019-010471-B	<1
WS- 010472	6/3/2019	6/3/2020	1	Cooler	In gym adjacent to room 114F Low Left	WF-06032019-010472	1/13/2020	FT-FY20-122019-010472-A	<1	FT-FY20-122019-010472-B	<1
WS- 010473	6/3/2019	6/3/2020	1	Cooler	In gym adjacent to room 114F High Right	WF-06032019-010473	1/13/2020	FT-FY20-122019-010473-A	<1	FT-FY20-122019-010473-B	<1
WS- 010474	6/3/2019	6/3/2020	1	Health Suite	In health suite in treatment room 117D	WF-06032019-010474	1/13/2020	FT-FY20-122019-010474-A	<1	FT-FY20-122019-010474-B	<1
WS- 010475	6/3/2019	6/3/2020	1	Combo Fountain	In treatment room 117D in health suite	WF-06032019-010475	1/13/2020	FT-FY20-122019-010475-A	<1	FT-FY20-122019-010475-B	<1
WS- 010477	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to room 202 High Right	WF-06032019-010477	1/13/2020	FT-FY20-122019-010477-A	<1	FT-FY20-122019-010477-B	<1
WS- 010486	6/3/2019	6/3/2020	2	Break Room	In staff lounge	WF-06032019-010486	1/13/2020	FT-FY20-122019-010486-A	<1	FT-FY20-122019-010486-B	<1
WS- 010488	6/3/2019	6/3/2020	3	Cooler	In hallway adjacent to room 302 Low Left	WF-06032019-010488	1/13/2020	FT-FY20-122019-010488-A	<1	FT-FY20-122019-010488-B	<1
WS- 010489	6/3/2019	6/3/2020	3	Cooler	In hallway adjacent to room 302 High Right	WF-06032019-010489	1/13/2020	FT-FY20-122019-010489-A	<1	FT-FY20-122019-010489-B	<1