



McKinley MS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010468	6/11/2018	6/11/2019	1	Cooler	In hallway across from room 115F Low Left	WF-06112018-010468	12/27/2018	FT-FY19-122018-010468-A	<1	FT-FY19-122018-010468-B	<1
WS-010469	6/11/2018	6/11/2019	1	Cooler	In hallway across from room 115F High Right	WF-06112018-010469	12/27/2018	FT-FY19-122018-010469-A	<1	FT-FY19-122018-010469-B	<1
WS-010470	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room 114C High Left	WF-06112018-010470	12/27/2018	FT-FY19-122018-010470-A	<1	FT-FY19-122018-010470-B	<1
WS-010471	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room 114C Low Right	WF-06112018-010471	12/27/2018	FT-FY19-122018-010471-A	<1	FT-FY19-122018-010471-B	<1
WS-010472	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room 114F Low Left	WF-06112018-010472	12/27/2018	FT-FY19-122018-010472-A	<1	FT-FY19-122018-010472-B	<1
WS-010473	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room 114F High Right	WF-06112018-010473	12/27/2018	FT-FY19-122018-010473-A	<1	FT-FY19-122018-010473-B	<1
WS-010474	6/11/2018	6/11/2019	1	Health Suite	In health suite in treatment room 117D	WF-06112018-010474	12/27/2018	FT-FY19-122018-010474-A	<1	FT-FY19-122018-010474-B	<1
WS-010475	6/11/2018	6/11/2019	1	Combo Fountain	In treatment room 117D in health suite	WF-06112018-010475	12/27/2018	FT-FY19-122018-010475-A	<1	FT-FY19-122018-010475-B	<1
WS-010476	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to room 202 Low Left	WF-06112018-010476	12/27/2018	FT-FY19-122018-010476-A	<1	FT-FY19-122018-010476-B	<1
WS-010477	6/11/2018	6/11/2019	2	Cooler	In hallway adjacent to room 202 High Right	WF-06112018-010477	12/27/2018	FT-FY19-122018-010477-A	<1	FT-FY19-122018-010477-B	<1
WS-010486	6/11/2018	6/11/2019	2	Break Room	In staff lounge	WF-06112018-010486	12/27/2018	FT-FY19-122018-010486-A	<1	FT-FY19-122018-010486-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011820	Basement	Food Prep Sink	In kitchen east wall Left	12/27/2018	FT-FY19-122018-011820-A	<1	FT-FY19-122018-011820-B	<1