



# McKINLEY TECH HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 002590	8/19/2016	Ground Floor	Cooler	In girls' locker room adjacent to room G-119	FT-82016-002590-A	< 1	FT-82016-002590-B	< 1
2	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 002591	8/19/2016	Ground Floor	Cooler	In boy's' locker room adjacent to room G-124	FT-82016-002591-A	< 1	FT-82016-002591-B	< 1
3	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 010490	8/19/2016	3	Cooler	In hallway adjacent to room 365	FT-82016-010490-A	< 1	FT-82016-010490-B	< 1
4	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 010491	8/19/2016	3	Cooler	In hallway across from room 368	FT-82016-010491-A	< 1	FT-82016-010491-B	< 1
5	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011747	8/19/2016	2	Cooler	In hallway across from boys' restroom	FT-82016-011747-A	< 1	FT-82016-011747-B	< 1
6	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011748	8/19/2016	2	Cooler	In hallway across from girl's restroom	FT-82016-011748-A	< 1	FT-82016-011748-B	< 1
7	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011800	8/19/2016	1	Health Suite	In health suite 156C	FT-82016-011800-A	< 1	FT-82016-011800-B	< 1
8	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011801	8/19/2016	1	Health Suite	In health suite 156B	FT-82016-011801-A	< 1	FT-82016-011801-B	< 1
9	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011802	8/19/2016	1	Health Suite	In health suite 156E	FT-82016-011802-A	< 1	FT-82016-011802-B	< 1
10	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011803	8/19/2016	1	Cooler	In hallway adjacent to restroom 163T	FT-82016-011803-A	< 1	FT-82016-011803-B	< 1
11	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011808	8/19/2016	1	Cooler	In gym adjacent to room G212	FT-82016-011808-A	< 1	FT-82016-011808-B	< 1
12	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011809	8/19/2016	1	Cooler	In gym adjacent to room G212	FT-82016-011809-A	< 1	FT-82016-011809-B	< 1
13	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011810	8/19/2016	Basement	Cooler	In gym adjacent to room G115	FT-82016-011810-A	< 1	FT-82016-011810-B	< 1
14	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011811	8/19/2016	Basement	Cooler	In gym adjacent to room G115	FT-82016-011811-A	< 1	FT-82016-011811-B	< 1
15	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011812	8/19/2016	Basement	Cooler	In hallway adjacent to room G102T	FT-82016-011812-A	< 1	FT-82016-011812-B	< 1
16	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011813	8/19/2016	Basement	Cooler	In hallway adjacent to room G102T	FT-82016-011813-A	< 1	FT-82016-011813-B	< 1
17	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011820	8/19/2016	Basement	Food Prep Sink	In kitchen east wall	FT-82016-011820-A	< 1	FT-82016-011820-B	< 1
18	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011822	8/19/2016	Basement	Ice Maker	In kitchen (ice maker)	FT-82016-011822-A	< 1	FT-82016-011822-B	< 1
19	MCKINLEY TECHNOLOGY HIGH SCHOOL	WS- 011825	8/19/2016	1	Cooler	In hallway adjacent to room 161T	FT-82016-011825-A	< 1	FT-82016-011825-B	< 1