



McKinley Tech High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002591	4/18/2022	4/18/2023	Basement	Cooler	In boy's' locker room adjacent to room G-124	WF-04182022-002591	2/2/2023	FT-FY23-01102023-002591-A	<1	FT-FY23-01102023-002591-B	<1	
WS- 010490	4/18/2022	4/18/2023	3	Cooler	In hallway adjacent to room 365	WF-04182022-010490	2/2/2023	FT-FY23-01102023-010490-A	<1	FT-FY23-01102023-010490-B	<1	
WS- 010491	4/18/2022	4/18/2023	3	Cooler	In hallway across from room 368	WF-04182022-010491	2/2/2023	FT-FY23-01102023-010491-A	<1	FT-FY23-01102023-010491-B	<1	
WS- 011747	4/18/2022	4/18/2023	2	Cooler	In hallway across from boys' restroom	WF-04182022-011747	2/2/2023	FT-FY23-01102023-011747-A	<1	FT-FY23-01102023-011747-B	<1	
WS- 011748	4/18/2022	4/18/2023	2	Cooler	In hallway across from girl's restroom	WF-04182022-011748	2/2/2023	FT-FY23-01102023-011748-A	<1	FT-FY23-01102023-011748-B	<1	
WS- 011800	4/18/2022	4/18/2023	1	Health Suite	In health suite 156B	WF-04182022-011800	2/2/2023	FT-FY23-01102023-011800-A	<1	FT-FY23-01102023-011800-B	<1	
WS- 011801	4/18/2022	4/18/2023	1	Health Suite	In health suite 156D	WF-04182022-011801	2/2/2023	FT-FY23-01102023-011801-A	<1	FT-FY23-01102023-011801-B	<1	
WS- 011802	4/18/2022	4/18/2023	1	Health Suite	In health suite 156E	WF-04182022-011802	2/2/2023	FT-FY23-01102023-011802-A	<1	FT-FY23-01102023-011802-B	<1	
WS- 011803	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to restroom 163T	WF-04182022-011803	2/2/2023	FT-FY23-01102023-011803-A	<1	FT-FY23-01102023-011803-B	<1	
WS- 011808	11/30/2022	11/30/2023	1	Cooler	In gym adjacent to room G212	Low Left	WF-11302022-011808	2/2/2023	FT-FY23-01102023-011808-A	<1	FT-FY23-01102023-011808-B	<1
WS- 011809	11/30/2022	11/30/2023	1	Cooler	In gym adjacent to room G212	High Right	WF-11302022-011809	2/2/2023	FT-FY23-01102023-011809-A	<1	FT-FY23-01102023-011809-B	<1
WS- 011810	4/18/2022	4/18/2023	Basement	Cooler	In gym adjacent to room G115	Low Left	WF-04182022-011810	2/2/2023	FT-FY23-01102023-011810-A	<1	FT-FY23-01102023-011810-B	<1
WS- 011811	4/18/2022	4/18/2023	Basement	Cooler	In gym adjacent to room G115	High Right	WF-04182022-011811	2/2/2023	FT-FY23-01102023-011811-A	<1	FT-FY23-01102023-011811-B	<1
WS- 011812	4/18/2022	4/18/2023	Basement	Cooler	In hallway adjacent to room G102T	Low Left	WF-04182022-011812	2/2/2023	FT-FY23-01102023-011812-A	<1	FT-FY23-01102023-011812-B	<1
WS- 011822	4/18/2022	4/18/2023	Basement	Ice Maker	In kitchen (ice maker)		WF-04182022-011822	2/2/2023	FT-FY23-01102023-011822-A	<1	FT-FY23-01102023-011822-B	<1
WS- 011825	4/18/2022	4/18/2023	1	Cooler	In hallway adjacent to room 161T		WF-04182022-011825	2/2/2023	FT-FY23-01102023-011825-A	<1	FT-FY23-01102023-011825-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011820	1/11/2023	1/11/2024	Basement	Food Prep Sink	In kitchen east wall	Left	WF-01112023-011820	2/2/2023	FT-FY23-01112023-011820-A	<1	FT-FY23-01112023-011820-B	<1