



McKinley Tech HS Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-017049	4/1/2025	4/1/2026	2	Bottle Filler	In hallway adjacent to boys restroom	WF-04012025-017049	12/15/2025	FT-FY26-12082025-017049-A	<2	FT-FY26-12082025-017049-B	<2	
WS-017050	4/1/2025	4/1/2026	2	Bottle Filler	In hallway adjacent to girls restroom	WF-04012025-017050	12/15/2025	FT-FY26-12082025-017050-A	<2	FT-FY26-12082025-017050-B	<2	
WS-002591	4/1/2025	4/1/2026	Basement	Cooler	In boy's locker room adjacent to room G-124	WF-04012025-002591	12/15/2025	FT-FY26-12082025-002591-A	<2	FT-FY26-12082025-002591-B	<2	
WS-010490	4/1/2025	4/1/2026	3	Cooler	In hallway adjacent to room 366	WF-04012025-010490	12/15/2025	FT-FY26-12082025-010490-A	<2	FT-FY26-12082025-010490-B	<2	
WS-010491	4/1/2025	4/1/2026	3	Cooler	In hallway across from room 368	WF-04012025-010491	12/15/2025	FT-FY26-12082025-010491-A	<2	FT-FY26-12082025-010491-B	<2	
WS-011524	4/1/2025	4/1/2026	1	Bottle Filler	In hallway adjacent to boys restroom	WF-04012025-011524	12/15/2025	FT-FY26-12082025-011524-A	<2	FT-FY26-12082025-011524-B	<2	
WS-011747	4/1/2025	4/1/2026	2	Cooler	In hallway adjacent to boys restroom	WF-04012025-011747	12/15/2025	FT-FY26-12082025-011747-A	<2	FT-FY26-12082025-011747-B	<2	
WS-011748	4/1/2025	4/1/2026	2	Cooler	In hallway adjacent to girls restroom	WF-04012025-011748	12/15/2025	FT-FY26-12082025-011748-A	<2	FT-FY26-12082025-011748-B	<2	
WS-011800	4/1/2025	4/1/2026	1	Health Suite	In health suite 156B	WF-04012025-011800	12/15/2025	FT-FY26-12082025-011800-A	<2	FT-FY26-12082025-011800-B	<2	
WS-011802	4/1/2025	4/1/2026	1	Health Suite	In health suite 156E	WF-04012025-011802	12/15/2025	FT-FY26-12082025-011802-A	<2	FT-FY26-12082025-011802-B	<2	
WS-011803	4/1/2025	4/1/2026	1	Cooler	In hallway adjacent to boys restroom	WF-04012025-011803	12/15/2025	FT-FY26-12082025-011803-A	<2	FT-FY26-12082025-011803-B	<2	
WS-011808	4/1/2025	4/1/2026	1	Cooler	In gym adjacent to room G212	Low Left	WF-04012025-011808	12/15/2025	FT-FY26-12082025-011808-A	<2	FT-FY26-12082025-011808-B	<2
WS-011809	4/1/2025	4/1/2026	1	Cooler	In gym adjacent to room G212	High Right	WF-04012025-011809	12/15/2025	FT-FY26-12082025-011809-A	<2	FT-FY26-12082025-011809-B	<2
WS-011810	4/1/2025	4/1/2026	Basement	Cooler	In gym adjacent to room G115	Low Left	WF-04012025-011810	12/15/2025	FT-FY26-12082025-011810-A	<2	FT-FY26-12082025-011810-B	<2
WS-011811	4/1/2025	4/1/2026	Basement	Cooler	In gym adjacent to room G115	High Right	WF-04012025-011811	12/15/2025	FT-FY26-12082025-011811-A	<2	FT-FY26-12082025-011811-B	<2
WS-011812	4/1/2025	4/1/2026	Basement	Cooler	In hallway adjacent to room G102T	Low Left	WF-04012025-011812	12/15/2025	FT-FY26-12082025-011812-A	<2	FT-FY26-12082025-011812-B	<2
WS-011813	4/1/2025	4/1/2026	Basement	Cooler	In hallway adjacent to room G102T	High Right	WF-04012025-011813	12/15/2025	FT-FY26-12082025-011813-A	<2	FT-FY26-12082025-011813-B	<2
WS-011822	4/1/2025	4/1/2026	Basement	Ice Maker	In kitchen (ice maker)	WF-04012025-011822	12/15/2025	FT-FY26-12082025-011822-A	<2	FT-FY26-12082025-011822-B	<2	
WS-011825	4/1/2025	4/1/2026	1	Cooler	In hallway adjacent to girls restroom	WF-04012025-011825	12/15/2025	FT-FY26-12082025-011825-A	<2	FT-FY26-12082025-011825-B	<2	
WS-012579	4/1/2025	4/1/2026	1	Bottle Filler	In gym adjacent to room G212	WF-04012025-012579	12/15/2025	FT-FY26-12082025-012579-A	<2	FT-FY26-12082025-012579-B	<2	
WS-012581	4/1/2025	4/1/2026	3	Bottle Filler	In hallway adjacent to room 366	WF-04012025-012581	12/15/2025	FT-FY26-12082025-012581-A	<2	FT-FY26-12082025-012581-B	<2	
WS-012582	4/1/2025	4/1/2026	3	Bottle Filler	In hallway across from room 368	WF-04012025-012582	12/15/2025	FT-FY26-12082025-012582-A	<2	FT-FY26-12082025-012582-B	<2	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-011820	11/24/2025	11/24/2026	Basement	Food Prep Sink	In kitchen east wall	Left	WF-11242025-011820	12/15/2025	FT-FY26-12082025-011820-A	<2	FT-FY26-12082025-011820-B	<2

FY26 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011801	4/1/2025	4/1/2026	1	Health Suite	In health suite 156D	WF-04012025-011801	12/15/2025	FT-FY26-12082025-011801-A	5.9	FT-FY26-12082025-011801-B	<2

First Re-test (After Plumbing Check)

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011801	12/19/2025	12/19/2026	1	Health Suite	In health suite 156D	WF-12192025-011801	1/19/2026	FT-FY26-12192025-011801-A	<2	FT-FY26-12192025-011801-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.