



# McKINLEY HS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011828	Classroom	1	In classroom 507	WT-042916-11845- A	1.5	WT-042916-11845- B	< 1			
2	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011827	Classroom	2	In room 272A north wall Right	WT-042916-11844- A	21.5	WT-042916-11844- B	< 1	Filter will be installed and then retested		
3	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011826	Classroom	2	In room 272A south wall Left	WT-042916-11843- A	2.7	WT-042916-11843- B	< 1			
4	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011825	Cooler	1	In hallway adjacent to 161T	WT-042916-11842- A	< 1	WT-042916-11842- B	< 1			
5	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011824	Classroom	1	In room 154 B	WT-042916-11841- A	< 1	WT-042916-11841- B	< 1			
6	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011823	Utility	Basement	In boiler room	WT-042916-11840- A	9.6	WT-042916-11840- B	4.9			
7	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011822	Kitchen	Basement	In kitchen ice maker	WT-042916-11839- A	< 1	WT-042916-11839- B	< 1			
8	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011821	Kitchen	Basement	In kitchen east wall (shower head) Right	WT-042916-11838- A	< 1	WT-042916-11838- B	< 1			
9	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011820	Kitchen	Basement	In kitchen east wall Left	WT-042916-11837- A	< 1	WT-042916-11837- B	< 1			
10	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011819	Kitchen	Basement	In kitchen north wall Right	WT-042916-11836- A	< 1	WT-042916-11836- B	< 1			
11	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011818	Kitchen	Basement	In kitchen north wall Left	WT-042916-11835- A	< 1	WT-042916-11835- B	< 1			
12	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011817	Kitchen	Basement	In kitchen north wall (shower head) Mid	WT-042916-11834- A	2.6	WT-042916-11834- B	< 1			
13	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011816	Classroom	Basement	In room G116 (ice maker)	WT-042916-11833- A	< 1	WT-042916-11833- B	< 1			
14	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011815	Classroom	Basement	In room G117	WT-042916-11832- A	1	WT-042916-11832- B	< 1			
15	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011814	Classroom	Basement	In room G116	WT-042916-11831- A	< 1	WT-042916-11831- B	< 1			
16	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011813	Cooler	Basement	In hallway adjacent to G102T Right High	WT-042916-11830- A	< 1	WT-042916-11830- B	< 1			
17	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011812	Cooler	Basement	In hallway adjacent to G102T Left Low	WT-042916-11829- A	< 1	WT-042916-11829- B	< 1			
18	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011811	Cooler	Basement	In gym adjacent to G115 Right High	WT-042916-11828- A	< 1	WT-042916-11828- B	1			
19	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011810	Cooler	Basement	In gym adjacent to G115 Left Low	WT-042916-11827- A	< 1	WT-042916-11827- B	< 1			
20	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011809	Cooler	1	In gym adjacent to G212 Right High	WT-042916-11826- A	< 1	WT-042916-11826- B	< 1			
21	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011808	Cooler	1	In gym adjacent to G212 Left Low	WT-042916-11825- A	< 1	WT-042916-11825- B	< 1			
22	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011807	Classroom	1	In classroom 171A art room Right	WT-042916-11824- A	186	WT-042916-11824- B	< 1	Filter will be installed and then retested		
23	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011806	Classroom	1	In classroom 171A art room Mid	WT-042916-11823- A	< 1	WT-042916-11823- B	< 1			
24	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011805	Classroom	1	In classroom 171A art room Left	WT-042916-11822- A	< 1	WT-042916-11822- B	< 1			
25	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011804	Classroom	1	In music room 158	WT-042916-11821- A	1.6	WT-042916-11821- B	< 1			
26	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011803	Cooler	1	In hallway adjacent to 163T restroom	WT-042916-11820- A	< 1	WT-042916-11820- B	< 1			
27	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011802	Classroom	1	In room 156E	WT-042916-11819- A	< 1	WT-042916-11819- B	< 1			
28	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011801	Classroom	1	In room 156D	WT-042916-11818- A	1.2	WT-042916-11818- B	< 1			
29	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011800	Health Suite	1	In room 156C	WT-042916-11817- A	6.6	WT-042916-11817- B	< 1			
30	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011799	Classroom	1	In room 152A	WT-042916-11816- A	< 1	WT-042916-11816- B	< 1			
31	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011798	Classroom	1	In room 148	WT-042916-11815- A	< 1	WT-042916-11815- B	< 1			
32	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011797	Classroom	1	In classroom 144C	WT-042916-11814- A	< 1	WT-042916-11814- B	< 1			
33	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011796	Classroom	2	In classroom 242	WT-042916-11813- A	33.8	WT-042916-11813- B	45.4	Filter will be installed and then retested		
34	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011795	Classroom	2	In classroom 248	WT-042916-11812- A	7.4	WT-042916-11812- B	< 1			
35	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011794	Classroom	2	In classroom 254	WT-042916-11811- A	27.8	WT-042916-11811- B	10.9	Filter will be installed and then retested		
36	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011793	Classroom	2	In classroom 250A table 2 last from left	WT-042916-11810- A	1.2	WT-042916-11810- B	< 1			
37	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011792	Classroom	2	In classroom 250A table 2 fifth from left	WT-042916-11809- A	6.6	WT-042916-11809- B	1.2			
38	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011791	Classroom	2	In classroom 250A table 2 fourth from left	WT-042916-11808- A	4	WT-042916-11808- B	< 1			
39	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011790	Classroom	2	In classroom 250A table 2 third from left	WT-042916-11807- A	5.9	WT-042916-11807- B	1.4			
40	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011789	Classroom	2	In classroom 250A table 2 second from left	WT-042916-11806- A	147	WT-042916-11806- B	1.9	Filter will be installed and then retested		
41	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011788	Classroom	1	In classroom 250A table 2 first from left	WT-042916-11805- A	211	WT-042916-11805- B	3.9	Filter will be installed and then retested		
42	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011787	Classroom	2	In classroom 250A table 1 first from left	WT-042916-11804- A	5.3	WT-042916-11804- B	< 1			



# McKINLEY HS LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
43	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011786	Classroom	2	In classroom 250A table 1 second from left	WT-042916-11803- A	< 1	WT-042916-11803- B	< 1				
44	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011785	Classroom	2	In classroom 250A table 1 third from left	WT-042916-11802- A	52.7	WT-042916-11802- B	< 1	Filter will be installed and then retested			
45	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011784	Classroom	2	In classroom 250A table 1 fourth from left	WT-042916-11801- A	8.1	WT-042916-11801- B	< 1				
46	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011783	Classroom	2	In classroom 250A table 1 fifth from left	WT-042916-11800- A	6.5	WT-042916-11800- B	1.4				
47	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011782	Classroom	2	In classroom 250A table 1 last from left	WT-042916-11799- A	1.2	WT-042916-11799- B	< 1				
48	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011781	Classroom	2	In classroom 250	WT-042916-11798- A	2.1	WT-042916-11798- B	< 1				
49	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011780	Classroom	2	In room 252A Left	WT-042916-11797- A	2.7	WT-042916-11797- B	< 1				
50	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011779	Classroom	2	In room 252A Right	WT-042916-11796- A	4.5	WT-042916-11796- B	< 1				
51	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011778	Classroom	2	In classroom 252	WT-042916-11795- A	1.3	WT-042916-11795- B	< 1				
52	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011777	Classroom	2	In classroom 264 table 2 second from left	WT-042916-11794- A	30.6	WT-042916-11794- B	< 1	Filter will be installed and then retested			
53	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011776	Classroom	2	In classroom 264 table 2 first from left	WT-042916-11793- A	18.9	WT-042916-11793- B	< 1	Filter will be installed and then retested			
54	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011775	Classroom	2	In classroom 264 table 2 third from left	WT-042916-11792- A	3.1	WT-042916-11792- B	< 1				
55	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011774	Classroom	2	In classroom 264 Table 2 fourth from left	WT-042916-11791- A	< 1	WT-042916-11791- B	< 1				
56	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011773	Classroom	2	In classroom 264 table 2 fifth from left	WT-042916-11790- A	< 1	WT-042916-11790- B	< 1				
57	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011772	Classroom	2	In classroom 264 table 2 last from left	WT-042916-11789- A	< 1	WT-042916-11789- B	< 1				
58	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011771	Classroom	2	In classroom 264 table 1 fourth from left	WT-042916-11788- A	10.5	WT-042916-11788- B	< 1				
59	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011770	Classroom	2	In classroom 264 table 1 last from left	WT-042916-11787- A	5.3	WT-042916-11787- B	< 1				
60	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011769	Classroom	2	In classroom 264 table 1 fifth from left	WT-042916-11786- A	5	WT-042916-11786- B	< 1				
61	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011768	Classroom	2	In classroom 264 table 1 third from left	WT-042916-11785- A	6.6	WT-042916-11785- B	< 1				
62	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011767	Classroom	2	In classroom 264 table 1 second from left	WT-042916-11784- A	7	WT-042916-11784- B	< 1				
63	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011766	Classroom	2	In classroom 264 table 1 first from left	WT-042916-11783- A	5.2	WT-042916-11783- B	< 1				
64	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011765	Classroom	2	In classroom 264 south wall	WT-042916-11782- A	< 1	WT-042916-11782- B	< 1				
65	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011764	Classroom	2	In classroom 266 table 2 fifth from left	WT-042916-11781- A	1.5	WT-042916-11781- B	< 1				
66	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011763	Classroom	2	In room 264A south wall	WT-042916-11780- A	2.8	WT-042916-11780- B	< 1				
67	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011762	Classroom	2	In room 264A north wall	WT-042916-11779- A	3.7	WT-042916-11779- B	< 1				
68	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011761	Classroom	2	In classroom 266 table 2 last from left	WT-042916-11778- A	13.9	WT-042916-11778- B	< 1				
69	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011760	Classroom	2	In classroom 226 table 2 fourth from left	WT-042916-11777- A	5.3	WT-042916-11777- B	< 1				
70	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011759	Classroom	2	In classroom 266 table 2 third from left	WT-042916-11776- A	21.2	WT-042916-11776- B	3.9	Filter will be installed and then retested			
71	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011758	Classroom	2	In classroom 266 table 2 second from left	WT-042916-11775- A	7.6	WT-042916-11775- B	< 1				
72	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011757	Classroom	2	In classroom 266 table 2 first from left	WT-042916-11774- A	19.2	WT-042916-11774- B	< 1	Filter will be installed and then retested			
73	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011756	Classroom	2	In classroom 266 table 1 last from left	WT-042916-11773- A	7	WT-042916-11773- B	< 1				
74	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011755	Classroom	2	In classroom 266 table 1 fifth from left	WT-042916-11772- A	7.9	WT-042916-11772- B	< 1				
75	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011754	Classroom	2	In classroom 266 table 1 fourth from left	WT-042916-11771- A	11	WT-042916-11771- B	< 1				
76	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011753	Classroom	2	In classroom 266 table 1 third from left	WT-042916-11770- A	8.1	WT-042916-11770- B	< 1				
77	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011752	Classroom	2	In classroom 266 table 1 second from left	WT-042916-11769- A	46.4	WT-042916-11769- B	1.3	Filter will be installed and then retested			
78	MCKINLEY TECHNOLOGY HS	5/14/2016	WS-011751	Classroom	2	In classroom 266 table 1 first from left	WT-042916-11768- A	13.3	WT-042916-11768- B	< 1				



# McKINLEY HS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
79	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011750	Classroom	2	In classroom 266 west wall	WT-042916-11767- A	< 1	WT-042916-11767- B	< 1			
80	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011749	Classroom	2	In classroom 266 south wall	WT-042916-11766- A	1	WT-042916-11766- B	< 1			
81	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011748	Classroom	2	In hallway across from 266A	WT-042916-11765- A	< 1	WT-042916-11765- B	< 1			
82	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 011747	Cooler	2	In hallway across from 266B	WT-042916-11764- A	< 1	WT-042916-11764- B	< 1			
83	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010527	Classroom	2	In classroom 268	WT-042916-10544- A	3.9	WT-042916-10544- B	< 1			
84	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010526	Classroom	2	In classroom 267	WT-042916-10543- A	5.3	WT-042916-10543- B	1.5			
85	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010525	Classroom	2	In classroom 271	WT-042916-10542- A	6.4	WT-042916-10542- B	< 1			
86	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010524	Classroom	2	In classroom 272	WT-042916-10541- A	40.2	WT-042916-10541- B	< 1	Filter will be installed and then retested		
87	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010523	Classroom	2	In classroom 271A	WT-042916-10540- A	9	WT-042916-10540- B	< 1			
88	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010522	Classroom	2	In classroom 273B east wall	WT-042916-10539- A	< 1	WT-042916-10539- B	< 1			
89	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010521	Classroom	2	In classroom 273B table 2 first from left	WT-042916-10538- A	300	WT-042916-10538- B	11.8	Filter will be installed and then retested		
90	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010520	Classroom	2	In classroom 273B table 2 second from left	WT-042916-10537- A	40.4	WT-042916-10537- B	44.9	Filter will be installed and then retested		
91	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010519	Classroom	2	In classroom 273B table 2 third from left	WT-042916-10536- A	15.4	WT-042916-10536- B	< 1	Filter will be installed and then retested		
92	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010518	Classroom	2	In classroom 273B table 1 fourth from left	WT-042916-10535- A	11.8	WT-042916-10535- B	< 1			
93	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010517	Classroom	2	In classroom 273B table 1 fifth from left	WT-042916-10534- A	24.3	WT-042916-10534- B	1.3	Filter will be installed and then retested		
94	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010516	Classroom	2	In classroom 273B table 2 fifth from left	WT-042916-10533- A	98.4	WT-042916-10533- B	1.1	Filter will be installed and then retested		
95	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010515	Classroom	2	In classroom 273B table 1 last from left	WT-042916-10532- A	20.4	WT-042916-10532- B	< 1	Filter will be installed and then retested		
96	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010514	Classroom	2	In classroom 273B table 2 last from left	WT-042916-10531- A	237	WT-042916-10531- B	2.4	Filter will be installed and then retested		
97	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010513	Classroom	2	In classroom 273B table 2 fourth from left	WT-042916-10530- A	5.3	WT-042916-10530- B	< 1			
98	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010512	Classroom	2	In classroom 273B table 2 third from left	WT-042916-10529- A	7.3	WT-042916-10529- B	< 1			
99	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010511	Classroom	2	In classroom 273B table 2 second from left	WT-042916-10528- A	28.9	WT-042916-10528- B	3.5	Filter will be installed and then retested		
100	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010510	Classroom	2	In classroom 273B table 2 first from left	WT-042916-10527- A	27.7	WT-042916-10527- B	< 1	Filter will be installed and then retested		
101	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010509	Classroom	2	In classroom 273B south wall	WT-042916-10526- A	24	WT-042916-10526- B	< 1	Filter will be installed and then retested		
102	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010508	Classroom	2	In classroom 274B table 2 last from left	WT-042916-10525- A	7.7	WT-042916-10525- B	< 1			
103	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010507	Classroom	2	In classroom 274B table 2 fifth from left	WT-042916-10524- A	10.3	WT-042916-10524- B	< 1			



# McKINLEY HS LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
104	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010506	Classroom	2	In classroom 274B table 2 fourth from left	WT-042916-10523- A	17.3	WT-042916-10523- B	< 1	Filter will be installed and then retested			
105	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010505	Classroom	2	In classroom 274B table 2 third from left	WT-042916-10522- A	23.5	WT-042916-10522- B	< 1	Filter will be installed and then retested			
106	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010504	Classroom	2	In classroom 274B table 2 second from left	WT-042916-10521- A	55.1	WT-042916-10521- B	1.1	Filter will be installed and then retested			
107	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010503	Classroom	2	In classroom 274B table 2 first from left	WT-042916-10520- A	30.8	WT-042916-10520- B	3.4	Filter will be installed and then retested			
108	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010502	Classroom	2	In classroom 274B table 1 last from left	WT-042916-10519- A	56.3	WT-042916-10519- B	< 1	Filter will be installed and then retested			
109	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010501	Classroom	2	In classroom 274B table 1 fifth from left	WT-042916-10518- A	38.2	WT-042916-10518- B	< 1	Filter will be installed and then retested			
110	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010500	Classroom	2	In classroom 274B table 1 fourth from left	WT-042916-10517- A	16.7	WT-042916-10517- B	< 1	Filter will be installed and then retested			
111	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010499	Classroom	2	In classroom 274B table 1 third from left	WT-042916-10516- A	4.3	WT-042916-10516- B	1.5				
112	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010498	Classroom	2	In classroom 274B table 1 second from left	WT-042916-10515- A	44.4	WT-042916-10515- B	2.3	Filter will be installed and then retested			
113	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010497	Classroom	2	In classroom 274 table 1 first from left	WT-042916-10514- A	17.1	WT-042916-10514- B	< 1	Filter will be installed and then retested			
114	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010496	Classroom	2	In classroom 274B west wall	WT-042916-10513- A	< 1	WT-042916-10513- B	< 1				
115	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010495	Classroom	2	In classroom 274B south wall	WT-042916-10512- A	24.3	WT-042916-10512- B	1.3	Filter will be installed and then retested			
116	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010494	Classroom	2	In teachers lounge 279	WT-042916-10511- A	< 1	WT-042916-10511- B	< 1				
117	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010493	Classroom	3	In staff lounge	WT-042916-10510- A	< 1	WT-042916-10510- B	< 1				
118	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010492	Classroom	3	In work center room 383B	WT-042916-10509- A	< 1	WT-042916-10509- B	< 1				
119	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010491	Cooler	3	In hallway across from 368	WT-042916-10508- A	< 1	WT-042916-10508- B	< 1				
120	MCKINLEY TECHNOLOGY HS	5/14/2016	WS- 010490	Cooler	3	In hallway adjacent to room 365	WT-042916-10507- A	< 1	WT-042916-10507- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.