



McKinley Tech Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010468	4/12/2023	4/12/2024	1	Cooler	In hallway across from room 115F Low Left	WF-04122023-010468	12/20/2023	FT-FY24-11012023-010468-A	<1	FT-FY24-11012023-010468-B	<1
WS- 010469	4/12/2023	4/12/2024	1	Cooler	In hallway across from room 115F High Right	WF-04122023-010469	12/20/2023	FT-FY24-11012023-010469-A	<1	FT-FY24-11012023-010469-B	<1
WS- 010472	4/12/2023	4/12/2024	1	Cooler	In gym adjacent to room 114F Low Left	WF-04122023-010472	12/20/2023	FT-FY24-11012023-010472-A	<1	FT-FY24-11012023-010472-B	<1
WS- 010473	4/12/2023	4/12/2024	1	Cooler	In gym adjacent to room 114F High Right	WF-04122023-010473	12/20/2023	FT-FY24-11012023-010473-A	<1	FT-FY24-11012023-010473-B	<1
WS- 010474	4/12/2023	4/12/2024	1	Health Suite	In health suite in treatment room 117D	WF-04122023-010474	12/20/2023	FT-FY24-11012023-010474-A	2.9	FT-FY24-11012023-010474-B	<1
WS- 010475	4/12/2023	4/12/2024	1	Combo Fountain	In treatment room 117D in health suite	WF-04122023-010475	12/20/2023	FT-FY24-11012023-010475-A	<1	FT-FY24-11012023-010475-B	<1
WS- 010476	4/12/2023	4/12/2024	2	Cooler	In hallway adjacent to room 202 Low Left	WF-04122023-010476	12/20/2023	FT-FY24-11012023-010476-A	<1	FT-FY24-11012023-010476-B	<1
WS- 010477	4/12/2023	4/12/2024	2	Cooler	In hallway adjacent to room 202 High Right	WF-04122023-010477	12/20/2023	FT-FY24-11012023-010477-A	<1	FT-FY24-11012023-010477-B	<1
WS- 010486	4/12/2023	4/12/2024	2	Break Room	In staff lounge	WF-04122023-010486	12/20/2023	FT-FY24-11012023-010486-A	<1	FT-FY24-11012023-010486-B	<1
WS- 010548	4/12/2023	4/12/2024	1	Bottle Filler	In hallway across from room 115F	WF-04122023-010548	12/20/2023	FT-FY24-11012023-010548-A	<1	FT-FY24-11012023-010548-B	<1