



McKinley Tech Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010468	11/28/2022	11/28/2023	1	Cooler	In hallway across from room 115F Low Left	WF-11282022-010468	2/10/2023	FT-FY23-01102023-010468-A	<1	FT-FY23-01102023-010468-B	<1
WS- 010469	11/28/2022	11/28/2023	1	Cooler	In hallway across from room 115F High Right	WF-11282022-010469	2/10/2023	FT-FY23-01102023-010469-A	<1	FT-FY23-01102023-010469-B	<1
WS- 010470	4/18/2022	4/18/2023	1	Cooler	In gym adjacent to room 114C High Left	WF-04182022-010470	2/10/2023	FT-FY23-01102023-010470-A	<1	FT-FY23-01102023-010470-B	<1
WS- 010471	4/18/2022	4/18/2023	1	Cooler	In gym adjacent to room 114C Low Right	WF-04182022-010471	2/10/2023	FT-FY23-01102023-010471-A	<1	FT-FY23-01102023-010471-B	<1
WS- 010472	4/18/2022	4/18/2023	1	Cooler	In gym adjacent to room 114F Low Left	WF-04182022-010472	2/10/2023	FT-FY23-01102023-010472-A	<1	FT-FY23-01102023-010472-B	<1
WS- 010473	4/18/2022	4/18/2023	1	Cooler	In gym adjacent to room 114F High Right	WF-04182022-010473	2/10/2023	FT-FY23-01102023-010473-A	<1	FT-FY23-01102023-010473-B	<1
WS- 010474	4/18/2022	4/18/2023	1	Health Suite	In health suite in treatment room 117D	WF-04182022-010474	2/10/2023	FT-FY23-01102023-010474-A	<1	FT-FY23-01102023-010474-B	<1
WS- 010475	4/18/2022	4/18/2023	1	Combo Fountain	In treatment room 117D in health suite	WF-04182022-010475	2/10/2023	FT-FY23-01102023-010475-A	<1	FT-FY23-01102023-010475-B	<1
WS- 010476	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to room 202 Low Left	WF-04182022-010476	2/10/2023	FT-FY23-01102023-010476-A	<1	FT-FY23-01102023-010476-B	<1
WS- 010477	4/18/2022	4/18/2023	2	Cooler	In hallway adjacent to room 202 High Right	WF-04182022-010477	2/10/2023	FT-FY23-01102023-010477-A	<1	FT-FY23-01102023-010477-B	<1
WS- 010486	4/18/2022	4/18/2023	2	Break Room	In staff lounge	WF-04182022-010486	2/10/2023	FT-FY23-01102023-010486-A	<1	FT-FY23-01102023-010486-B	<1
WS- 010548	11/28/2022	11/28/2023	1	Bottle Filler	In hallway across from room 115F	WF-11282022-010548	2/10/2023	FT-FY23-01102023-010548-A	<1	FT-FY23-01102023-010548-B	<1