



McKinley Tech Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011748	6/27/17	6/27/18	2	Cooler	In hallway across from girl's restroom	WF-62017-011748	12/19/17	FT-FY18--62017-011748-A	<1	FT-FY18--62017-011748-B	<1
WS- 011803	6/27/17	6/27/18	1	Cooler	In hallway adjacent to restroom 163T	WF-62017-011803	12/19/17	FT-FY18--62017-011803-A	<1	FT-FY18--62017-011803-B	<1
WS- 011808	6/27/17	6/27/18	1	Cooler	In gym adjacent to room G212 Left Low	WF-72017-011808	12/19/17	FT-FY18--72017-011808-A	<1	FT-FY18--72017-011808-B	<1
WS- 011811	6/27/17	6/27/18	Basement	Cooler	In gym adjacent to room G115 Right High	WF-62017-011811	12/19/17	FT-FY18--62017-011811-A	<1	FT-FY18--62017-011811-B	<1
WS- 011812	6/27/17	6/27/18	Basement	Cooler	In hallway adjacent to room G102T Left Low	WF-62017-011812	12/19/17	FT-FY18--62017-011812-A	<1	FT-FY18--62017-011812-B	<1
WS- 011822	6/27/17	6/27/18	Basement	Ice Maker	In kitchen (ice maker)	WF-62017-011822	12/19/17	FT-FY18--62017-011822-A	<1	FT-FY18--62017-011822-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011820	Basement	Food Prep Sink	In kitchen east wall Left	12/19/17	FT-FY18-102017-011820-A	<1	FT-FY18-102017-011820-B	<1	