



McKinley Tech HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002590	6/11/2018	6/11/2019	Basement	Cooler	In girls' locker room adjacent to room G-119	WF-06112018-002590	12/27/2018	FT-FY19-122018-002590-A	<1	FT-FY19-122018-002590-B	<1
WS- 002591	6/11/2018	6/11/2019	Basement	Cooler	In boy's' locker room adjacent to room G-124	WF-06112018-002591	12/27/2018	FT-FY19-122018-002591-A	<1	FT-FY19-122018-002591-B	<1
WS- 010490	6/11/2018	6/11/2019	3	Cooler	In hallway adjacent to room 365	WF-06112018-010490	12/27/2018	FT-FY19-122018-010490-A	<1	FT-FY19-122018-010490-B	<1
WS- 010491	6/11/2018	6/11/2019	3	Cooler	In hallway across from room 368	WF-06112018-010491	12/27/2018	FT-FY19-122018-010491-A	<1	FT-FY19-122018-010491-B	<1
WS- 011747	6/11/2018	6/11/2019	2	Cooler	In hallway across from boys' restroom	WF-06112018-011747	12/27/2018	FT-FY19-122018-011747-A	<1	FT-FY19-122018-011747-B	<1
WS- 011748	6/11/2018	6/11/2019	2	Cooler	In hallway across from girl's restroom	WF-06112018-011748	12/27/2018	FT-FY19-122018-011748-A	<1	FT-FY19-122018-011748-B	<1
WS- 011800	6/11/2018	6/11/2019	1	Health Suite	In health suite 156B	WF-06112018-011800	12/27/2018	FT-FY19-122018-011800-A	<1	FT-FY19-122018-011800-B	<1
WS- 011801	6/11/2018	6/11/2019	1	Health Suite	In health suite 156D	WF-06112018-011801	12/27/2018	FT-FY19-122018-011801-A	3	FT-FY19-122018-011801-B	<1
WS- 011802	6/11/2018	6/11/2019	1	Health Suite	In health suite 156E	WF-06112018-011802	12/27/2018	FT-FY19-122018-011802-A	<1	FT-FY19-122018-011802-B	<1
WS- 011803	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to restroom 163T	WF-06112018-011803	12/27/2018	FT-FY19-122018-011803-A	<1	FT-FY19-122018-011803-B	<1
WS- 011808	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room G212	WF-06112018-011808	12/27/2018	FT-FY19-122018-011808-A	<1	FT-FY19-122018-011808-B	<1
WS- 011809	6/11/2018	6/11/2019	1	Cooler	In gym adjacent to room G212	WF-06112018-011809	12/27/2018	FT-FY19-122018-011809-A	<1	FT-FY19-122018-011809-B	<1
WS- 011822	6/11/2018	6/11/2019	Basement	Ice Maker	In kitchen (ice maker)	WF-06112018-011822	12/27/2018	FT-FY19-122018-011822-A	<1	FT-FY19-122018-011822-B	<1
WS- 011825	6/11/2018	6/11/2019	1	Cooler	In hallway adjacent to room 161T	WF-06112018-011825	12/27/2018	FT-FY19-122018-011825-A	<1	FT-FY19-122018-011825-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011820	Basement	Food Prep Sink	In kitchen east wall Left	12/27/2018	FT-FY19-122018-011820-A	<1	FT-FY19-122018-011820-B	<1