



McKinley Tech High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002591	4/12/2023	4/12/2024	Basement	Cooler	In boy's' locker room adjacent to room G-124	WF-04122023-002591	12/30/2023	FT-FY24-11012023-002591-A	<1	FT-FY24-11012023-002591-B	<1	
WS- 010490	4/12/2023	4/12/2024	3	Cooler	In hallway adjacent to room 366	WF-04122023-010490	12/30/2023	FT-FY24-11012023-010490-A	<1	FT-FY24-11012023-010490-B	<1	
WS- 010491	4/12/2023	4/12/2024	3	Cooler	In hallway across from room 368	WF-04122023-010491	12/30/2023	FT-FY24-11012023-010491-A	<1	FT-FY24-11012023-010491-B	<1	
WS- 011524	10/31/2023	10/31/2024	1	Bottle Filler	In hallway adjacent to boys restroom	WF-10312023-011524	12/30/2023	FT-FY24-11012023-011524-A	<1	FT-FY24-11012023-011524-B	<1	
WS- 011747	4/12/2023	4/12/2024	2	Cooler	In hallway adjacent to boys restroom	WF-04122023-011747	12/30/2023	FT-FY24-11012023-011747-A	<1	FT-FY24-11012023-011747-B	<1	
WS- 011748	4/12/2023	4/12/2024	2	Cooler	In hallway adjacent to girls restroom	WF-04122023-011748	12/30/2023	FT-FY24-11012023-011748-A	<1	FT-FY24-11012023-011748-B	<1	
WS- 011800	4/12/2023	4/12/2024	1	Health Suite	In health suite 156B	WF-04122023-011800	12/30/2023	FT-FY24-11012023-011800-A	<1	FT-FY24-11012023-011800-B	<1	
WS- 011801	4/12/2023	4/12/2024	1	Health Suite	In health suite 156D	WF-04122023-011801	12/30/2023	FT-FY24-11012023-011801-A	<1	FT-FY24-11012023-011801-B	<1	
WS- 011802	4/12/2023	4/12/2024	1	Health Suite	In health suite 156E	WF-04122023-011802	12/30/2023	FT-FY24-11012023-011802-A	<1	FT-FY24-11012023-011802-B	<1	
WS- 011803	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to boys restroom	WF-04122023-011803	12/30/2023	FT-FY24-11012023-011803-A	<1	FT-FY24-11012023-011803-B	<1	
WS- 011808	4/12/2023	4/12/2024	1	Cooler	In gym adjacent to room G212	Low Left	WF-04122023-011808	12/30/2023	FT-FY24-11012023-011808-A	<1	FT-FY24-11012023-011808-B	<1
WS- 011809	4/12/2023	4/12/2024	1	Cooler	In gym adjacent to room G212	High Right	WF-04122023-011809	12/30/2023	FT-FY24-11012023-011809-A	<1	FT-FY24-11012023-011809-B	<1
WS- 011810	4/12/2023	4/12/2024	Basement	Cooler	In gym adjacent to room G115	Low Left	WF-04122023-011810	12/30/2023	FT-FY24-11012023-011810-A	<1	FT-FY24-11012023-011810-B	<1
WS- 011811	4/12/2023	4/12/2024	Basement	Cooler	In gym adjacent to room G115	High Right	WF-04122023-011811	12/30/2023	FT-FY24-11012023-011811-A	<1	FT-FY24-11012023-011811-B	<1
WS- 011812	4/12/2023	4/12/2024	Basement	Cooler	In hallway adjacent to room G102T	Low Left	WF-04122023-011812	12/30/2023	FT-FY24-11012023-011812-A	<1	FT-FY24-11012023-011812-B	1.0
WS- 011822	4/12/2023	4/12/2024	Basement	Ice Maker	In kitchen (ice maker)	WF-04122023-011822	12/30/2023	FT-FY24-11012023-011822-A	<1	FT-FY24-11012023-011822-B	<1	
WS- 011825	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to girls restroom	WF-04122023-011825	12/30/2023	FT-FY24-11012023-011825-A	<1	FT-FY24-11012023-011825-B	<1	
WS- 012579	10/31/2023	10/31/2024	1	Bottle Filler	In gym adjacent to room G212	WF-10312023-012579	12/30/2023	FT-FY24-11012023-012579-A	<1	FT-FY24-11012023-012579-B	<1	
WS- 012580	10/31/2023	10/31/2024	1	Bottle Filler	In hallway adjacent to girls restroom	WF-10312023-012580	12/30/2023	FT-FY24-11012023-012580-A	<1	FT-FY24-11012023-012580-B	<1	
WS- 012581	10/31/2023	10/31/2024	3	Bottle Filler	In hallway adjacent to room 366	WF-10312023-012581	12/30/2023	FT-FY24-11012023-012581-A	<1	FT-FY24-11012023-012581-B	<1	
WS- 012582	10/31/2023	10/31/2024	3	Bottle Filler	In hallway across from room 368	WF-10312023-012582	12/30/2023	FT-FY24-11012023-012582-A	<1	FT-FY24-11012023-012582-B	<1	
WS-017049	11/2/2023	11/2/2024	2	Bottle Filler	In hallway adjacent to boys restroom	WF-11022023-017049	12/30/2023	FT-FY24-12012023-017049-A	<1	FT-FY24-12012023-017049-B	<1	
WS-017050	11/2/2023	11/2/2024	2	Bottle Filler	In hallway adjacent to girls restroom	WF-11022023-017050	12/30/2023	FT-FY24-12012023-017050-A	<1	FT-FY24-12012023-017050-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011820	1/11/2023	1/11/2024	Basement	Food Prep Sink	In kitchen east wall	Left	WF-01112023-011820	12/30/2023	FT-FY24-11012023-011820-A	<1	FT-FY24-11012023-011820-B	<1