



MEYER ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	MEYER ELEMENTARY	WS- 010537	8/18/2016	1	Ice Maker	In kitchen (ice maker) Mid	FT-82016-010537-A	< 1	FT-82016-010537-B	< 1
2	MEYER ELEMENTARY	WS- 012048	8/18/2016	Ground Floor	Cooler	In hallway across from room G14	FT-82016-012048-A	< 1	FT-82016-012048-B	< 1
3	MEYER ELEMENTARY	WS- 012049	8/18/2016	Ground Floor	Cooler	In hallway adjacent to the restroom	FT-82016-012049-A	3.06	FT-82016-012049-B	< 1
			10/10/2016				Re-test A	< 1	Re-test B	< 1
4	MEYER ELEMENTARY	WS- 012061	8/18/2016	Ground Floor	Cooler	POD, in hallway adjacent to girls' restroom High Left	FT-82016-012061-A	< 1	FT-82016-012061-B	< 1
5	MEYER ELEMENTARY	WS- 012062	8/18/2016	Ground Floor	Cooler	POD, in hallway adjacent to girls' restroom Low Right	FT-82016-012062-A	< 1	FT-82016-012062-B	< 1
6	MEYER ELEMENTARY	WS- 012063	8/18/2016	Ground Floor	Cooler	POD, in hallway adjacent to boys' restroom High Left	FT-82016-012063-A	< 1	FT-82016-012063-B	< 1
7	MEYER ELEMENTARY	WS- 012064	8/18/2016	Ground Floor	Cooler	POD, in hallway adjacent to boys' restroom Low Right	FT-82016-012064-A	< 1	FT-82016-012064-B	< 1
8	MEYER ELEMENTARY	WS- 012066	8/18/2016	1	Cooler	In hallway adjacent to room 143	FT-82016-012066-A	< 1	FT-82016-012066-B	< 1
9	MEYER ELEMENTARY	WS- 012067	8/18/2016	1	Health Suite	In health suite	FT-82016-012067-A	< 1	FT-82016-012067-B	< 1
10	MEYER ELEMENTARY	WS- 012068	8/18/2016	1	Cooler	In health suite	FT-82016-012068-A	< 1	FT-82016-012068-B	< 1
11	MEYER ELEMENTARY	WS- 012071	8/18/2016	1	Cooler	In hallway adjacent to restroom	FT-82016-012071-A	< 1	FT-82016-012071-B	< 1
12	MEYER ELEMENTARY	WS- 012072	8/18/2016	1	Food Prep Sink	In kitchen Left	FT-82016-012072-A	< 1	FT-82016-012072-B	< 1
13	MEYER ELEMENTARY	WS- 012074	8/18/2016	1	Cooler	In hallway adjacent to room 115	FT-82016-012074-A	< 1	FT-82016-012074-B	< 1
14	MEYER ELEMENTARY	WS- 012075	8/18/2016	2	Cooler	In hallway adjacent to room 215	FT-82016-012075-A	< 1	FT-82016-012075-B	< 1
15	MEYER ELEMENTARY	WS- 012077	8/18/2016	2	Cooler	In hallway adjacent to restroom	FT-82016-012077-A	< 1	FT-82016-012077-B	< 1
16	MEYER ELEMENTARY	WS- 012078	8/18/2016	2	Cooler	In hallway across from room 202	FT-82016-012078-A	< 1	FT-82016-012078-B	< 1