



Meyer ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012048	6/26/2017	6/26/2018	Ground Floor	Cooler	In hallway across from room G14	WF-62017-012048	11/1/2017	FT-FY18-102017-012048-A	<1	FT-FY18-102017-012048-B	<1
WS- 012066	6/26/2017	6/26/2018	1	Cooler	In hallway adjacent to room 143	WF-62017-012066	11/1/2017	FT-FY18-102017-012066-A	<1	FT-FY18-102017-012066-B	<1
WS- 012071	6/26/2017	6/26/2018	1	Cooler	In hallway adjacent to restroom	WF-62017-012071	11/1/2017	FT-FY18-102017-012071-A	<1	FT-FY18-102017-012071-B	<1
WS- 012074	6/26/2017	6/26/2018	1	Cooler	In hallway adjacent to room 115	WF-62017-012074	11/1/2017	FT-FY18-102017-012074-A	<1	FT-FY18-102017-012074-B	<1
WS- 012078	6/26/2017	6/26/2018	2	Cooler	In hallway across from room 202	WF-62017-012078	11/1/2017	FT-FY18-102017-012078-A	<1	FT-FY18-102017-012078-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012072	1	Food Prep Sink	In kitchen Left	11/1/2017	FT-FY18-102017-012072-A	<1	FT-FY18-102017-012072-B	<1