



Meyer Swing Space Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012049	2/22/2023	2/22/2024	Ground Floor	Cooler	In hallway adjacent to the restroom	WF-02222023-012049	10/16/2023	FT-FY24-09182023-012049-A	<1	FT-FY24-09182023-012049-B	<1
WS- 012066	2/22/2023	2/22/2024	1	Cooler	In hallway adjacent to room 103	WF-02222023-012066	10/16/2023	FT-FY24-09182023-012066-A	1.0	FT-FY24-09182023-012066-B	1.0
WS- 012068	2/22/2023	2/22/2024	1	Cooler	In room 105B health suite	WF-02222023-012068	10/16/2023	FT-FY24-09182023-012068-A	<1	FT-FY24-09182023-012068-B	<1
WS- 012070	2/22/2023	2/22/2024	1	Break Room	In room 110	WF-02222023-012070	10/16/2023	FT-FY24-09182023-012070-A	<1	FT-FY24-09182023-012070-B	<1
WS- 012071	2/22/2023	2/22/2024	1	Cooler	In hallway adjacent to restroom	WF-02222023-012071	10/16/2023	FT-FY24-09182023-012071-A	<1	FT-FY24-09182023-012071-B	<1
WS- 012150	2/22/2023	2/22/2024	1	Bottle Filler	In hallway adjacent to restroom	WF-02222023-012150	10/16/2023	FT-FY24-09182023-012150-A	<1	FT-FY24-09182023-012150-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012072	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen Left	WF-12192022-012072	10/16/2023	FT-FY24-09182023-012072-A	<1	FT-FY24-09182023-012072-B	<1