



# Meyer Swing Space Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012048	2/21/2024	2/21/2025	Ground Floor	Cooler	In hallway across from room G24	WF-02212024-012048	10/16/2024	FT-FY25-10032024-012048-A	<2	FT-FY25-10032024-012048-B	<2
WS- 012049	2/21/2024	2/21/2025	Ground Floor	Cooler	In hallway adjacent to the restroom	WF-02212024-012049	10/16/2024	FT-FY25-10032024-012049-A	<2	FT-FY25-10032024-012049-B	<2
WS- 012066	2/21/2024	2/21/2025	1	Cooler	In hallway adjacent to room 103	WF-02212024-012066	10/16/2024	FT-FY25-10032024-012066-A	<2	FT-FY25-10032024-012066-B	<2
WS- 012068	2/21/2024	2/21/2025	1	Cooler	In room 105B health suite	WF-02212024-012068	10/16/2024	FT-FY25-10032024-012068-A	<2	FT-FY25-10032024-012068-B	<2
WS- 012070	2/21/2024	2/21/2025	1	Break Room	In room 110	WF-02212024-012070	10/16/2024	FT-FY25-10032024-012070-A	<2	FT-FY25-10032024-012070-B	<2
WS- 012071	8/26/2024	8/26/2025	1	Cooler	In hallway adjacent to restroom	WF-08262024-012071	10/16/2024	FT-FY25-10032024-012071-A	<2	FT-FY25-10032024-012071-B	<2
WS- 012074	2/21/2024	2/21/2025	1	Cooler	In hallway opposite to room 126	WF-02212024-012074	10/16/2024	FT-FY25-10032024-012074-A	<2	FT-FY25-10032024-012074-B	<2
WS- 012077	2/21/2024	2/21/2025	2	Cooler	In hallway adjacent to restroom	WF-02212024-012077	10/16/2024	FT-FY25-10032024-012077-A	<2	FT-FY25-10032024-012077-B	<2
WS- 012150	8/26/2024	8/26/2025	1	Bottle Filler	In hallway adjacent to restroom	WF-08262024-012150	10/16/2024	FT-FY25-10032024-012150-A	<2	FT-FY25-10032024-012150-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012072	11/15/2023	11/15/2024	1	Food Prep Sink	In kitchen Left	WF-11152023-012072	10/16/2024	FT-FY25-10032024-012072-A	<2	FT-FY25-10032024-012072-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.