



Military Road Early Learning Center Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005200	9/25/2024	9/25/2025	Basement	Break Room	In staff lounge	WF-09252024-005200	11/6/2024	FT-FY25-10082024-005200-A	<2	FT-FY25-10082024-005200-B	<2	
WS- 005203	9/25/2024	9/25/2025	Basement	Classroom Faucet	In resource room B12	WF-09252024-005203	11/6/2024	FT-FY25-10082024-005203-A	<2	FT-FY25-10082024-005203-B	<2	
WS- 005204	5/21/2024	5/21/2025	1	Bottle Filler	In hallway adjacent to front desk	WF-05212024-005204	11/6/2024	FT-FY25-10082024-005204-A	<2	FT-FY25-10082024-005204-B	<2	
WS- 005205	5/21/2024	5/21/2025	1	Cooler	In hallway adjacent to front desk	High Left	WF-05212024-005205	11/6/2024	FT-FY25-10082024-005205-A	<2	FT-FY25-10082024-005205-B	<2
WS- 005206	5/21/2024	5/21/2025	1	Cooler	In hallway adjacent to front desk	Low Right	WF-05212024-005206	11/6/2024	FT-FY25-10082024-005206-A	<2	FT-FY25-10082024-005206-B	<2
WS- 005207	9/25/2024	9/25/2025	1	Health Suite	In health suite 128	WF-09252024-005207	11/6/2024	FT-FY25-10082024-005207-A	<2	FT-FY25-10082024-005207-B	<2	
WS- 005208	9/25/2024	9/25/2025	1	Combo Faucet	In classroom 103	WF-09252024-005208	11/6/2024	FT-FY25-10082024-005208-A	<2	FT-FY25-10082024-005208-B	<2	
WS- 005209	9/25/2024	9/25/2025	1	Combo Fountain	In classroom 103	WF-09252024-005209	11/6/2024	FT-FY25-10082024-005209-A	<2	FT-FY25-10082024-005209-B	<2	
WS- 005210	9/25/2024	9/25/2025	1	Combo Faucet	In classroom 106	WF-09252024-005210	11/6/2024	FT-FY25-10082024-005210-A	<2	FT-FY25-10082024-005210-B	<2	
WS- 005212	9/25/2024	9/25/2025	1	Combo Faucet	In classroom 121	WF-09252024-005212	11/6/2024	FT-FY25-10082024-005212-A	2.0	FT-FY25-10082024-005212-B	<2	
WS- 005213	9/25/2024	9/25/2025	1	Combo Fountain	In classroom 121	WF-09252024-005213	11/6/2024	FT-FY25-10082024-005213-A	<2	FT-FY25-10082024-005213-B	<2	
WS- 005214	5/21/2024	5/21/2025	2	Cooler	In hallway adjacent to room 217	High Left	WF-05212024-005214	11/6/2024	FT-FY25-10082024-005214-A	<2	FT-FY25-10082024-005214-B	<2
WS- 005215	5/21/2024	5/21/2025	2	Cooler	In hallway adjacent to room 217	Low Right	WF-05212024-005215	11/6/2024	FT-FY25-10082024-005215-A	<2	FT-FY25-10082024-005215-B	<2
WS- 005216	9/25/2024	9/25/2025	2	Combo Faucet	In classroom 205	WF-09252024-005216	11/6/2024	FT-FY25-10082024-005216-A	<2	FT-FY25-10082024-005216-B	<2	
WS- 005217	9/25/2024	9/25/2025	2	Combo Fountain	In classroom 205	WF-09252024-005217	11/6/2024	FT-FY25-10082024-005217-A	<2	FT-FY25-10082024-005217-B	<2	
WS- 005218	9/25/2024	9/25/2025	2	Combo Faucet	In classroom 209	WF-09252024-005218	11/6/2024	FT-FY25-10082024-005218-A	<2	FT-FY25-10082024-005218-B	<2	
WS- 005220	9/25/2024	9/25/2025	2	Classroom Faucet	In classroom 218	WF-09252024-005220	11/6/2024	FT-FY25-10082024-005220-A	<2	FT-FY25-10082024-005220-B	<2	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005201	11/27/2023	11/27/2024	Basement	Food Prep Sink	In kitchen	Left	WF-11272023-005201	11/6/2024	FT-FY25-10082024-005201-A	<2	FT-FY25-10082024-005201-B	<2
WS- 005202	11/27/2023	11/27/2024	Basement	Food Prep Sink	In kitchen	Right	WF-11272023-005202	11/6/2024	FT-FY25-10082024-005202-A	2.6	FT-FY25-10082024-005202-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.