



Military Road Early Learning Center Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005200	9/17/2025	9/17/2026	Basement	Break Room	In staff lounge	WF-09172025-005200	10/31/2025	FT-FY26-10172025-005200-A	<2	FT-FY26-10172025-005200-B	<2	
WS- 005203	9/17/2025	9/17/2026	Basement	Classroom Faucet	In resource room B12	WF-09172025-005203	10/31/2025	FT-FY26-10172025-005203-A	<2	FT-FY26-10172025-005203-B	<2	
WS- 005204	5/14/2025	5/14/2026	1	Bottle Filler	In hallway adjacent to front desk	WF-05142025-005204	10/31/2025	FT-FY26-10172025-005204-A	<2	FT-FY26-10172025-005204-B	<2	
WS- 005205	5/14/2025	5/14/2026	1	Cooler	In hallway adjacent to front desk	High Left	WF-05142025-005205	10/31/2025	FT-FY26-10172025-005205-A	<2	FT-FY26-10172025-005205-B	<2
WS- 005206	5/14/2025	5/14/2026	1	Cooler	In hallway adjacent to front desk	Low Right	WF-05142025-005206	10/31/2025	FT-FY26-10172025-005206-A	<2	FT-FY26-10172025-005206-B	<2
WS- 005207	9/17/2025	9/17/2026	1	Health Suite	In health suite 128	WF-09172025-005207	10/31/2025	FT-FY26-10172025-005207-A	<2	FT-FY26-10172025-005207-B	<2	
WS- 005208	9/17/2025	9/17/2026	1	Combo Faucet	In classroom 103	WF-09172025-005208	10/31/2025	FT-FY26-10172025-005208-A	<2	FT-FY26-10172025-005208-B	<2	
WS- 005209	10/7/2025	10/7/2026	1	Combo Fountain	In classroom 103	WF-10072025-005209	10/31/2025	FT-FY26-10172025-005209-A	<2	FT-FY26-10172025-005209-B	<2	
WS- 005210	9/17/2025	9/17/2026	1	Combo Faucet	In classroom 106	WF-09172025-005210	10/31/2025	FT-FY26-10172025-005210-A	<2	FT-FY26-10172025-005210-B	<2	
WS- 005211	10/7/2025	10/7/2026	1	Combo Fountain	In classroom 106	WF-10072025-005211	10/31/2025	FT-FY26-10172025-005211-A	<2	FT-FY26-10172025-005211-B	<2	
WS- 005212	9/17/2025	9/17/2026	1	Combo Faucet	In classroom 121	WF-09172025-005212	10/31/2025	FT-FY26-10172025-005212-A	<2	FT-FY26-10172025-005212-B	<2	
WS- 005213	10/7/2025	10/7/2026	1	Combo Fountain	In classroom 121	WF-10072025-005213	10/31/2025	FT-FY26-10172025-005213-A	<2	FT-FY26-10172025-005213-B	<2	
WS- 005214	5/14/2025	5/14/2026	2	Cooler	In hallway adjacent to room 217	High Left	WF-05142025-005214	10/31/2025	FT-FY26-10172025-005214-A	<2	FT-FY26-10172025-005214-B	<2
WS- 005215	5/14/2025	5/14/2026	2	Cooler	In hallway adjacent to room 217	Low Right	WF-05142025-005215	10/31/2025	FT-FY26-10172025-005215-A	<2	FT-FY26-10172025-005215-B	<2
WS- 005216	9/17/2025	9/17/2026	2	Combo Faucet	In classroom 205	WF-09172025-005216	10/31/2025	FT-FY26-10172025-005216-A	<2	FT-FY26-10172025-005216-B	<2	
WS- 005217	10/7/2025	10/7/2026	2	Combo Fountain	In classroom 205	WF-10072025-005217	10/31/2025	FT-FY26-10172025-005217-A	<2	FT-FY26-10172025-005217-B	<2	
WS- 005218	9/17/2025	9/17/2026	2	Combo Faucet	In classroom 209	WF-09172025-005218	10/31/2025	FT-FY26-10172025-005218-A	<2	FT-FY26-10172025-005218-B	<2	
WS- 005219	10/7/2025	10/7/2026	2	Combo Fountain	In classroom 209	WF-10072025-005219	10/31/2025	FT-FY26-10172025-005219-A	<2	FT-FY26-10172025-005219-B	<2	
WS- 005220	9/17/2025	9/17/2026	2	Classroom Faucet	In classroom 218	WF-09172025-005220	10/31/2025	FT-FY26-10172025-005220-A	<2	FT-FY26-10172025-005220-B	<2	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005201	11/26/2024	11/26/2025	Basement	Food Prep Sink	In kitchen	Left	WF-11262024-005201	10/31/2025	FT-FY26-10172025-005201-A	<2	FT-FY26-10172025-005201-B	<2
WS- 005202	11/26/2024	11/26/2025	Basement	Food Prep Sink	In kitchen	Right	WF-11262024-005202	10/31/2025	FT-FY26-10172025-005202-A	<2	FT-FY26-10172025-005202-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.