



Military Road Learning Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005203	9/25/2023	9/25/2024	Basement	Classroom Faucet	In resource room B12	WF-09252023-005203	10/30/2023	FT-FY24-09282023-005203-A	<1	FT-FY24-09282023-005203-B	<1	
WS- 005204	5/24/2023	5/24/2024	1	Bottle Filler	In hallway adjacent to front desk	WF-05242023-005204	10/30/2023	FT-FY24-09282023-005204-A	<1	FT-FY24-09282023-005204-B	<1	
WS- 005205	5/24/2023	5/24/2024	1	Cooler	In hallway adjacent to front desk	High Left	WF-05242023-005205	10/30/2023	FT-FY24-09282023-005205-A	<1	FT-FY24-09282023-005205-B	<1
WS- 005206	5/24/2023	5/24/2024	1	Cooler	In hallway adjacent to front desk	Low Right	WF-05242023-005206	10/30/2023	FT-FY24-09282023-005206-A	<1	FT-FY24-09282023-005206-B	<1
WS- 005207	9/25/2023	9/25/2024	1	Health Suite	In health suite 128	WF-09252023-005207	10/30/2023	FT-FY24-09282023-005207-A	<1	FT-FY24-09282023-005207-B	<1	
WS- 005208	9/25/2023	9/25/2024	1	Combo Faucet	In classroom 103	WF-09252023-005208	10/30/2023	FT-FY24-09282023-005208-A	<1	FT-FY24-09282023-005208-B	<1	
WS- 005209	9/25/2023	9/25/2024	1	Combo Fountain	In classroom 103	WF-09252023-005209	10/30/2023	FT-FY24-09282023-005209-A	<1	FT-FY24-09282023-005209-B	<1	
WS- 005210	9/25/2023	9/25/2024	1	Combo Faucet	In classroom 106	WF-09252023-005210	10/30/2023	FT-FY24-09282023-005210-A	<1	FT-FY24-09282023-005210-B	<1	
WS- 005212	9/25/2023	9/25/2024	1	Combo Faucet	In classroom 121	WF-09252023-005212	10/30/2023	FT-FY24-09282023-005212-A	<1	FT-FY24-09282023-005212-B	<1	
WS- 005213	9/25/2023	9/25/2024	1	Combo Fountain	In classroom 121	WF-09252023-005213	10/30/2023	FT-FY24-09282023-005213-A	<1	FT-FY24-09282023-005213-B	<1	
WS- 005214	5/24/2023	5/24/2024	2	Cooler	In hallway adjacent to room 217	High Left	WF-05242023-005214	10/30/2023	FT-FY24-09282023-005214-A	<1	FT-FY24-09282023-005214-B	<1
WS- 005215	5/24/2023	5/24/2024	2	Cooler	In hallway adjacent to room 217	Low Right	WF-05242023-005215	10/30/2023	FT-FY24-09282023-005215-A	<1	FT-FY24-09282023-005215-B	<1
WS- 005216	9/25/2023	9/25/2024	2	Combo Faucet	In classroom 205	WF-09252023-005216	10/30/2023	FT-FY24-09282023-005216-A	<1	FT-FY24-09282023-005216-B	<1	
WS- 005217	9/25/2023	9/25/2024	2	Combo Fountain	In classroom 205	WF-09252023-005217	10/30/2023	FT-FY24-09282023-005217-A	<1	FT-FY24-09282023-005217-B	<1	
WS- 005218	9/25/2023	9/25/2024	2	Combo Faucet	In classroom 209	WF-09252023-005218	10/30/2023	FT-FY24-09282023-005218-A	<1	FT-FY24-09282023-005218-B	<1	
WS- 005220	9/25/2023	9/25/2024	2	Classroom Faucet	In classroom 218	WF-09252023-005220	10/30/2023	FT-FY24-09282023-005220-A	<1	FT-FY24-09282023-005220-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005201	1/25/2023	1/25/2024	Basement	Food Prep Sink	In kitchen	Left	WF-01252023-005201	10/30/2023	FT-FY24-09282023-005201-A	<1	FT-FY24-09282023-005201-B	<1
WS- 005202	1/25/2023	1/25/2024	Basement	Food Prep Sink	In kitchen	Right	WF-01252023-005202	10/30/2023	FT-FY24-09282023-005202-A	<1	FT-FY24-09282023-005202-B	<1