



Military Road Learning Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005200	10/5/2022	10/5/2023	Basement	Break Room	In staff lounge	WF-10052022-005200	12/30/2022	FT-FY23-11182022-005200-A	<1	FT-FY23-11182022-005200-B	<1	
WS-005203	10/5/2022	10/5/2023	Basement	Classroom Faucet	In resource room B12	WF-10052022-005203	12/30/2022	FT-FY23-11182022-005203-A	1.2	FT-FY23-11182022-005203-B	1.9	
WS-005204	6/15/2022	6/15/2023	1	Bottle Filler	In hallway adjacent to front desk	WF-06152022-005204	12/30/2022	FT-FY23-11182022-005204-A	<1	FT-FY23-11182022-005204-B	<1	
WS-005205	6/15/2022	6/15/2023	1	Cooler	In hallway adjacent to front desk	High Left	WF-06152022-005205	12/30/2022	FT-FY23-11182022-005205-A	1.1	FT-FY23-11182022-005205-B	<1
WS-005206	6/15/2022	6/15/2023	1	Cooler	In hallway adjacent to front desk	Low Right	WF-06152022-005206	12/30/2022	FT-FY23-11182022-005206-A	<1	FT-FY23-11182022-005206-B	<1
WS-005207	10/5/2022	10/5/2023	1	Health Suite	In health suite 128	WF-10052022-005207	12/30/2022	FT-FY23-11182022-005207-A	1.0	FT-FY23-11182022-005207-B	<1	
WS-005208	10/5/2022	10/5/2023	1	Combo Faucet	In classroom 103	WF-10052022-005208	12/30/2022	FT-FY23-11182022-005208-A	<1	FT-FY23-11182022-005208-B	<1	
WS-005209	10/5/2022	10/5/2023	1	Combo Fountain	In classroom 103	WF-10052022-005209	12/30/2022	FT-FY23-11182022-005209-A	1.4	FT-FY23-11182022-005209-B	<1	
WS-005210	10/5/2022	10/5/2023	1	Combo Faucet	In classroom 106	WF-10052022-005210	12/30/2022	FT-FY23-11182022-005210-A	2.7	FT-FY23-11182022-005210-B	<1	
WS-005212	10/5/2022	10/5/2023	1	Combo Faucet	In classroom 121	WF-10052022-005212	12/30/2022	FT-FY23-11182022-005212-A	2.6	FT-FY23-11182022-005212-B	<1	
WS-005214	6/15/2022	6/15/2023	2	Cooler	In hallway adjacent to room 217	High Left	WF-06152022-005214	12/30/2022	FT-FY23-11182022-005214-A	<1	FT-FY23-11182022-005214-B	<1
WS-005215	6/15/2022	6/15/2023	2	Cooler	In hallway adjacent to room 217	Low Right	WF-06152022-005215	12/30/2022	FT-FY23-11182022-005215-A	<1	FT-FY23-11182022-005215-B	<1
WS-005216	10/5/2022	10/5/2023	2	Combo Faucet	In classroom 205	WF-10052022-005216	12/30/2022	FT-FY23-11182022-005216-A	<1	FT-FY23-11182022-005216-B	<1	
WS-005217	10/5/2022	10/5/2023	2	Combo Fountain	In classroom 205	WF-10052022-005217	12/30/2022	FT-FY23-11182022-005217-A	1.0	FT-FY23-11182022-005217-B	<1	
WS-005218	10/5/2022	10/5/2023	2	Combo Faucet	In classroom 209	WF-10052022-005218	12/30/2022	FT-FY23-11182022-005218-A	<1	FT-FY23-11182022-005218-B	<1	
WS-005219	10/5/2022	10/5/2023	2	Combo Fountain	In classroom 209	WF-10052022-005219	12/30/2022	FT-FY23-11182022-005219-A	<1	FT-FY23-11182022-005219-B	<1	
WS-005220	10/5/2022	10/5/2023	2	Classroom Faucet	In classroom 218	WF-10052022-005220	12/30/2022	FT-FY23-11182022-005220-A	1.1	FT-FY23-11182022-005220-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005201	6/15/2022	6/15/2023	Basement	Food Prep Sink	In kitchen	Left	WF-06152022-005201	12/30/2022	FT-FY23-11182022-005201-A	3.5	FT-FY23-11182022-005201-B	<1
WS-005202	6/15/2022	6/15/2023	Basement	Food Prep Sink	In kitchen	Right	WF-06152022-005202	12/30/2022	FT-FY23-11182022-005202-A	3.7	FT-FY23-11182022-005202-B	3.9

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005213	10/5/2022	10/5/2023	1	Combo Fountain	In classroom 121	WF-10052022-005213	12/30/2022	FT-FY23-11182022-005213-A	7.1	FT-FY23-11182022-005213-B	1.3

First Re-test (After Plumbing Check)

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005213	1/19/2023	1/19/2024	1	Combo Fountain	In classroom 121	WF-01192023-005213	1/27/2023	FT-FY23-01232023-005213-A	<1	FT-FY23-01232023-005213-B	<1