



Miner Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000257	3/9/2021	3/9/2022	1	Break Room	In cafeteria staff lounge	WF-03092021-000257	2/22/2022	FT-FY22-12292021-000257-A	<1	FT-FY22-12292021-000257-B	<1
WS-000258	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 101 Left	WF-09062021-000258	2/22/2022	FT-FY22-12292021-000258-A	<1	FT-FY22-12292021-000258-B	<1
WS-000259	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 103 Left	WF-03092021-000259	2/22/2022	FT-FY22-12292021-000259-A	<1	FT-FY22-12292021-000259-B	<1
WS-000260	3/9/2021	3/9/2022	1	Health Suite	In health suite	WF-03092021-000260	2/22/2022	FT-FY22-12292021-000260-A	<1	FT-FY22-12292021-000260-B	<1
WS-000261	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 103 Right	WF-09062021-000261	2/22/2022	FT-FY22-12292021-000261-A	<1	FT-FY22-12292021-000261-B	<1
WS-000262	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 101 Left	WF-03092021-000262	2/22/2022	FT-FY22-12292021-000262-A	<1	FT-FY22-12292021-000262-B	<1
WS-000263	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 105	WF-09062021-000263	2/22/2022	FT-FY22-12292021-000263-A	<1	FT-FY22-12292021-000263-B	<1
WS-000264	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 111 Left	WF-03092021-000264	2/22/2022	FT-FY22-12292021-000264-A	<1	FT-FY22-12292021-000264-B	<1
WS-000265	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 105	WF-03092021-000265	2/22/2022	FT-FY22-12292021-000265-A	<1	FT-FY22-12292021-000265-B	<1
WS-000266	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 107 Left	WF-09062021-000266	2/22/2022	FT-FY22-12292021-000266-A	<1	FT-FY22-12292021-000266-B	<1
WS-000267	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 109	WF-09062021-000267	2/22/2022	FT-FY22-12292021-000267-A	<1	FT-FY22-12292021-000267-B	<1
WS-000268	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 107 Left	WF-03092021-000268	2/22/2022	FT-FY22-12292021-000268-A	<1	FT-FY22-12292021-000268-B	<1
WS-000269	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 109	WF-03092021-000269	2/22/2022	FT-FY22-12292021-000269-A	<1	FT-FY22-12292021-000269-B	<1
WS-000270	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 117	WF-09062021-000270	2/22/2022	FT-FY22-12292021-000270-A	<1	FT-FY22-12292021-000270-B	<1
WS-000271	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 115 Left	WF-09062021-000271	2/22/2022	FT-FY22-12292021-000271-A	<1	FT-FY22-12292021-000271-B	<1
WS-000272	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 117	WF-03092021-000272	2/22/2022	FT-FY22-12292021-000272-A	<1	FT-FY22-12292021-000272-B	<1
WS-000273	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 111 Mid	WF-09062021-000273	2/22/2022	FT-FY22-12292021-000273-A	<1	FT-FY22-12292021-000273-B	<1
WS-000274	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 115 Left	WF-03092021-000274	2/22/2022	FT-FY22-12292021-000274-A	<1	FT-FY22-12292021-000274-B	<1
WS-000275	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 119	WF-09062021-000275	2/22/2022	FT-FY22-12292021-000275-A	<1	FT-FY22-12292021-000275-B	<1
WS-000276	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 119	WF-03092021-000276	2/22/2022	FT-FY22-12292021-000276-A	<1	FT-FY22-12292021-000276-B	<1
WS-000277	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 121 Right	WF-03092021-000277	2/22/2022	FT-FY22-12292021-000277-A	<1	FT-FY22-12292021-000277-B	<1
WS-000278	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 123 Left	WF-09062021-000278	2/22/2022	FT-FY22-12292021-000278-A	<1	FT-FY22-12292021-000278-B	<1
WS-000279	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 123 Left	WF-03092021-000279	2/22/2022	FT-FY22-12292021-000279-A	<1	FT-FY22-12292021-000279-B	<1
WS-000280	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 121 Mid	WF-09062021-000280	2/22/2022	FT-FY22-12292021-000280-A	<1	FT-FY22-12292021-000280-B	<1
WS-000281	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 129	WF-09062021-000281	2/22/2022	FT-FY22-12292021-000281-A	<1	FT-FY22-12292021-000281-B	<1
WS-000282	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 133 Left	WF-03092021-000282	2/22/2022	FT-FY22-12292021-000282-A	1.1	FT-FY22-12292021-000282-B	<1
WS-000283	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 129	WF-03092021-000283	2/22/2022	FT-FY22-12292021-000283-A	<1	FT-FY22-12292021-000283-B	<1
WS-000284	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 133 Mid	WF-09062021-000284	2/22/2022	FT-FY22-12292021-000284-A	<1	FT-FY22-12292021-000284-B	<1
WS-000286	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 137 Right	WF-09062021-000286	2/22/2022	FT-FY22-12292021-000286-A	<1	FT-FY22-12292021-000286-B	<1
WS-000288	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 137 Left	WF-03092021-000288	2/22/2022	FT-FY22-12292021-000288-A	<1	FT-FY22-12292021-000288-B	<1
WS-000291	3/9/2021	3/9/2022	1	Combo Fountain	In common area adjacent to room 128 Right	WF-03092021-000291	2/22/2022	FT-FY22-12292021-000291-A	<1	FT-FY22-12292021-000291-B	<1
WS-000293	3/9/2021	3/9/2022	1	Combo Fountain	In common area adjacent to room 112 Left	WF-03092021-000293	2/22/2022	FT-FY22-12292021-000293-A	<1	FT-FY22-12292021-000293-B	<1
WS-000297	3/9/2021	3/9/2022	1	Break Room	In laundry room 112 Mid	WF-03092021-000297	2/22/2022	FT-FY22-12292021-000297-A	<1	FT-FY22-12292021-000297-B	<1
WS-000300	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 127	WF-09062021-000300	2/22/2022	FT-FY22-12292021-000300-A	<1	FT-FY22-12292021-000300-B	<1
WS-000301	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 131 Right	WF-03092021-000301	2/22/2022	FT-FY22-12292021-000301-A	<1	FT-FY22-12292021-000301-B	<1

WS-000302	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 127	Left	WF-03092021-000302	2/22/2022	FT-FY22-12292021-000302-A	<1	FT-FY22-12292021-000302-B	<1
WS-000304	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 131	Mid	WF-09062021-000304	2/22/2022	FT-FY22-12292021-000304-A	<1	FT-FY22-12292021-000304-B	<1
WS-000305	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 135	Left	WF-09062021-000305	2/22/2022	FT-FY22-12292021-000305-A	<1	FT-FY22-12292021-000305-B	<1
WS-000306	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 135	Right	WF-03092021-000306	2/22/2022	FT-FY22-12292021-000306-A	<1	FT-FY22-12292021-000306-B	<1
WS-000311	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 130		WF-09062021-000311	2/22/2022	FT-FY22-12292021-000311-A	<1	FT-FY22-12292021-000311-B	<1
WS-000312	9/6/2021	9/6/2022	1	Combo Faucet	In classroom 132	Mid	WF-09062021-000312	2/22/2022	FT-FY22-12292021-000312-A	<1	FT-FY22-12292021-000312-B	<1
WS-000314	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 130		WF-03092021-000314	2/22/2022	FT-FY22-12292021-000314-A	<1	FT-FY22-12292021-000314-B	<1
WS-000317	3/9/2021	3/9/2022	1	Combo Fountain	In classroom 132	Right	WF-03092021-000317	2/22/2022	FT-FY22-12292021-000317-A	<1	FT-FY22-12292021-000317-B	<1
WS-000320	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 238	Right	WF-03092021-000320	2/22/2022	FT-FY22-12292021-000320-A	<1	FT-FY22-12292021-000320-B	<1
WS-000322	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 234	Left	WF-03092021-000322	2/22/2022	FT-FY22-12292021-000322-A	<1	FT-FY22-12292021-000322-B	<1
WS-000334	3/9/2021	3/9/2022	2	Cooler	In hallway adjacent to room 234	Left	WF-03092021-000334	2/22/2022	FT-FY22-12292021-000334-A	<1	FT-FY22-12292021-000334-B	<1
WS-000335	3/9/2021	3/9/2022	2	Cooler	In hallway adjacent to room 234	Right	WF-03092021-000335	2/22/2022	FT-FY22-12292021-000335-A	<1	FT-FY22-12292021-000335-B	<1
WS-000339	3/9/2021	3/9/2022	2	Combo Fountain	In common area adjacent to room 228	Right	WF-03092021-000339	2/22/2022	FT-FY22-12292021-000339-A	<1	FT-FY22-12292021-000339-B	<1
WS-000346	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 251	Left	WF-03092021-000346	2/22/2022	FT-FY22-12292021-000346-A	<1	FT-FY22-12292021-000346-B	<1
WS-000355	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 253	Right	WF-03092021-000355	2/22/2022	FT-FY22-12292021-000355-A	<1	FT-FY22-12292021-000355-B	<1
WS-000360	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 243	Right	WF-03092021-000360	2/22/2022	FT-FY22-12292021-000360-A	<1	FT-FY22-12292021-000360-B	<1
WS-000364	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 241	Right	WF-03092021-000364	2/22/2022	FT-FY22-12292021-000364-A	<1	FT-FY22-12292021-000364-B	<1
WS-000366	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 233	Left	WF-03092021-000366	2/22/2022	FT-FY22-12292021-000366-A	<1	FT-FY22-12292021-000366-B	<1
WS-000369	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 231	Right	WF-03092021-000369	2/22/2022	FT-FY22-12292021-000369-A	<1	FT-FY22-12292021-000369-B	<1
WS-000373	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 227	Left	WF-03092021-000373	2/22/2022	FT-FY22-12292021-000373-A	<1	FT-FY22-12292021-000373-B	<1
WS-000375	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 229	Right	WF-03092021-000375	2/22/2022	FT-FY22-12292021-000375-A	<1	FT-FY22-12292021-000375-B	<1
WS-000376	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 219	Left	WF-03092021-000376	2/22/2022	FT-FY22-12292021-000376-A	<1	FT-FY22-12292021-000376-B	<1
WS-000379	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 217	Right	WF-03092021-000379	2/22/2022	FT-FY22-12292021-000379-A	<1	FT-FY22-12292021-000379-B	<1
WS-000380	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 215	Left	WF-03092021-000380	2/22/2022	FT-FY22-12292021-000380-A	<1	FT-FY22-12292021-000380-B	<1
WS-000382	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 225	Right	WF-03092021-000382	2/22/2022	FT-FY22-12292021-000382-A	<1	FT-FY22-12292021-000382-B	<1
WS-000384	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 213	Right	WF-03092021-000384	2/22/2022	FT-FY22-12292021-000384-A	<1	FT-FY22-12292021-000384-B	<1
WS-000386	9/6/2021	9/6/2022	2	Combo Faucet	In classroom 211	Right	WF-09062021-000386	2/22/2022	FT-FY22-12292021-000386-A	<1	FT-FY22-12292021-000386-B	<1
WS-000389	3/9/2021	3/9/2022	2	Combo Fountain	In common area adjacent to room 212	Right	WF-03092021-000389	2/22/2022	FT-FY22-12292021-000389-A	<1	FT-FY22-12292021-000389-B	1.4
WS-000390	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 209		WF-03092021-000390	2/22/2022	FT-FY22-12292021-000390-A	<1	FT-FY22-12292021-000390-B	<1
WS-000391	3/9/2021	3/9/2022	2	Combo Fountain	In classroom 211	Left	WF-03092021-000391	2/22/2022	FT-FY22-12292021-000391-A	<1	FT-FY22-12292021-000391-B	<1
WS-000392	3/9/2021	3/9/2022	2	Combo Fountain	In resource room 212	Left	WF-03092021-000392	2/22/2022	FT-FY22-12292021-000392-A	<1	FT-FY22-12292021-000392-B	<1
WS-000393	9/6/2021	9/6/2022	2	Combo Faucet	In resource room 212	Right	WF-09062021-000393	2/22/2022	FT-FY22-12292021-000393-A	1.1	FT-FY22-12292021-000393-B	<1
WS-000395	9/6/2021	9/6/2022	2	Classroom Faucet	In music room 206	Right	WF-09062021-000395	2/22/2022	FT-FY22-12292021-000395-A	<1	FT-FY22-12292021-000395-B	1.1
WS-000398	3/9/2021	3/9/2022	1	Fountain	In hallway adjacent to room 136	High Right	WF-03092021-000398	2/22/2022	FT-FY22-12292021-000398-A	<1	FT-FY22-12292021-000398-B	<1
WS-000399	3/9/2021	3/9/2022	1	Fountain	In hallway adjacent to room 136	Low Left	WF-03092021-000399	2/22/2022	FT-FY22-12292021-000399-A	<1	FT-FY22-12292021-000399-B	<1
WS-000400	3/9/2021	3/9/2022	1	Fountain	In hallway adjacent to room 146	Low Left	WF-03092021-000400	2/22/2022	FT-FY22-12292021-000400-A	<1	FT-FY22-12292021-000400-B	<1
WS-000401	3/9/2021	3/9/2022	1	Fountain	In hallway adjacent to room 146	High Right	WF-03092021-000401	2/22/2022	FT-FY22-12292021-000401-A	<1	FT-FY22-12292021-000401-B	<1
WS-012573	3/9/2021	3/9/2022	1	Break Room	In work room 171		WF-03092021-012573	2/22/2022	FT-FY22-12292021-012573-A	<1	FT-FY22-12292021-012573-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000256	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door	Right	WF-02092022-000256	2/22/2022	FT-FY22-12292021-000256-A	<1	FT-FY22-12292021-000256-B	<1