



Miner ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | |
|------------|-----------------------|------------------------|-------|----------------|---|---------------------|--------------------|----------------------|----------------------------------|----------------------|----------------------------------|----|
| WS- 000256 | 7/3/2019 | 7/3/2020 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | Right | WF-07032019-000256 | 11/20/2019 | FT-FY20-112019-000256-A | <1 | FT-FY20-112019-000256-B | <1 |
| WS- 000257 | 3/27/2019 | 3/27/2020 | 1 | Break Room | In cafeteria staff lounge | | WF-03272019-000257 | 11/20/2019 | FT-FY20-112019-000257-A | <1 | FT-FY20-112019-000257-B | <1 |
| WS- 000258 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 101 | Left | WF-09232019-000258 | 11/20/2019 | FT-FY20-112019-000258-A | <1 | FT-FY20-112019-000258-B | <1 |
| WS- 000259 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 103 | Left | WF-03272019-000259 | 11/20/2019 | FT-FY20-112019-000259-A | <1 | FT-FY20-112019-000259-B | <1 |
| WS- 000260 | 3/27/2019 | 3/27/2020 | 1 | Health Suite | In health suite | | WF-03272019-000260 | 11/20/2019 | FT-FY20-112019-000260-A | <1 | FT-FY20-112019-000260-B | <1 |
| WS- 000261 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 103 | Right | WF-09232019-000261 | 11/20/2019 | FT-FY20-112019-000261-A | <1 | FT-FY20-112019-000261-B | <1 |
| WS- 000262 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 101 | Left | WF-03272019-000262 | 11/20/2019 | FT-FY20-112019-000262-A | <1 | FT-FY20-112019-000262-B | <1 |
| WS- 000263 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 105 | | WF-09232019-000263 | 11/20/2019 | FT-FY20-112019-000263-A | 2.3 | FT-FY20-112019-000263-B | <1 |
| WS- 000264 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 111 | Left | WF-03272019-000264 | 11/20/2019 | FT-FY20-112019-000264-A | <1 | FT-FY20-112019-000264-B | <1 |
| WS- 000265 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 105 | | WF-03272019-000265 | 11/20/2019 | FT-FY20-112019-000265-A | <1 | FT-FY20-112019-000265-B | <1 |
| WS- 000266 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 107 | Left | WF-09232019-000266 | 11/20/2019 | FT-FY20-112019-000266-A | <1 | FT-FY20-112019-000266-B | <1 |
| WS- 000267 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 109 | | WF-09232019-000267 | 11/20/2019 | FT-FY20-112019-000267-A | <1 | FT-FY20-112019-000267-B | <1 |
| WS- 000268 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 107 | Left | WF-03272019-000268 | 11/20/2019 | FT-FY20-112019-000268-A | <1 | FT-FY20-112019-000268-B | <1 |
| WS- 000269 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 109 | | WF-03272019-000269 | 11/20/2019 | FT-FY20-112019-000269-A | <1 | FT-FY20-112019-000269-B | <1 |
| WS- 000270 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 117 | | WF-09232019-000270 | 11/20/2019 | FT-FY20-112019-000270-A | <1 | FT-FY20-112019-000270-B | <1 |
| WS- 000271 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 115 | Left | WF-09232019-000271 | 11/20/2019 | FT-FY20-112019-000271-A | <1 | FT-FY20-112019-000271-B | <1 |
| WS- 000272 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 117 | | WF-03272019-000272 | 11/20/2019 | FT-FY20-112019-000272-A | <1 | FT-FY20-112019-000272-B | <1 |
| WS- 000273 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 111 | Mid | WF-09232019-000273 | 11/20/2019 | FT-FY20-112019-000273-A | <1 | FT-FY20-112019-000273-B | <1 |
| WS- 000274 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 115 | Left | WF-03272019-000274 | 11/20/2019 | FT-FY20-112019-000274-A | <1 | FT-FY20-112019-000274-B | <1 |
| WS- 000275 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 119 | | WF-09232019-000275 | 11/20/2019 | FT-FY20-112019-000275-A | <1 | FT-FY20-112019-000275-B | <1 |
| WS- 000276 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 119 | | WF-03272019-000276 | 11/20/2019 | FT-FY20-112019-000276-A | <1 | FT-FY20-112019-000276-B | <1 |
| WS- 000277 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 121 | Right | WF-03272019-000277 | 11/20/2019 | FT-FY20-112019-000277-A | <1 | FT-FY20-112019-000277-B | <1 |
| WS- 000278 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 123 | Left | WF-09232019-000278 | 11/20/2019 | FT-FY20-112019-000278-A | <1 | FT-FY20-112019-000278-B | <1 |
| WS- 000279 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 123 | Left | WF-03272019-000279 | 11/20/2019 | FT-FY20-112019-000279-A | <1 | FT-FY20-112019-000279-B | <1 |
| WS- 000280 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 121 | Mid | WF-09232019-000280 | 11/20/2019 | FT-FY20-112019-000280-A | <1 | FT-FY20-112019-000280-B | <1 |
| WS- 000281 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 129 | | WF-09232019-000281 | 11/20/2019 | FT-FY20-112019-000281-A | <1 | FT-FY20-112019-000281-B | <1 |
| WS- 000283 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 129 | | WF-03272019-000283 | 11/20/2019 | FT-FY20-112019-000283-A | <1 | FT-FY20-112019-000283-B | <1 |
| WS- 000284 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 133 | Mid | WF-09232019-000284 | 11/20/2019 | FT-FY20-112019-000284-A | 1.5 | FT-FY20-112019-000284-B | <1 |
| WS- 000286 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 137 | Right | WF-09232019-000286 | 11/20/2019 | FT-FY20-112019-000286-A | <1 | FT-FY20-112019-000286-B | <1 |
| WS- 000288 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 137 | Left | WF-03272019-000288 | 11/20/2019 | FT-FY20-112019-000288-A | <1 | FT-FY20-112019-000288-B | <1 |
| WS- 000291 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In common area adjacent to room 128 | Right | WF-03272019-000291 | 11/20/2019 | FT-FY20-112019-000291-A | <1 | FT-FY20-112019-000291-B | <1 |
| WS- 000293 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In common area adjacent to room 112 | Left | WF-03272019-000293 | 11/20/2019 | FT-FY20-112019-000293-A | <1 | FT-FY20-112019-000293-B | <1 |
| WS- 000297 | 3/27/2019 | 3/27/2020 | 1 | Break Room | In laundry room 112 | Mid | WF-03272019-000297 | 11/20/2019 | FT-FY20-112019-000297-A | <1 | FT-FY20-112019-000297-B | <1 |
| WS- 000300 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 127 | | WF-09232019-000300 | 11/20/2019 | FT-FY20-112019-000300-A | <1 | FT-FY20-112019-000300-B | <1 |
| WS- 000301 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 131 | Right | WF-03272019-000301 | 11/20/2019 | FT-FY20-112019-000301-A | <1 | FT-FY20-112019-000301-B | <1 |

| | | | | | | | | | | | | |
|-----------|-----------|-----------|---|------------------|---|------------|--------------------|------------|-------------------------|-----|-------------------------|----|
| WS-000302 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 127 | Left | WF-03272019-000302 | 11/20/2019 | FT-FY20-112019-000302-A | <1 | FT-FY20-112019-000302-B | <1 |
| WS-000304 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 131 | Mid | WF-09232019-000304 | 11/20/2019 | FT-FY20-112019-000304-A | <1 | FT-FY20-112019-000304-B | <1 |
| WS-000305 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 135 | Left | WF-09232019-000305 | 11/20/2019 | FT-FY20-112019-000305-A | 1.3 | FT-FY20-112019-000305-B | <1 |
| WS-000306 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 135 | Right | WF-03272019-000306 | 11/20/2019 | FT-FY20-112019-000306-A | <1 | FT-FY20-112019-000306-B | <1 |
| WS-000311 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 130 | | WF-09232019-000311 | 11/20/2019 | FT-FY20-112019-000311-A | <1 | FT-FY20-112019-000311-B | <1 |
| WS-000312 | 9/23/2019 | 9/23/2020 | 1 | Combo Faucet | In classroom 132 | Mid | WF-09232019-000312 | 11/20/2019 | FT-FY20-112019-000312-A | 3 | FT-FY20-112019-000312-B | <1 |
| WS-000314 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 130 | | WF-03272019-000314 | 11/20/2019 | FT-FY20-112019-000314-A | <1 | FT-FY20-112019-000314-B | <1 |
| WS-000317 | 3/27/2019 | 3/27/2020 | 1 | Combo Fountain | In classroom 132 | Right | WF-03272019-000317 | 11/20/2019 | FT-FY20-112019-000317-A | <1 | FT-FY20-112019-000317-B | <1 |
| WS-000320 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 238 | Right | WF-03272019-000320 | 11/20/2019 | FT-FY20-112019-000320-A | 1.6 | FT-FY20-112019-000320-B | <1 |
| WS-000322 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 234 | Left | WF-03272019-000322 | 11/20/2019 | FT-FY20-112019-000322-A | <1 | FT-FY20-112019-000322-B | <1 |
| WS-000334 | 5/9/2019 | 5/9/2020 | 2 | Cooler | In hallway adjacent to room 234 | Left | WF-05092019-000334 | 11/20/2019 | FT-FY20-112019-000334-A | <1 | FT-FY20-112019-000334-B | <1 |
| WS-000335 | 5/9/2019 | 5/9/2020 | 2 | Cooler | In hallway adjacent to room 234 | Right | WF-05092019-000335 | 11/20/2019 | FT-FY20-112019-000335-A | <1 | FT-FY20-112019-000335-B | <1 |
| WS-000339 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In common area adjacent to room 228 | Right | WF-03272019-000339 | 11/20/2019 | FT-FY20-112019-000339-A | <1 | FT-FY20-112019-000339-B | <1 |
| WS-000346 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 251 | Left | WF-03272019-000346 | 11/20/2019 | FT-FY20-112019-000346-A | <1 | FT-FY20-112019-000346-B | <1 |
| WS-000355 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 253 | Right | WF-03272019-000355 | 11/20/2019 | FT-FY20-112019-000355-A | <1 | FT-FY20-112019-000355-B | <1 |
| WS-000358 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 249 | Right | WF-03272019-000358 | 11/20/2019 | FT-FY20-112019-000358-A | <1 | FT-FY20-112019-000358-B | <1 |
| WS-000360 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 243 | Right | WF-03272019-000360 | 11/20/2019 | FT-FY20-112019-000360-A | <1 | FT-FY20-112019-000360-B | <1 |
| WS-000364 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 241 | Right | WF-03272019-000364 | 11/20/2019 | FT-FY20-112019-000364-A | <1 | FT-FY20-112019-000364-B | <1 |
| WS-000366 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 233 | Left | WF-03272019-000366 | 11/20/2019 | FT-FY20-112019-000366-A | <1 | FT-FY20-112019-000366-B | <1 |
| WS-000369 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 231 | Right | WF-03272019-000369 | 11/20/2019 | FT-FY20-112019-000369-A | <1 | FT-FY20-112019-000369-B | <1 |
| WS-000373 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 227 | Left | WF-03272019-000373 | 11/20/2019 | FT-FY20-112019-000373-A | <1 | FT-FY20-112019-000373-B | <1 |
| WS-000375 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 229 | Right | WF-03272019-000375 | 11/20/2019 | FT-FY20-112019-000375-A | <1 | FT-FY20-112019-000375-B | <1 |
| WS-000376 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 219 | Left | WF-03272019-000376 | 11/20/2019 | FT-FY20-112019-000376-A | <1 | FT-FY20-112019-000376-B | <1 |
| WS-000378 | 3/27/2019 | 3/27/2020 | 2 | Combo Faucet | In classroom 217 | Left | WF-03272019-000378 | 11/20/2019 | FT-FY20-112019-000378-A | <1 | FT-FY20-112019-000378-B | <1 |
| WS-000379 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 217 | Right | WF-03272019-000379 | 11/20/2019 | FT-FY20-112019-000379-A | <1 | FT-FY20-112019-000379-B | <1 |
| WS-000380 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 215 | Left | WF-03272019-000380 | 11/20/2019 | FT-FY20-112019-000380-A | <1 | FT-FY20-112019-000380-B | <1 |
| WS-000382 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 225 | Right | WF-03272019-000382 | 11/20/2019 | FT-FY20-112019-000382-A | <1 | FT-FY20-112019-000382-B | <1 |
| WS-000384 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 213 | Right | WF-03272019-000384 | 11/20/2019 | FT-FY20-112019-000384-A | <1 | FT-FY20-112019-000384-B | <1 |
| WS-000386 | 9/23/2019 | 9/23/2020 | 2 | Combo Faucet | In classroom 211 | Right | WF-09232019-000386 | 11/20/2019 | FT-FY20-112019-000386-A | 2.1 | FT-FY20-112019-000386-B | <1 |
| WS-000389 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In common area adjacent to room 212 | Right | WF-03272019-000389 | 11/20/2019 | FT-FY20-112019-000389-A | 1.2 | FT-FY20-112019-000389-B | <1 |
| WS-000390 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 209 | | WF-03272019-000390 | 11/20/2019 | FT-FY20-112019-000390-A | <1 | FT-FY20-112019-000390-B | <1 |
| WS-000391 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In classroom 211 | Left | WF-03272019-000391 | 11/20/2019 | FT-FY20-112019-000391-A | <1 | FT-FY20-112019-000391-B | <1 |
| WS-000392 | 3/27/2019 | 3/27/2020 | 2 | Combo Fountain | In resource room 212 | Left | WF-03272019-000392 | 11/20/2019 | FT-FY20-112019-000392-A | <1 | FT-FY20-112019-000392-B | <1 |
| WS-000393 | 9/23/2019 | 9/23/2020 | 2 | Combo Faucet | In resource room 212 | Right | WF-09232019-000393 | 11/20/2019 | FT-FY20-112019-000393-A | 2.5 | FT-FY20-112019-000393-B | <1 |
| WS-000394 | 8/26/2019 | 8/26/2020 | 2 | Fountain | In hallway, adjacent to girls restroom and room 206 | | WF-08262019-000394 | 11/20/2019 | FT-FY20-112019-000394-A | <1 | FT-FY20-112019-000394-B | <1 |
| WS-000395 | 9/23/2019 | 9/23/2020 | 2 | Classroom Faucet | In music room 206 | Right | WF-09232019-000395 | 11/20/2019 | FT-FY20-112019-000395-A | <1 | FT-FY20-112019-000395-B | <1 |
| WS-000398 | 3/27/2019 | 3/27/2020 | 1 | Fountain | In hallway adjacent to room 136 | High Right | WF-03272019-000398 | 11/20/2019 | FT-FY20-112019-000398-A | <1 | FT-FY20-112019-000398-B | <1 |
| WS-000399 | 3/27/2019 | 3/27/2020 | 1 | Fountain | In hallway adjacent to room 136 | Low Left | WF-03272019-000399 | 11/20/2019 | FT-FY20-112019-000399-A | <1 | FT-FY20-112019-000399-B | <1 |
| WS-000400 | 3/27/2019 | 3/27/2020 | 1 | Fountain | In hallway adjacent to room 146 | Low Left | WF-03272019-000400 | 11/20/2019 | FT-FY20-112019-000400-A | <1 | FT-FY20-112019-000400-B | <1 |
| WS-000401 | 3/27/2019 | 3/27/2020 | 1 | Fountain | In hallway adjacent to room 146 | High Right | WF-03272019-000401 | 11/20/2019 | FT-FY20-112019-000401-A | <1 | FT-FY20-112019-000401-B | <1 |
| WS-012573 | 3/27/2019 | 3/27/2020 | 1 | Break Room | In work room 171 | | WF-03272019-012573 | 11/20/2019 | FT-FY20-112019-012573-A | <1 | FT-FY20-112019-012573-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|---|-------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 000256 | 7/3/2019 | 7/3/2020 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | Right | WF-07032019-000256 | 11/20/2019 | FT-FY20-112019-000256-A | <1 | FT-FY20-112019-000256-B | <1 |