



MINER LEAD WATER TEST RESULTS

May 10th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
1	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000409	Classroom	2	Second floor instrumental room 200	WT-042916-426- A	4.79	WT-042916-426- B	5.68		
2	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000408	Classroom	2	Second floor in science/computer lab fifth sink clockwise from southeast door	Mid	WT-042916-425- A	2.11	WT-042916-425- B	9.31	
3	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000407	Classroom	2	Second floor in science/computer lab forth sink clockwise from southeast door	Right	WT-042916-424- A	< 1	WT-042916-424- B	< 1	
4	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000406	Classroom	2	Second floor in science/computer lab third sink clockwise from southeast door	Left	WT-042916-423- A	11	WT-042916-423- B	< 1	
5	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000405	Classroom	2	Second floor in science/computer lab second sink clockwise from southeast door	Right	WT-042916-422- A	8.59	WT-042916-422- B	1.07	
6	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000404	Classroom	2	Second floor in science/computer lab first sink clockwise from southeast door	Left	WT-042916-421- A	2.67	WT-042916-421- B	< 1	
7	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000403	Fountain	1	First floor in play room 106	Right	WT-042816-420- A	3.79	WT-042816-420- B	< 1	
8	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000402	Classroom	1	First floor in play room 106	Right	WT-042816-419- A	496	WT-042816-419- B	17.7	Filter will be installed and then retested
9	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000401	Fountain	1	First floor in hallway adjacent to resource room 146	Right High	WT-042816-418- A	< 1	WT-042816-418- B	< 1	
10	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000400	Fountain	1	First floor in hallway adjacent to resource 146	Left Low	WT-042816-417- A	< 1	WT-042816-417- B	< 1	
11	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000399	Fountain	1	First floor in hallway adjacent to resource room 136	Left Low	WT-042816-416- A	< 1	WT-042816-416- B	< 1	
12	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000398	Fountain	1	First floor in hallway adjacent to research room 136	Right High	WT-042816-415- A	< 1	WT-042816-415- B	< 1	
13	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000397	Fountain	2	Second floor in hallway, adjacent to girls restroom and room 206	Right	WT-042816-414- A	< 1	WT-042816-414- B	< 1	
14	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000396	Other	2	Second floor in hallway, adjacent to girls restroom and room 206	Mid	WT-042816-413- A	< 1	WT-042816-413- B	< 1	
15	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000395	Classroom	2	Second floor in music room 206	Right	WT-042816-412- A	3.75	WT-042816-412- B	< 1	
16	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000394	Fountain	2	Second floor in hallway, adjacent to girls restroom and room 206	Left	WT-042816-411- A	< 1	WT-042816-411- B	< 1	
17	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000393	Other	2	Second floor in resource room 212 (sink)	Right	WT-042816-410- A	1.13	WT-042816-410- B	< 1	
18	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000392	Fountain	2	Second floor in resource room 212	Left	WT-042816-409- A	< 1	WT-042816-409- B	< 1	
19	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000391	Fountain	2	Second floor in classroom 211	Left	WT-042816-408- A	< 1	WT-042816-408- B	< 1	
20	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000390	Fountain	2	Second floor in class room 209	Left	WT-042816-407- A	< 1	WT-042816-407- B	< 1	
21	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000389	Fountain	2	Second floor in common area next to 212 resource	Right	WT-042816-406- A	< 1	WT-042816-406- B	< 1	
22	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000388	Classroom	2	Second floor in class room 209	Left	WT-042816-405- A	< 1	WT-042816-405- B	< 1	
23	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000387	Other	2	Second floor in common area next to 212 resource (sink)	Left	WT-042816-404- A	7.14	WT-042816-404- B	< 1	
24	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000386	Classroom	2	Second floor in classroom 211	Right	WT-042816-403- A	< 1	WT-042816-403- B	< 1	
25	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000385	Classroom	2	Second floor in class room 215	Left	WT-042816-402- A	< 1	WT-042816-402- B	< 1	
26	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000384	Fountain	2	Second floor in classroom 213	Right	WT-042816-401- A	< 1	WT-042816-401- B	< 1	
27	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000383	Classroom	2	Second floor in classroom 213	Left	WT-042816-400- A	< 1	WT-042816-400- B	< 1	
28	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000382	Fountain	2	Second floor in classroom 225	Right	WT-042816-399- A	< 1	WT-042816-399- B	< 1	
29	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000381	Classroom	2	Second floor in class room 225	Left	WT-042816-398- A	< 1	WT-042816-398- B	< 1	
30	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000380	Fountain	2	Second floor in classroom 215	Left	WT-042816-397- A	< 1	WT-042816-397- B	< 1	
31	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000379	Fountain	2	Second floor in classroom 217	Right	WT-042816-396- A	< 1	WT-042816-396- B	< 1	
32	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000378	Classroom	2	Second floor in classroom 217	Left	WT-042816-395- A	< 1	WT-042816-395- B	< 1	
33	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000377	Classroom	2	Second floor in classroom 219	Right	WT-042816-394- A	< 1	WT-042816-394- B	< 1	
34	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000376	Fountain	2	Second floor in classroom 219	Left	WT-042816-393- A	< 1	WT-042816-393- B	< 1	
35	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000375	Fountain	2	Second floor in classroom 229	Right	WT-042816-392- A	2.04	WT-042816-392- B	< 1	
36	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000374	Classroom	2	Second floor in classroom 227	Left	WT-042816-391- A	< 1	WT-042816-391- B	< 1	
37	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000373	Fountain	2	Second floor in classroom 227	Left	WT-042816-390- A	< 1	WT-042816-390- B	< 1	
38	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000370	Classroom	2	Second floor in classroom 229	Left	WT-042816-387- A	24.7	WT-042816-387- B	36	Filter will be installed and then retested
39	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000369	Fountain	2	Second floor in class room 231	Right	WT-042816-386- A	< 1	WT-042816-386- B	< 1	
40	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000368	Classroom	2	Second floor in classroom 231	Left	WT-042816-385- A	< 1	WT-042816-385- B	< 1	
41	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000367	Classroom	2	Second floor in classroom 233	Right	WT-042816-384- A	< 1	WT-042816-384- B	< 1	
42	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000366	Fountain	2	Second floor in class room 233	Left	WT-042816-383- A	< 1	WT-042816-383- B	< 1	
43	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000364	Fountain	2	Second floor in classroom 241	Right	WT-042816-381- A	< 1	WT-042816-381- B	< 1	
44	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000362	Classroom	2	Second floor in classroom 241	Left	WT-042816-379- A	< 1	WT-042816-379- B	< 1	
45	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000360	Fountain	2	Second floor in class room 243	Right	WT-042816-377- A	< 1	WT-042816-377- B	< 1	



MINER LEAD WATER TEST RESULTS

May 10th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^a	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^b	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
46	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000359	Classroom	2	Second floor in class room 243	Mid	WT-042816-376- A	< 1	WT-042816-376- B	< 1	
47	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000358	Fountain	2	Second floor in classroom 249	Right	WT-042816-375- A	< 1	WT-042816-375- B	< 1	
48	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000357	Classroom	2	Second floor in classroom 249	Left	WT-042816-374- A	1.29	WT-042816-374- B	< 1	
49	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000355	Fountain	2	Second floor in classroom 253	Right	WT-042816-372- A	< 1	WT-042816-372- B	< 1	
50	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000352	Classroom	2	Second floor in classroom 253	Mid	WT-042816-369- A	1.04	WT-042816-369- B	< 1	
51	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000349	Classroom	2	Second floor in classroom 251	Mid	WT-042816-366- A	1.1	WT-042816-366- B	< 1	
52	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000346	Fountain	2	Second floor in classroom 251	Left	WT-042816-363- A	< 1	WT-042816-363- B	< 1	
53	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000342	Fountain	2	Second floor in hallway adjacent to room 234	Mid	WT-042816-359- A	< 1	WT-042816-359- B	< 1	
54	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000341	Classroom	2	Second floor in art room 255	Right	WT-042816-358- A	< 1	WT-042816-358- B	< 1	
55	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000339	Fountain	2	Second floor, in common area adjacent to room 228	Right	WT-042816-356- A	< 1	WT-042816-356- B	< 1	
56	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000338	Classroom	2	Second floor in art room 255	Left	WT-042816-355- A	< 1	WT-042816-355- B	< 1	
57	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000335	Fountain	2	Second floor in hallway adjacent to room 234	Right	WT-042816-352- A	< 1	WT-042816-352- B	< 1	
58	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000334	Fountain	2	Second floor, in hallway adjacent to room 234	Left	WT-042816-351- A	< 1	WT-042816-351- B	7.57	
59	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000332	Other	2	Second floor in common area adjacent to room 228 (sink)	Left	WT-042816-349- A	< 1	WT-042816-349- B	< 1	
60	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000328	Other	2	Second floor planning room 228	Mid	WT-042816-345- A	< 1	WT-042816-345- B	< 1	
61	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000326	Classroom	2	Second floor in classroom 234	Mid	WT-042816-343- A	2.66	WT-042816-343- B	< 1	
62	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000322	Fountain	2	Second floor in classroom 234	Left	WT-042816-339- A	< 1	WT-042816-339- B	< 1	
63	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000320	Fountain	2	Second floor in classroom 238	Right	WT-042816-337- A	< 1	WT-042816-337- B	1.45	
64	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000319	Classroom	2	Second floor in classroom 238	Left	WT-042816-336- A	13.9	WT-042816-336- B	< 1	
65	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000317	Fountain	1	First floor in class room 132	Right	WT-042816-334- A	< 1	WT-042816-334- B	< 1	
66	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000314	Fountain	1	First floor in class room 130	Left	WT-042816-331- A	< 1	WT-042816-331- B	< 1	
67	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000312	Classroom	1	First floor in class room 132	Mid	WT-042816-329- A	< 1	WT-042816-329- B	< 1	
68	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000311	Classroom	1	First floor in class room 130	Left	WT-042816-328- A	1.5	WT-042816-328- B	< 1	
69	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000306	Fountain	1	First floor in classroom 135	Right	WT-042816-323- A	< 1	WT-042816-323- B	< 1	
70	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000305	Classroom	1	First floor in classroom 135	Left	WT-042816-322- A	< 1	WT-042816-322- B	< 1	
71	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000304	Classroom	1	First floor in classroom 131	Mid	WT-042816-321- A	< 1	WT-042816-321- B	< 1	
72	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000302	Classroom	1	First floor in class room 127	Left	WT-042816-319- A	< 1	WT-042816-319- B	< 1	
73	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000301	Fountain	1	First floor in class room 131	Right	WT-042816-318- A	< 1	WT-042816-318- B	< 1	
74	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000300	Classroom	1	First floor in class room 127	Left	WT-042816-317- A	< 1	WT-042816-317- B	< 1	
75	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000297	Kitchen	1	First floor in kitchen room 112	Mid	WT-042816-314- A	1.03	WT-042816-314- B	< 1	
76	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000295	Other	1	First floor in common area adjacent kitchen/ laundry room 112	Mid	WT-042816-312- A	< 1	WT-042816-312- B	8.84	
77	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000293	Fountain	1	First floor in common area adjacent kitchen/laundry 112	Left	WT-042816-310- A	< 1	WT-042816-310- B	5.17	
78	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000292	Other	1	First floor in common area adjacent to room 128 (sink)	Mid	WT-042816-309- A	2.24	WT-042816-309- B	1.6	
79	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000291	Fountain	1	First floor in common area adjacent to room 128	Right	WT-042816-308- A	< 1	WT-042816-308- B	< 1	
80	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000290	Classroom	1	First floor in planning room 128	Right	WT-042816-307- A	< 1	WT-042816-307- B	1.9	
81	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000288	Fountain	1	First floor in class room 137	Left	WT-042816-305- A	< 1	WT-042816-305- B	< 1	
82	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000287	Classroom	1	First floor in class room 143	Left	WT-042816-304- A	2.23	WT-042816-304- B	3.82	
83	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000286	Classroom	1	First floor in class room 137	Right	WT-042816-303- A	< 1	WT-042816-303- B	< 1	
84	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000284	Classroom	1	First floor in class room 133	Mid	WT-042816-301- A	< 1	WT-042816-301- B	< 1	
85	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000283	Fountain	1	First floor in class room 129	Left	WT-042816-300- A	< 1	WT-042816-300- B	< 1	
86	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000282	Fountain	1	First floor in class room 133	Left	WT-042816-299- A	< 1	WT-042816-299- B	< 1	
87	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000281	Classroom	1	First floor in class room 129	Left	WT-042816-298- A	< 1	WT-042816-298- B	< 1	
88	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000280	Classroom	1	First floor in class room 121	Mid	WT-042816-297- A	< 1	WT-042816-297- B	< 1	
89	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000279	Fountain	1	First floor in classroom 123	Left	WT-042816-296- A	< 1	WT-042816-296- B	< 1	
90	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000278	Classroom	1	First floor in classroom 123	Left	WT-042816-295- A	< 1	WT-042816-295- B	< 1	
91	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000277	Fountain	1	First floor in class room 121	Right	WT-042816-294- A	< 1	WT-042816-294- B	< 1	
92	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000276	Fountain	1	First floor in class room 119	Left	WT-042816-293- A	< 1	WT-042816-293- B	< 1	
93	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000275	Classroom	1	First floor in class room 119	Left	WT-042816-292- A	< 1	WT-042816-292- B	< 1	
94	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000274	Fountain	1	First floor in classroom 115	Left	WT-042816-291- A	< 1	WT-042816-291- B	< 1	
95	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000273	Classroom	1	First floor in class room 111	Mid	WT-042816-290- A	< 1	WT-042816-290- B	< 1	
96	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000272	Fountain	1	First floor in class room 117	Left	WT-042816-289- A	< 1	WT-042816-289- B	< 1	
97	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000271	Classroom	1	First floor in classroom 115	Left	WT-042816-288- A	< 1	WT-042816-288- B	< 1	
98	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000270	Classroom	1	First floor in class room 117	Left	WT-042816-287- A	< 1	WT-042816-287- B	< 1	
99	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000269	Fountain	1	First floor in class room 109	Left	WT-042816-286- A	< 1	WT-042816-286- B	< 1	



MINER LEAD WATER TEST RESULTS

May 10th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
100	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000268	Fountain	1	First floor in classroom 107	Left	WT-042816-285- A	< 1	WT-042816-285- B	< 1	
101	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000267	Classroom	1	First floor in class room 109		WT-042816-284- A	< 1	WT-042816-284- B	< 1	
102	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000266	Classroom	1	First floor in classroom 107	Left	WT-042816-283- A	< 1	WT-042816-283- B	< 1	
103	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000265	Fountain	1	First floor in room 105		WT-042816-282- A	< 1	WT-042816-282- B	< 1	
104	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000264	Fountain	1	First floor in class room 111	Left	WT-042816-281- A	< 1	WT-042816-281- B	< 1	
105	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000263	Classroom	1	First floor in room 105		WT-042816-280- A	< 1	WT-042816-280- B	< 1	
106	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000262	Fountain	1	First floor in classroom 101	Left	WT-042816-279- A	< 1	WT-042816-279- B	< 1	
107	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000261	Classroom	1	First floor in class room 103	Right	WT-042816-278- A	< 1	WT-042816-278- B	< 1	
108	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000260	Health Suite	1	First floor in health suite		WT-042816-277- A	< 1	WT-042816-277- B	< 1	
109	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000259	Fountain	1	First floor in class room 103	Left	WT-042816-276- A	< 1	WT-042816-276- B	< 1	
110	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000258	Classroom	1	First floor in classroom 101	Left	WT-042816-275- A	< 1	WT-042816-275- B	< 1	
111	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000257	Break Room	1	First floor in staff lounge south wall		WT-042816-274- A	< 1	WT-042816-274- B	< 1	
112	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000256	Kitchen	1	First floor in kitchen west wall	Right	WT-042816-273- A	< 1	WT-042816-273- B	< 1	
113	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000255	Kitchen	1	First floor in kitchen west wall	Mid	WT-042816-272- A	< 1	WT-042816-272- B	< 1	
114	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000254	Kitchen	1	First floor kitchen west wall (single handwash sink) right corner		WT-042816-271- A	< 1	WT-042816-271- B	< 1	
115	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000253	Kitchen	1	First floor kitchen (spray nozzle)	Left	WT-042816-270- A	1.18	WT-042816-270- B	< 1	
116	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000252	Kitchen	1	First floor in kitchen south wall		WT-042816-269- A	1.05	WT-042816-269- B	< 1	
117	MINER ELEMENTARY SCHOOL	4/29/2016	WS- 000251	Utility	1	First floor in mechanical room east wall water source point		WT-042816-268- A	74.9	WT-042816-268- B	3.11	Non-drinking water source - Not accessible to children

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.