



Miner ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000259	5/17/2017	5/17/2018	1	Combo Fountain	In classroom 103	Left	WF-52017-000259	11/14/2017	FT-FY18--52017-000259-A	<1	FT-FY18--52017-000259-B	<1
WS-000261	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 103	Right	WF-102017-000261	11/14/2017	FT-FY18-102017-000261-A	<1	FT-FY18-102017-000261-B	<1
WS-000265	5/17/2017	5/17/2018	1	Combo Fountain	In classroom 105		WF-52017-000265	11/14/2017	FT-FY18--52017-000265-A	<1	FT-FY18--52017-000265-B	<1
WS-000267	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 109		WF-102017-000267	11/14/2017	FT-FY18-102017-000267-A	<1	FT-FY18-102017-000267-B	<1
WS-000271	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 115	Left	WF-102017-000271	11/14/2017	FT-FY18-102017-000271-A	<1	FT-FY18-102017-000271-B	<1
WS-000272	5/17/2017	5/17/2018	1	Combo Fountain	In classroom 117		WF-52017-000272	11/14/2017	FT-FY18--52017-000272-A	<1	FT-FY18--52017-000272-B	<1
WS-000274	5/17/2017	5/17/2018	1	Combo Fountain	In classroom 115	Left	WF-52017-000274	11/14/2017	FT-FY18--52017-000274-A	<1	FT-FY18--52017-000274-B	<1
WS-000278	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 123	Left	WF-102017-000278	11/14/2017	FT-FY18-102017-000278-A	<1	FT-FY18-102017-000278-B	<1
WS-000280	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 121	Mid	WF-102017-000280	11/14/2017	FT-FY18-102017-000280-A	<1	FT-FY18-102017-000280-B	<1
WS-000286	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 137	Right	WF-102017-000286	11/14/2017	FT-FY18-102017-000286-A	<1	FT-FY18-102017-000286-B	<1
WS-000291	5/17/2017	5/17/2018	1	Combo Fountain	In common area adjacent to room 128	Right	WF-52017-000291	11/14/2017	FT-FY18--52017-000291-A	<1	FT-FY18--52017-000291-B	<1
WS-000293	5/17/2017	5/17/2018	1	Combo Fountain	In common area adjacent to room 112	Left	WF-52017-000293	11/14/2017	FT-FY18--52017-000293-A	<1	FT-FY18--52017-000293-B	<1
WS-000304	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 131	Mid	WF-102017-000304	11/14/2017	FT-FY18-102017-000304-A	<1	FT-FY18-102017-000304-B	<1
WS-000312	10/26/2017	10/26/2018	1	Combo Faucet	In classroom 132	Mid	WF-102017-000312	11/14/2017	FT-FY18-102017-000312-A	<1	FT-FY18-102017-000312-B	<1
WS-000314	5/17/2017	5/17/2018	1	Combo Fountain	In classroom 130		WF-52017-000314	11/14/2017	FT-FY18--52017-000314-A	<1	FT-FY18--52017-000314-B	<1
WS-000335	5/18/2017	5/18/2018	2	Cooler	In hallway adjacent to room 234	Right	WF-52017-000335	11/14/2017	FT-FY18--52017-000335-A	<1	FT-FY18--52017-000335-B	<1
WS-000346	5/17/2017	5/17/2018	2	Combo Fountain	In classroom 251	Left	WF-52017-000346	11/14/2017	FT-FY18--52017-000346-A	<1	FT-FY18--52017-000346-B	<1
WS-000358	5/17/2017	5/17/2018	2	Combo Fountain	In classroom 249	Right	WF-52017-000358	11/14/2017	FT-FY18--52017-000358-A	<1	FT-FY18--52017-000358-B	<1
WS-000366	5/17/2017	5/17/2018	2	Combo Fountain	In classroom 233	Left	WF-52017-000366	11/14/2017	FT-FY18--52017-000366-A	<1	FT-FY18--52017-000366-B	<1
WS-000376	5/17/2017	5/17/2018	2	Combo Fountain	In classroom 219	Left	WF-52017-000376	11/14/2017	FT-FY18--52017-000376-A	<1	FT-FY18--52017-000376-B	<1
WS-000386	10/26/2017	10/26/2018	2	Combo Faucet	In classroom 211	Right	WF-102017-000386	11/14/2017	FT-FY18-102017-000386-A	<1	FT-FY18-102017-000386-B	<1
WS-000391	5/17/2017	5/17/2018	2	Combo Fountain	In classroom 211	Left	WF-52017-000391	11/14/2017	FT-FY18--52017-000391-A	<1	FT-FY18--52017-000391-B	<1
WS-000393	10/26/2017	10/26/2018	2	Combo Faucet	In resource room 212	Right	WF-102017-000393	11/14/2017	FT-FY18-102017-000393-A	<1	FT-FY18-102017-000393-B	<1
WS-000397	5/18/2017	5/18/2018	2	Fountain	In hallway adjacent to room 206	Right	WF-52017-000397	11/14/2017	FT-FY18--52017-000397-A	<1	FT-FY18--52017-000397-B	<1
WS-000401	5/17/2017	5/17/2018	1	Fountain	In hallway adjacent to room 146	Right High	WF-52017-000401	11/14/2017	FT-FY18--52017-000401-A	<1	FT-FY18--52017-000401-B	<1
WS-012573	5/17/2017	5/17/2018	1	Break Room	In work room 171		WF-52017-012573	11/14/2017	FT-FY18--52017-012573-A	<1	FT-FY18--52017-012573-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS-000255	1	Food Prep Sink	In kitchen third clockwise from entry door	Mid	11/14/2017	FT-FY18-102017-000255-A	1.8	FT-FY18-102017-000255-B	<1		
WS-000256	1	Food Prep Sink	In kitchen fourth clockwise from entry door	Right	11/14/2017	FT-FY18-102017-000256-A	<1	FT-FY18-102017-000256-B	<1		