



Miner ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000257	4/5/2018	4/5/2019	1	Break Room	In cafeteria staff lounge	WF-04052018-000257	11/19/2018	FT-FY19-112018-000257-A	< 1	FT-FY19-112018-000257-B	< 1
WS-000258	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 101	WF-10022018-000258	11/19/2018	FT-FY19-112018-000258-A	< 1	FT-FY19-112018-000258-B	< 1
WS-000259	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 103	WF-04052018-000259	11/19/2018	FT-FY19-112018-000259-A	< 1	FT-FY19-112018-000259-B	< 1
WS-000260	4/5/2018	4/5/2019	1	Health Suite	In health suite	WF-04052018-000260	11/19/2018	FT-FY19-112018-000260-A	< 1	FT-FY19-112018-000260-B	< 1
WS-000261	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 103	WF-10022018-000261	11/19/2018	FT-FY19-112018-000261-A	< 1	FT-FY19-112018-000261-B	< 1
WS-000262	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 101	WF-04052018-000262	11/19/2018	FT-FY19-112018-000262-A	< 1	FT-FY19-112018-000262-B	< 1
WS-000263	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 105	WF-10022018-000263	11/19/2018	FT-FY19-112018-000263-A	< 1	FT-FY19-112018-000263-B	< 1
WS-000264	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 111	WF-04052018-000264	11/19/2018	FT-FY19-112018-000264-A	< 1	FT-FY19-112018-000264-B	< 1
WS-000265	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 105	WF-04052018-000265	11/19/2018	FT-FY19-112018-000265-A	< 1	FT-FY19-112018-000265-B	< 1
WS-000266	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 107	WF-10022018-000266	11/19/2018	FT-FY19-112018-000266-A	< 1	FT-FY19-112018-000266-B	< 1
WS-000267	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 109	WF-10022018-000267	11/19/2018	FT-FY19-112018-000267-A	< 1	FT-FY19-112018-000267-B	< 1
WS-000268	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 107	WF-04052018-000268	11/19/2018	FT-FY19-112018-000268-A	< 1	FT-FY19-112018-000268-B	< 1
WS-000269	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 109	WF-04052018-000269	11/19/2018	FT-FY19-112018-000269-A	< 1	FT-FY19-112018-000269-B	< 1
WS-000270	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 117	WF-10022018-000270	11/19/2018	FT-FY19-112018-000270-A	< 1	FT-FY19-112018-000270-B	< 1
WS-000271	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 115	WF-10022018-000271	11/19/2018	FT-FY19-112018-000271-A	< 1	FT-FY19-112018-000271-B	< 1
WS-000272	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 117	WF-04052018-000272	11/19/2018	FT-FY19-112018-000272-A	< 1	FT-FY19-112018-000272-B	< 1
WS-000273	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 111	WF-10022018-000273	11/19/2018	FT-FY19-112018-000273-A	< 1	FT-FY19-112018-000273-B	< 1
WS-000274	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 115	WF-04052018-000274	11/19/2018	FT-FY19-112018-000274-A	< 1	FT-FY19-112018-000274-B	< 1
WS-000275	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 119	WF-10022018-000275	11/19/2018	FT-FY19-112018-000275-A	< 1	FT-FY19-112018-000275-B	< 1
WS-000276	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 119	WF-04052018-000276	11/19/2018	FT-FY19-112018-000276-A	< 1	FT-FY19-112018-000276-B	< 1
WS-000277	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 121	WF-04052018-000277	11/19/2018	FT-FY19-112018-000277-A	< 1	FT-FY19-112018-000277-B	< 1
WS-000278	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 123	WF-10022018-000278	11/19/2018	FT-FY19-112018-000278-A	< 1	FT-FY19-112018-000278-B	< 1
WS-000279	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 123	WF-04052018-000279	11/19/2018	FT-FY19-112018-000279-A	< 1	FT-FY19-112018-000279-B	< 1
WS-000280	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 121	WF-10022018-000280	11/19/2018	FT-FY19-112018-000280-A	< 1	FT-FY19-112018-000280-B	< 1
WS-000281	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 129	WF-10022018-000281	11/19/2018	FT-FY19-112018-000281-A	< 1	FT-FY19-112018-000281-B	< 1
WS-000282	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 133	WF-04052018-000282	11/19/2018	FT-FY19-112018-000282-A	< 1	FT-FY19-112018-000282-B	< 1
WS-000283	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 129	WF-04052018-000283	11/19/2018	FT-FY19-112018-000283-A	< 1	FT-FY19-112018-000283-B	< 1
WS-000284	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 133	WF-10022018-000284	11/19/2018	FT-FY19-112018-000284-A	< 1	FT-FY19-112018-000284-B	< 1
WS-000286	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 137	WF-10022018-000286	11/19/2018	FT-FY19-112018-000286-A	1	FT-FY19-112018-000286-B	< 1
WS-000288	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 137	WF-04052018-000288	11/19/2018	FT-FY19-112018-000288-A	< 1	FT-FY19-112018-000288-B	< 1
WS-000291	4/5/2018	4/5/2019	1	Combo Fountain	In common area adjacent to room 128	WF-04052018-000291	11/19/2018	FT-FY19-112018-000291-A	< 1	FT-FY19-112018-000291-B	< 1
WS-000293	4/5/2018	4/5/2019	1	Combo Fountain	In common area adjacent to room 112	WF-04052018-000293	11/19/2018	FT-FY19-112018-000293-A	< 1	FT-FY19-112018-000293-B	< 1

WS- 000297	4/5/2018	4/5/2019	1	Break Room	In laundry room 112	Mid	WF-04052018-000297	11/19/2018	FT-FY19-112018-000297-A	< 1	FT-FY19-112018-000297-B	< 1
WS- 000300	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 127		WF-10022018-000300	11/19/2018	FT-FY19-112018-000300-A	< 1	FT-FY19-112018-000300-B	< 1
WS- 000301	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 131	Right	WF-04052018-000301	11/19/2018	FT-FY19-112018-000301-A	< 1	FT-FY19-112018-000301-B	< 1
WS- 000302	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 127	Left	WF-04052018-000302	11/19/2018	FT-FY19-112018-000302-A	< 1	FT-FY19-112018-000302-B	< 1
WS- 000304	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 131	Mid	WF-10022018-000304	11/19/2018	FT-FY19-112018-000304-A	< 1	FT-FY19-112018-000304-B	< 1
WS- 000305	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 135	Left	WF-10022018-000305	11/19/2018	FT-FY19-112018-000305-A	< 1	FT-FY19-112018-000305-B	< 1
WS- 000306	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 135	Right	WF-04052018-000306	11/19/2018	FT-FY19-112018-000306-A	< 1	FT-FY19-112018-000306-B	< 1
WS- 000311	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 130		WF-10022018-000311	11/19/2018	FT-FY19-112018-000311-A	< 1	FT-FY19-112018-000311-B	< 1
WS- 000312	10/2/2018	10/2/2019	1	Combo Faucet	In classroom 132	Mid	WF-10022018-000312	11/19/2018	FT-FY19-112018-000312-A	< 1	FT-FY19-112018-000312-B	< 1
WS- 000314	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 130		WF-04052018-000314	11/19/2018	FT-FY19-112018-000314-A	< 1	FT-FY19-112018-000314-B	< 1
WS- 000317	4/5/2018	4/5/2019	1	Combo Fountain	In classroom 132	Right	WF-04052018-000317	11/19/2018	FT-FY19-112018-000317-A	< 1	FT-FY19-112018-000317-B	< 1
WS- 000320	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 238	Right	WF-04052018-000320	11/19/2018	FT-FY19-112018-000320-A	< 1	FT-FY19-112018-000320-B	< 1
WS- 000322	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 234	Left	WF-04052018-000322	11/19/2018	FT-FY19-112018-000322-A	< 1	FT-FY19-112018-000322-B	< 1
WS- 000334	4/5/2018	4/5/2019	2	Cooler	In hallway adjacent to room 234	Left	WF-04052018-000334	11/19/2018	FT-FY19-112018-000334-A	< 1	FT-FY19-112018-000334-B	< 1
WS- 000335	4/5/2018	4/5/2019	2	Cooler	In hallway adjacent to room 234	Right	WF-04052018-000335	11/20/2018	FT-FY19-112018-000335-A	< 1	FT-FY19-112018-000335-B	< 1
WS- 000339	4/5/2018	4/5/2019	2	Combo Fountain	In common area adjacent to room 228	Right	WF-04052018-000339	11/19/2018	FT-FY19-112018-000339-A	< 1	FT-FY19-112018-000339-B	< 1
WS- 000346	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 251	Left	WF-04052018-000346	11/19/2018	FT-FY19-112018-000346-A	< 1	FT-FY19-112018-000346-B	< 1
WS- 000355	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 253	Right	WF-04052018-000355	11/19/2018	FT-FY19-112018-000355-A	< 1	FT-FY19-112018-000355-B	< 1
WS- 000358	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 249	Right	WF-04052018-000358	11/19/2018	FT-FY19-112018-000358-A	< 1	FT-FY19-112018-000358-B	< 1
WS- 000360	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 243	Right	WF-04052018-000360	11/19/2018	FT-FY19-112018-000360-A	< 1	FT-FY19-112018-000360-B	< 1
WS- 000364	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 241	Right	WF-04052018-000364	11/19/2018	FT-FY19-112018-000364-A	< 1	FT-FY19-112018-000364-B	< 1
WS- 000366	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 233	Left	WF-04052018-000366	11/19/2018	FT-FY19-112018-000366-A	< 1	FT-FY19-112018-000366-B	< 1
WS- 000369	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 231	Right	WF-04052018-000369	11/19/2018	FT-FY19-112018-000369-A	< 1	FT-FY19-112018-000369-B	< 1
WS- 000373	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 227	Left	WF-04052018-000373	11/19/2018	FT-FY19-112018-000373-A	< 1	FT-FY19-112018-000373-B	< 1
WS- 000375	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 229	Right	WF-04052018-000375	11/19/2018	FT-FY19-112018-000375-A	< 1	FT-FY19-112018-000375-B	< 1
WS- 000376	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 219	Left	WF-04052018-000376	11/19/2018	FT-FY19-112018-000376-A	< 1	FT-FY19-112018-000376-B	< 1
WS- 000379	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 217	Right	WF-04052018-000379	11/19/2018	FT-FY19-112018-000379-A	< 1	FT-FY19-112018-000379-B	< 1
WS- 000380	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 215	Left	WF-04052018-000380	11/19/2018	FT-FY19-112018-000380-A	< 1	FT-FY19-112018-000380-B	< 1
WS- 000382	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 225	Right	WF-04052018-000382	11/19/2018	FT-FY19-112018-000382-A	< 1	FT-FY19-112018-000382-B	< 1
WS- 000384	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 213	Right	WF-04052018-000384	11/19/2018	FT-FY19-112018-000384-A	< 1	FT-FY19-112018-000384-B	< 1
WS- 000386	10/2/2018	10/2/2019	2	Combo Faucet	In classroom 211	Right	WF-10022018-000386	11/19/2018	FT-FY19-112018-000386-A	< 1	FT-FY19-112018-000386-B	< 1
WS- 000389	4/5/2018	4/5/2019	2	Combo Fountain	In common area adjacent to room 212	Right	WF-04052018-000389	11/19/2018	FT-FY19-112018-000389-A	< 1	FT-FY19-112018-000389-B	< 1
WS- 000390	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 209		WF-04052018-000390	11/19/2018	FT-FY19-112018-000390-A	< 1	FT-FY19-112018-000390-B	< 1
WS- 000391	4/5/2018	4/5/2019	2	Combo Fountain	In classroom 211	Left	WF-04052018-000391	11/19/2018	FT-FY19-112018-000391-A	< 1	FT-FY19-112018-000391-B	< 1
WS- 000392	4/5/2018	4/5/2019	2	Combo Fountain	In resource room 212	Left	WF-04052018-000392	11/19/2018	FT-FY19-112018-000392-A	< 1	FT-FY19-112018-000392-B	< 1
WS- 000393	10/2/2018	10/2/2019	2	Combo Faucet	In resource room 212	Right	WF-10022018-000393	11/19/2018	FT-FY19-112018-000393-A	< 1	FT-FY19-112018-000393-B	< 1
WS- 000394	4/5/2018	4/5/2019	2	Fountain	In hallway, adjacent to girls restroom and room 206		WF-04052018-000394	11/19/2018	FT-FY19-112018-000394-A	< 1	FT-FY19-112018-000394-B	< 1
WS- 000395	10/2/2018	10/2/2019	2	Classroom Faucet	In music room 206	Right	WF-10022018-000395	11/19/2018	FT-FY19-112018-000395-A	< 1	FT-FY19-112018-000395-B	< 1

WS- 000397	4/5/2018	4/5/2019	2	Fountain	In hallway adjacent to room 206		WF-04052018-000397	11/19/2018	FT-FY19-112018-000397-A	< 1	FT-FY19-112018-000397-B	< 1
WS- 000398	4/5/2018	4/5/2019	1	Fountain	In hallway adjacent to room 136	High Right	WF-04052018-000398	11/19/2018	FT-FY19-112018-000398-A	< 1	FT-FY19-112018-000398-B	< 1
WS- 000399	4/5/2018	4/5/2019	1	Fountain	In hallway adjacent to room 136	Low Left	WF-04052018-000399	11/19/2018	FT-FY19-112018-000399-A	< 1	FT-FY19-112018-000399-B	< 1
WS- 000400	4/5/2018	4/5/2019	1	Fountain	In hallway adjacent to room 146	Low Left	WF-04052018-000400	11/19/2018	FT-FY19-112018-000400-A	< 1	FT-FY19-112018-000400-B	< 1
WS- 000401	4/5/2018	4/5/2019	1	Fountain	In hallway adjacent to room 146	High Right	WF-04052018-000401	11/19/2018	FT-FY19-112018-000401-A	< 1	FT-FY19-112018-000401-B	< 1
WS- 012573	4/5/2018	4/5/2019	1	Break Room	In work room 171		WF-04052018-012573	11/19/2018	FT-FY19-112018-012573-A	< 1	FT-FY19-112018-012573-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000255	1	Food Prep Sink	In kitchen third clockwise from entry door	Mid		11/19/2018	FT-FY19-112018-000255-A	< 1	FT-FY19-112018-000255-B	< 1	
WS- 000256	1	Food Prep Sink	In kitchen fourth clockwise from entry door	Right		11/19/2018	FT-FY19-112018-000256-A	< 1	FT-FY19-112018-000256-B	< 1	