



Miner Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000257	2/20/2023	2/20/2024	1	Break Room	In cafeteria staff lounge	WF-02202023-000257	12/21/2023	FT-FY24-11272023-000257-A	<1	FT-FY24-11272023-000257-B	<1
WS- 000258	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 101 Left	WF-08222023-000258	12/21/2023	FT-FY24-11272023-000258-A	1.7	FT-FY24-11272023-000258-B	<1
WS- 000259	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 103 Left	WF-02202023-000259	12/21/2023	FT-FY24-11272023-000259-A	<1	FT-FY24-11272023-000259-B	<1
WS- 000260	2/20/2023	2/20/2024	1	Health Suite	In health suite	WF-02202023-000260	12/21/2023	FT-FY24-11272023-000260-A	<1	FT-FY24-11272023-000260-B	<1
WS- 000261	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 103 Right	WF-08222023-000261	12/21/2023	FT-FY24-11272023-000261-A	<1	FT-FY24-11272023-000261-B	<1
WS- 000262	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 101 Left	WF-02202023-000262	12/21/2023	FT-FY24-11272023-000262-A	<1	FT-FY24-11272023-000262-B	<1
WS- 000263	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 105	WF-08222023-000263	12/21/2023	FT-FY24-11272023-000263-A	<1	FT-FY24-11272023-000263-B	<1
WS- 000264	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 111 Left	WF-02202023-000264	12/21/2023	FT-FY24-11272023-000264-A	<1	FT-FY24-11272023-000264-B	<1
WS- 000265	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 105	WF-02202023-000265	12/21/2023	FT-FY24-11272023-000265-A	<1	FT-FY24-11272023-000265-B	<1
WS- 000266	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 107 Left	WF-08222023-000266	12/21/2023	FT-FY24-11272023-000266-A	<1	FT-FY24-11272023-000266-B	<1
WS- 000267	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 109	WF-08222023-000267	12/21/2023	FT-FY24-11272023-000267-A	<1	FT-FY24-11272023-000267-B	<1
WS- 000268	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 107 Left	WF-02202023-000268	12/21/2023	FT-FY24-11272023-000268-A	<1	FT-FY24-11272023-000268-B	<1
WS- 000269	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 109	WF-02202023-000269	12/21/2023	FT-FY24-11272023-000269-A	<1	FT-FY24-11272023-000269-B	<1
WS- 000270	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 117	WF-08222023-000270	12/21/2023	FT-FY24-11272023-000270-A	<1	FT-FY24-11272023-000270-B	<1
WS- 000271	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 115 Left	WF-08222023-000271	12/21/2023	FT-FY24-11272023-000271-A	3.1	FT-FY24-11272023-000271-B	<1
WS- 000272	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 117	WF-02202023-000272	12/21/2023	FT-FY24-11272023-000272-A	<1	FT-FY24-11272023-000272-B	<1
WS- 000273	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 111 Mid	WF-08222023-000273	12/21/2023	FT-FY24-11272023-000273-A	<1	FT-FY24-11272023-000273-B	<1
WS- 000274	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 115 Left	WF-02202023-000274	12/21/2023	FT-FY24-11272023-000274-A	<1	FT-FY24-11272023-000274-B	<1
WS- 000275	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 119	WF-08222023-000275	12/21/2023	FT-FY24-11272023-000275-A	<1	FT-FY24-11272023-000275-B	<1
WS- 000276	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 119	WF-02202023-000276	12/21/2023	FT-FY24-11272023-000276-A	<1	FT-FY24-11272023-000276-B	<1
WS- 000277	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 121 Right	WF-02202023-000277	12/21/2023	FT-FY24-11272023-000277-A	<1	FT-FY24-11272023-000277-B	<1
WS- 000278	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 123 Left	WF-08222023-000278	12/21/2023	FT-FY24-11272023-000278-A	<1	FT-FY24-11272023-000278-B	<1
WS- 000279	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 123 Left	WF-02202023-000279	12/21/2023	FT-FY24-11272023-000279-A	<1	FT-FY24-11272023-000279-B	<1
WS- 000280	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 121 Mid	WF-08222023-000280	12/21/2023	FT-FY24-11272023-000280-A	<1	FT-FY24-11272023-000280-B	<1
WS- 000281	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 129	WF-08222023-000281	12/21/2023	FT-FY24-11272023-000281-A	<1	FT-FY24-11272023-000281-B	<1
WS- 000283	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 129	WF-02202023-000283	12/21/2023	FT-FY24-11272023-000283-A	<1	FT-FY24-11272023-000283-B	<1
WS- 000284	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 133 Mid	WF-08222023-000284	12/21/2023	FT-FY24-11272023-000284-A	1.2	FT-FY24-11272023-000284-B	<1
WS- 000286	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 137 Right	WF-08222023-000286	12/21/2023	FT-FY24-11272023-000286-A	1.2	FT-FY24-11272023-000286-B	<1
WS- 000288	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 137 Left	WF-02202023-000288	12/21/2023	FT-FY24-11272023-000288-A	<1	FT-FY24-11272023-000288-B	<1
WS- 000291	2/20/2023	2/20/2024	1	Combo Fountain	In common area adjacent to room 128 Right	WF-02202023-000291	12/21/2023	FT-FY24-11272023-000291-A	<1	FT-FY24-11272023-000291-B	<1
WS- 000293	2/20/2023	2/20/2024	1	Combo Fountain	In common area adjacent to room 112 Left	WF-02202023-000293	12/21/2023	FT-FY24-11272023-000293-A	<1	FT-FY24-11272023-000293-B	<1
WS- 000297	2/20/2023	2/20/2024	1	Break Room	In laundry room 112 Mid	WF-02202023-000297	12/21/2023	FT-FY24-11272023-000297-A	1.3	FT-FY24-11272023-000297-B	<1
WS- 000300	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 127	WF-08222023-000300	12/21/2023	FT-FY24-11272023-000300-A	<1	FT-FY24-11272023-000300-B	<1
WS- 000301	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 131 Right	WF-02202023-000301	12/21/2023	FT-FY24-11272023-000301-A	<1	FT-FY24-11272023-000301-B	<1

WS- 000302	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 127	Left	WF-02202023-000302	12/21/2023	FT-FY24-11272023-000302-A	<1	FT-FY24-11272023-000302-B	<1
WS- 000304	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 131	Mid	WF-08222023-000304	12/21/2023	FT-FY24-11272023-000304-A	<1	FT-FY24-11272023-000304-B	<1
WS- 000305	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 135	Left	WF-08222023-000305	12/21/2023	FT-FY24-11272023-000305-A	<1	FT-FY24-11272023-000305-B	<1
WS- 000306	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 135	Right	WF-02202023-000306	12/21/2023	FT-FY24-11272023-000306-A	<1	FT-FY24-11272023-000306-B	<1
WS- 000311	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 130		WF-08222023-000311	12/21/2023	FT-FY24-11272023-000311-A	1.6	FT-FY24-11272023-000311-B	<1
WS- 000312	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 132	Mid	WF-08222023-000312	12/21/2023	FT-FY24-11272023-000312-A	4.8	FT-FY24-11272023-000312-B	<1
WS- 000314	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 130		WF-02202023-000314	12/21/2023	FT-FY24-11272023-000314-A	<1	FT-FY24-11272023-000314-B	<1
WS- 000317	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 132	Right	WF-02202023-000317	12/21/2023	FT-FY24-11272023-000317-A	<1	FT-FY24-11272023-000317-B	<1
WS- 000320	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 238	Right	WF-02202023-000320	12/21/2023	FT-FY24-11272023-000320-A	1.3	FT-FY24-11272023-000320-B	<1
WS- 000322	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 234	Left	WF-02202023-000322	12/21/2023	FT-FY24-11272023-000322-A	1.1	FT-FY24-11272023-000322-B	<1
WS- 000334	2/20/2023	2/20/2024	2	Cooler	In hallway adjacent to room 234	Left	WF-02202023-000334	12/21/2023	FT-FY24-11272023-000334-A	<1	FT-FY24-11272023-000334-B	<1
WS- 000335	2/20/2023	2/20/2024	2	Cooler	In hallway adjacent to room 234	Right	WF-02202023-000335	12/21/2023	FT-FY24-11272023-000335-A	<1	FT-FY24-11272023-000335-B	<1
WS- 000346	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 251	Left	WF-02202023-000346	12/21/2023	FT-FY24-11272023-000346-A	<1	FT-FY24-11272023-000346-B	<1
WS- 000355	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 253	Right	WF-02202023-000355	12/21/2023	FT-FY24-11272023-000355-A	<1	FT-FY24-11272023-000355-B	<1
WS- 000360	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 243	Right	WF-02202023-000360	12/21/2023	FT-FY24-11272023-000360-A	<1	FT-FY24-11272023-000360-B	<1
WS- 000364	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 241	Right	WF-02202023-000364	12/21/2023	FT-FY24-11272023-000364-A	<1	FT-FY24-11272023-000364-B	<1
WS- 000366	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 233	Left	WF-02202023-000366	12/21/2023	FT-FY24-11272023-000366-A	4.9	FT-FY24-11272023-000366-B	<1
WS- 000369	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 231	Right	WF-02202023-000369	12/21/2023	FT-FY24-11272023-000369-A	<1	FT-FY24-11272023-000369-B	<1
WS- 000373	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 227	Left	WF-02202023-000373	12/21/2023	FT-FY24-11272023-000373-A	<1	FT-FY24-11272023-000373-B	<1
WS- 000375	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 229	Right	WF-02202023-000375	12/21/2023	FT-FY24-11272023-000375-A	<1	FT-FY24-11272023-000375-B	<1
WS- 000376	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 219	Left	WF-02202023-000376	12/21/2023	FT-FY24-11272023-000376-A	<1	FT-FY24-11272023-000376-B	<1
WS- 000379	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 217	Right	WF-02202023-000379	12/21/2023	FT-FY24-11272023-000379-A	<1	FT-FY24-11272023-000379-B	<1
WS- 000380	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 215	Left	WF-02202023-000380	12/21/2023	FT-FY24-11272023-000380-A	<1	FT-FY24-11272023-000380-B	<1
WS- 000382	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 225	Right	WF-02202023-000382	12/21/2023	FT-FY24-11272023-000382-A	<1	FT-FY24-11272023-000382-B	<1
WS- 000384	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 213	Right	WF-02202023-000384	12/21/2023	FT-FY24-11272023-000384-A	<1	FT-FY24-11272023-000384-B	<1
WS- 000386	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 211	Right	WF-08222023-000386	12/21/2023	FT-FY24-11272023-000386-A	2.8	FT-FY24-11272023-000386-B	2.7
WS- 000389	2/20/2023	2/20/2024	2	Combo Fountain	In common area adjacent to room 212	Right	WF-02202023-000389	12/21/2023	FT-FY24-11272023-000389-A	<1	FT-FY24-11272023-000389-B	<1
WS- 000390	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 209		WF-02202023-000390	12/21/2023	FT-FY24-11272023-000390-A	<1	FT-FY24-11272023-000390-B	<1
WS- 000391	2/20/2023	2/20/2024	2	Combo Fountain	In classroom 211	Left	WF-02202023-000391	12/21/2023	FT-FY24-11272023-000391-A	<1	FT-FY24-11272023-000391-B	<1
WS- 000393	8/22/2023	8/22/2024	2	Combo Faucet	In resource room 212	Right	WF-08222023-000393	12/21/2023	FT-FY24-11272023-000393-A	<1	FT-FY24-11272023-000393-B	<1
WS- 000394	2/20/2023	2/20/2024	2	Cooler	In hallway, adjacent to girls restroom and room 206		WF-02202023-000394	12/21/2023	FT-FY24-11272023-000394-A	<1	FT-FY24-11272023-000394-B	<1
WS- 000395	8/22/2023	8/22/2024	2	Classroom Faucet	In music room 206	Right	WF-08222023-000395	12/21/2023	FT-FY24-11272023-000395-A	2.2	FT-FY24-11272023-000395-B	1.1
WS- 000397	2/20/2023	2/20/2024	2	Cooler	In hallway adjacent to boys restroom and room 212		WF-02202023-000397	12/21/2023	FT-FY24-11272023-000397-A	<1	FT-FY24-11272023-000397-B	<1
WS- 000398	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 136	High Right	WF-02202023-000398	12/21/2023	FT-FY24-11272023-000398-A	<1	FT-FY24-11272023-000398-B	<1
WS- 000399	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 136	Low Left	WF-02202023-000399	12/21/2023	FT-FY24-11272023-000399-A	<1	FT-FY24-11272023-000399-B	<1
WS- 000400	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 146	Low Left	WF-02202023-000400	12/21/2023	FT-FY24-11272023-000400-A	<1	FT-FY24-11272023-000400-B	<1
WS- 000401	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 146	High Right	WF-02202023-000401	12/21/2023	FT-FY24-11272023-000401-A	<1	FT-FY24-11272023-000401-B	<1
WS- 000710	2/17/2023	2/17/2024	2	Bottle Filler	In hallway adjacent to room 234	Left	WF-02172023-000710	12/21/2023	FT-FY24-11272023-000710-A	<1	FT-FY24-11272023-000710-B	<1
WS- 000711	3/1/2023	3/1/2024	2	Bottle Filler	In hallway adjacent to room 234	Right	WF-03012023-000711	12/21/2023	FT-FY24-11272023-000711-A	<1	FT-FY24-11272023-000711-B	<1
WS- 000712	2/20/2023	2/20/2024	2	Bottle Filler	In hallway, adjacent to girls restroom and room 206	Left	WF-02202023-000712	12/21/2023	FT-FY24-11272023-000712-A	<1	FT-FY24-11272023-000712-B	<1

WS- 000713	2/20/2023	2/20/2024	2	Bottle Filler	In hallway adjacent to boys restroom and room 212	Right	WF-02202023-000713	12/21/2023	FT-FY24-11272023-000713-A	<1	FT-FY24-11272023-000713-B	<1
WS- 000714	2/20/2023	2/20/2024	1	Bottle Filler	In hallway adjacent to room 136		WF-02202023-000714	12/21/2023	FT-FY24-11272023-000714-A	<1	FT-FY24-11272023-000714-B	<1
WS- 000715	2/20/2023	2/20/2024	1	Bottle Filler	In hallway adjacent to room 146		WF-02202023-000715	12/21/2023	FT-FY24-11272023-000715-A	<1	FT-FY24-11272023-000715-B	<1
WS- 012573	2/20/2023	2/20/2024	1	Break Room	In work room 171		WF-02202023-012573	12/21/2023	FT-FY24-11272023-012573-A	<1	FT-FY24-11272023-012573-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000256	1/18/2023	1/18/2024	1	Food Prep Sink	In kitchen fourth clockwise from entry door	Right	WF-01182023-000256	12/21/2023	FT-FY24-11272023-000256-A	<1	FT-FY24-11272023-000256-B	<1