



# Moten Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002322	6/22/2020	6/22/2021	1	Break Room	In administrative work room 113	WF-06222020-002322	1/14/2021	FT-FY21-012021-002322-A	2.4	FT-FY21-012021-002322-B	<1
WS-004318	6/22/2020	6/22/2021	Basement	Cooler	In hallway across from room B08	WF-06222020-004318	1/14/2021	FT-FY21-012021-004318-A	<1	FT-FY21-012021-004318-B	<1
WS-004319	9/22/2020	9/22/2021	Basement	Classroom Faucet	In classroom B07	WF-09222020-004319	1/14/2021	FT-FY21-012021-004319-A	<1	FT-FY21-012021-004319-B	<1
WS-004320	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G01	WF-09222020-004320	1/14/2021	FT-FY21-012021-004320-A	1.7	FT-FY21-012021-004320-B	<1
WS-004321	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G05	WF-09222020-004321	1/14/2021	FT-FY21-012021-004321-A	2.4	FT-FY21-012021-004321-B	<1
WS-004322	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G06 High Left	WF-06222020-004322	1/14/2021	FT-FY21-012021-004322-A	<1	FT-FY21-012021-004322-B	<1
WS-004323	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G06 Low Right	WF-06222020-004323	1/14/2021	FT-FY21-012021-004323-A	<1	FT-FY21-012021-004323-B	<1
WS-004329	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G10 High Left	WF-06222020-004329	1/14/2021	FT-FY21-012021-004329-A	<1	FT-FY21-012021-004329-B	<1
WS-004330	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G10 Low Right	WF-06222020-004330	1/14/2021	FT-FY21-012021-004330-A	<1	FT-FY21-012021-004330-B	<1
WS-004331	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G14	WF-09222020-004331	1/14/2021	FT-FY21-012021-004331-A	1.3	FT-FY21-012021-004331-B	<1
WS-004332	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G17	WF-09222020-004332	1/14/2021	FT-FY21-012021-004332-A	<1	FT-FY21-012021-004332-B	<1
WS-004333	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G25	WF-06222020-004333	1/14/2021	FT-FY21-012021-004333-A	<1	FT-FY21-012021-004333-B	<1
WS-004334	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G29	WF-09222020-004334	1/14/2021	FT-FY21-012021-004334-A	1.5	FT-FY21-012021-004334-B	<1
WS-004335	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G30	WF-09222020-004335	1/14/2021	FT-FY21-012021-004335-A	1.8	FT-FY21-012021-004335-B	<1
WS-004336	9/22/2020	9/22/2021	Ground Floor	Classroom Faucet	In classroom G31	WF-09222020-004336	1/14/2021	FT-FY21-012021-004336-A	2.7	FT-FY21-012021-004336-B	<1
WS-004337	6/22/2020	6/22/2021	Ground Floor	Cooler	In hallway adjacent to room G31	WF-06222020-004337	1/14/2021	FT-FY21-012021-004337-A	<1	FT-FY21-012021-004337-B	<1
WS-004338	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to girls' restroom 103 High Left	WF-06222020-004338	1/14/2021	FT-FY21-012021-004338-A	<1	FT-FY21-012021-004338-B	<1
WS-004339	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to girls' restroom 103 Low Right	WF-06222020-004339	1/14/2021	FT-FY21-012021-004339-A	<1	FT-FY21-012021-004339-B	<1
WS-004342	6/22/2020	6/22/2021	1	Health Suite	In health suite	WF-06222020-004342	1/14/2021	FT-FY21-012021-004342-A	<1	FT-FY21-012021-004342-B	<1
WS-004343	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 119 High Left	WF-06222020-004343	1/14/2021	FT-FY21-012021-004343-A	<1	FT-FY21-012021-004343-B	<1
WS-004344	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 119 Low Right	WF-06222020-004344	1/14/2021	FT-FY21-012021-004344-A	<1	FT-FY21-012021-004344-B	<1
WS-004346	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 124	WF-06222020-004346	1/14/2021	FT-FY21-012021-004346-A	<1	FT-FY21-012021-004346-B	<1
WS-004347	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 130	WF-09222020-004347	1/14/2021	FT-FY21-012021-004347-A	2.6	FT-FY21-012021-004347-B	<1
WS-004350	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 134	WF-06222020-004350	1/14/2021	FT-FY21-012021-004350-A	<1	FT-FY21-012021-004350-B	<1
WS-004351	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 224B	WF-06222020-004351	1/14/2021	FT-FY21-012021-004351-A	<1	FT-FY21-012021-004351-B	<1
WS-004352	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 203A High Left	WF-06222020-004352	1/14/2021	FT-FY21-012021-004352-A	<1	FT-FY21-012021-004352-B	<1
WS-004353	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 203A Low Right	WF-06222020-004353	1/14/2021	FT-FY21-012021-004353-A	<1	FT-FY21-012021-004353-B	<1
WS-004356	6/22/2020	6/22/2021	2	Break Room	In break room 208	WF-06222020-004356	1/14/2021	FT-FY21-012021-004356-A	<1	FT-FY21-012021-004356-B	<1
WS-004357	6/22/2020	6/22/2021	2	Cooler	In hallway across from room 210 High Left	WF-06222020-004357	1/14/2021	FT-FY21-012021-004357-A	<1	FT-FY21-012021-004357-B	<1
WS-004358	6/22/2020	6/22/2021	2	Cooler	In hallway across from room 210 Low Right	WF-06222020-004358	1/14/2021	FT-FY21-012021-004358-A	<1	FT-FY21-012021-004358-B	<1
WS-004364	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 216	WF-06222020-004364	1/14/2021	FT-FY21-012021-004364-A	<1	FT-FY21-012021-004364-B	<1
WS-004366	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 301 High Left	WF-06222020-004366	1/14/2021	FT-FY21-012021-004366-A	<1	FT-FY21-012021-004366-B	<1

WS- 004367	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 301	Low	Right	WF-06222020-004367	1/14/2021	FT-FY21-012021-004367-A	<1	FT-FY21-012021-004367-B	<1
WS- 004374	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 312	High	Left	WF-06222020-004374	1/14/2021	FT-FY21-012021-004374-A	<1	FT-FY21-012021-004374-B	<1
WS- 004375	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 312	Low	Right	WF-06222020-004375	1/14/2021	FT-FY21-012021-004375-A	<1	FT-FY21-012021-004375-B	<1
WS- 004378	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 317			WF-06222020-004378	1/14/2021	FT-FY21-012021-004378-A	<1	FT-FY21-012021-004378-B	<1
WS- 004383	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 327			WF-06222020-004383	1/14/2021	FT-FY21-012021-004383-A	<1	FT-FY21-012021-004383-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004324	2/24/2020	2/24/2021	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	Low	WF-02242020-004324	1/14/2021	FT-FY21-012021-004324-A	<1	FT-FY21-012021-004324-B	<1