



Moten ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002322	5/8/2019	5/8/2020	1	Break Room	In administrative work room 113	WF-05082019-002322	10/22/2019	FT-FY20-102019-002322-A	<1	FT-FY20-102019-002322-B	<1
WS- 004318	5/8/2019	5/8/2020	Basement	Cooler	In hallway across from room B08	WF-05082019-004318	10/22/2019	FT-FY20-102019-004318-A	<1	FT-FY20-102019-004318-B	<1
WS- 004319	9/30/2019	9/30/2020	Basement	Classroom Faucet	In classroom B07	WF-09302019-004319	10/22/2019	FT-FY20-102019-004319-A	<1	FT-FY20-102019-004319-B	<1
WS- 004320	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G01	WF-09302019-004320	10/22/2019	FT-FY20-102019-004320-A	<1	FT-FY20-102019-004320-B	<1
WS- 004321	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G05	WF-09302019-004321	10/22/2019	FT-FY20-102019-004321-A	<1	FT-FY20-102019-004321-B	<1
WS- 004322	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G06 High Left	WF-05082019-004322	10/22/2019	FT-FY20-102019-004322-A	<1	FT-FY20-102019-004322-B	<1
WS- 004323	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G06 Low Right	WF-05082019-004323	10/22/2019	FT-FY20-102019-004323-A	1.1	FT-FY20-102019-004323-B	<1
WS- 004329	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G10 High Left	WF-05082019-004329	10/22/2019	FT-FY20-102019-004329-A	<1	FT-FY20-102019-004329-B	<1
WS- 004330	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G10 Low Right	WF-05082019-004330	10/22/2019	FT-FY20-102019-004330-A	<1	FT-FY20-102019-004330-B	<1
WS- 004331	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G14	WF-09302019-004331	10/22/2019	FT-FY20-102019-004331-A	1.3	FT-FY20-102019-004331-B	<1
WS- 004332	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G17	WF-09302019-004332	10/22/2019	FT-FY20-102019-004332-A	<1	FT-FY20-102019-004332-B	<1
WS- 004333	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G25	WF-05082019-004333	10/22/2019	FT-FY20-102019-004333-A	<1	FT-FY20-102019-004333-B	<1
WS- 004334	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G29	WF-09302019-004334	10/22/2019	FT-FY20-102019-004334-A	1.3	FT-FY20-102019-004334-B	<1
WS- 004335	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G30	WF-09302019-004335	10/22/2019	FT-FY20-102019-004335-A	<1	FT-FY20-102019-004335-B	<1
WS- 004336	9/30/2019	9/30/2020	Ground Floor	Classroom Faucet	In classroom G31	WF-09302019-004336	10/22/2019	FT-FY20-102019-004336-A	<1	FT-FY20-102019-004336-B	<1
WS- 004337	5/8/2019	5/8/2020	Ground Floor	Cooler	In hallway adjacent to room G31	WF-05082019-004337	10/22/2019	FT-FY20-102019-004337-A	<1	FT-FY20-102019-004337-B	<1
WS- 004338	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to girls' restroom 103 High Left	WF-05082019-004338	10/22/2019	FT-FY20-102019-004338-A	<1	FT-FY20-102019-004338-B	<1
WS- 004339	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to girls' restroom 103 Low Right	WF-05082019-004339	10/22/2019	FT-FY20-102019-004339-A	<1	FT-FY20-102019-004339-B	<1
WS- 004342	5/8/2019	5/8/2020	1	Health Suite	In health suite	WF-05082019-004342	10/22/2019	FT-FY20-102019-004342-A	<1	FT-FY20-102019-004342-B	<1
WS- 004343	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to room 119 High Left	WF-05082019-004343	10/22/2019	FT-FY20-102019-004343-A	<1	FT-FY20-102019-004343-B	<1
WS- 004344	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to room 119 Low Right	WF-05082019-004344	10/22/2019	FT-FY20-102019-004344-A	<1	FT-FY20-102019-004344-B	<1
WS- 004346	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to room 124	WF-05082019-004346	10/22/2019	FT-FY20-102019-004346-A	<1	FT-FY20-102019-004346-B	<1
WS- 004347	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 130	WF-09302019-004347	10/22/2019	FT-FY20-102019-004347-A	<1	FT-FY20-102019-004347-B	<1
WS- 004350	5/8/2019	5/8/2020	1	Cooler	In hallway adjacent to room 134	WF-05082019-004350	10/22/2019	FT-FY20-102019-004350-A	<1	FT-FY20-102019-004350-B	<1
WS- 004351	5/8/2019	5/8/2020	2	Cooler	In hallway adjacent to room 224B	WF-05082019-004351	10/22/2019	FT-FY20-102019-004351-A	<1	FT-FY20-102019-004351-B	<1
WS- 004352	5/8/2019	5/8/2020	2	Cooler	In hallway adjacent to room 203A High Left	WF-05082019-004352	10/22/2019	FT-FY20-102019-004352-A	<1	FT-FY20-102019-004352-B	<1
WS- 004353	5/8/2019	5/8/2020	2	Cooler	In hallway adjacent to room 203A Low Right	WF-05082019-004353	10/22/2019	FT-FY20-102019-004353-A	<1	FT-FY20-102019-004353-B	<1
WS- 004356	5/8/2019	5/8/2020	2	Break Room	In break room 208	WF-05082019-004356	10/22/2019	FT-FY20-102019-004356-A	<1	FT-FY20-102019-004356-B	<1
WS- 004357	5/8/2019	5/8/2020	2	Cooler	In hallway across from room 210 High Left	WF-05082019-004357	10/22/2019	FT-FY20-102019-004357-A	<1	FT-FY20-102019-004357-B	<1
WS- 004358	5/8/2019	5/8/2020	2	Cooler	In hallway across from room 210 Low Right	WF-05082019-004358	10/22/2019	FT-FY20-102019-004358-A	<1	FT-FY20-102019-004358-B	<1
WS- 004364	5/8/2019	5/8/2020	2	Cooler	In hallway adjacent to room 216	WF-05082019-004364	10/22/2019	FT-FY20-102019-004364-A	<1	FT-FY20-102019-004364-B	<1
WS- 004366	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 301 High Left	WF-05082019-004366	10/22/2019	FT-FY20-102019-004366-A	<1	FT-FY20-102019-004366-B	<1
WS- 004367	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 301 Low Right	WF-05082019-004367	10/22/2019	FT-FY20-102019-004367-A	<1	FT-FY20-102019-004367-B	<1
WS- 004374	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 312 High Left	WF-05082019-004374	10/22/2019	FT-FY20-102019-004374-A	<1	FT-FY20-102019-004374-B	<1

WS- 004375	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 312	Low Right	WF-05082019-004375	10/22/2019	FT-FY20-102019-004375-A	<1	FT-FY20-102019-004375-B	<1
WS- 004378	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 317		WF-05082019-004378	10/22/2019	FT-FY20-102019-004378-A	<1	FT-FY20-102019-004378-B	<1
WS- 004383	5/8/2019	5/8/2020	3	Cooler	In hallway adjacent to room 327		WF-05082019-004383	10/22/2019	FT-FY20-102019-004383-A	<1	FT-FY20-102019-004383-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004324	7/1/2019	7/1/2020	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	Low	WF-07012019-004324	10/22/2019	FT-FY20-102019-004324-A	<1	FT-FY20-102019-004324-B	<1